APPENDIX A

NOTICE OF VIOLATION

Pacific Gas and Electric Company 77 Beale Street, Room 1451 San Francisco, California 94106 Docket No. 50-323 License No. DPR-82

As a result of the inspection conducted during the period of January 26 through March 1, 1986, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), the following violation was identified:

A. Technical Specification surveillance requirement 4.6.1.1.a states that containment integrity shall be demonstrated during modes 1-4, "At lease once per 31 days by verifying that all penetrations not capable of being closed by OPERABLE containment automatic isolation valves and required to be closed during accident conditions are closed by valves, blind flanges, or deactivated automatic valves secured in their positions..."

Contrary to the above, a spare instrument test line through penetration 82 was not included as part of the containment integrity surveillance program and, as such, had not been verified capped and sealed since commencement of initial operation in July 1985.

This is a Severity Level IV Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Pacific Gas and Electric Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement of explanation in reply including: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further items of noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

MAR 11 1986

Dated

R. T. Dodds, Chief

Reactor Projects Section 1

The state of the s

Total Maria Maria

The second secon

C I a F H

1

4 J