

APPENDIX A

NOTICE OF VIOLATION

Pacific Gas and Electric Company  
77 Beale Street, Room 1451  
San Francisco, California 94106

Docket No. 50-275  
License No. DPR-80

As a result of the inspection conducted during the period of May 25 through July 5, 1986, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR 50, Appendix B, Criterion XVI and the PG&E Quality Assurance Policy, Section 16, require that conditions adverse to quality are promptly identified and corrected.

Nuclear Plant Operations Administrative Procedure C-12 "Identification and Resolution of Problems and Nonconformances" requires "that conditions adverse to plant safety are promptly identified, evaluated and corrected."

Contrary to the above, the existence of a Unit 1 containment penetration line was identified on May 2, 1986 that was not included in the surveillance program. The integrity of this spare line through containment penetration 82 was not verified until May 21, 1986.

This is a Severity Level IV Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Pacific Gas and Electric Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement of explanation in reply including: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further items of noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

JUL 17 1986

\_\_\_\_\_  
Dated



\_\_\_\_\_  
M. M. Mendonca, Chief  
Reactor Projects Section 1

8608040312 860717  
PDR ADOCK 05000275  
Q PDR

CONFIDENTIAL

SECRET

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL