

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8909130365      DOC. DATE: 89/09/07      NOTARIZED: NO      DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga      05000275  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga      05000323

AUTH. NAME      AUTHOR AFFILIATION  
 SHIFFER, J.D.      Pacific Gas & Electric Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

*See Rpt*

SUBJECT: Forwards addenda to Revs 7 & 4 of inservice insp program plan for plant.

DISTRIBUTION CODE: A047D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3 + 40  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	PD5 LA		1	0	PD5 PD		5	5
	ROOD, H		1	1				
INTERNAL:	ACRS		6	6	AEOD/DSP/TPAB		1	1
	NRR/DEST/MEB 9H		1	1	NRR/DEST/MTB 9H		1	1
	NUDOCS-ABSTRACT		1	1	OC/LEMB		1	0
	OGC/HDS2		1	0	<u>REG FILE</u> 01		1	1
	RES/DSIR/EIB		1	1				
EXTERNAL:	EG&G BROWN, B		1	1	EG&G ROCKHOLD, H		1	1
	LPDR		1	1	NRC PDR		1	1
	NSIC		1	1				


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 23

*MAJ  
Cc*

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
  
  
  
  
  
  
  
  
  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



Pacific Gas and Electric Company

77 Beale Street  
San Francisco, CA 94106  
415/972-7000  
TWX 910-372-6587

James D. Shiffer  
Vice President  
Nuclear Power Generation

September 7, 1989

PG&E Letter No. DCL-89-231



U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
Addenda to Inservice Inspection Program Plans

Gentlemen:

Enclosed are addenda to revisions 7 and 4 of the Inservice Inspection (ISI) Program Plans for Diablo Canyon Units 1 and 2, respectively. These addenda provide the additional information requested by the NRC Staff regarding ISI system pressure test relief requests Nos. 8 and 9. The addenda also provide clarification and additional detail to the program unrelated to these relief requests. A summary of the relief request changes is provided below.

System Pressure Test Relief Request No. 8

Relief Request No. 8 has been revised to clarify PG&E's basis for the relief request, the proposed alternate testing, and proposed test schedules.

System Pressure Test Relief Request No. 9

The proposed alternate testing schedule has been changed from every 5 years to at least every 3 1/3 years.

PG&E understands that this additional information is sufficient for the NRC and its contractors to complete the review of revisions 7 and 4 of the ISI Program Plan. PG&E requests timely review and approval of the plan by early October 1989, since the Unit 1 refueling outage is scheduled to commence on October 13, 1989.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. D. Shiffer'. The signature is fluid and cursive, written over a white background.

J. D. Shiffer

8909130365 890907  
PDR ADOCK 05000275  
Q PDC

A047  
11  
43



Handwritten marks and scribbles in the top right corner.

Handwritten marks in the middle right area.

Handwritten marks at the bottom left.

September 7, 1989

cc w/enc: B. Brown, EG&G Idaho  
G. D. Horn, State of California  
J. B. Martin  
P. P. Narbut  
H. Rockhold, EG&G Idaho  
H. Rood  
C. Tahnk, Regional Manager, Hartford Steam Boiler

cc w/o enc: M. M. Mendonca  
B. H. Vogler  
CPUC  
Diablo Distribution

Enclosure

2825S/0071K/JHA/469



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

PACIFIC GAS AND ELECTRIC COMPANY  
Diablo Canyon Power Plant  
ISI/NDE Department  
420.9

Change to Diablo Canyon Unit 1  
Inspection and Testing  
Program Plan

Date: 9/7/89

Diablo Canyon Unit 1 ISI and IST Program Plan Receipt Acknowledgement  
M \_\_\_\_\_

You have been issued a Controlled Copy of the Diablo Canyon ISI and IST Program Plan. Here is the Addenda 1 to Revision 7 of the plan. Please revise your controlled copy as follows:

CHANGE INSTRUCTIONS

Remove the following pages from the Program Plan binder and replace with Addenda 1.

- Pumps Table 1.5 Page 3 of 5
- Section 3.5 Tables 5.1, 5.2, and 5.3 Page 1 of 1
- Test Summary Table 5.2 Pages 9,10,11,12,13 of 13
- Test Summary Table 5.3 Pages 2,3, and 4 of 4
- Test Summary Table 5.4 Pages 1 thru 9 of 9

For questions or assistance please phone the Document Control office, PG&E extension 691-4500, Pacific Bell phone (805) 595-4500.

After revising your copy of the Program Plan in accordance with these instructions, place the attached change description in the front of the manual behind the controlled copy numbered titled page.

Please acknowledge receipt of this revision by signing below and returning this form to:

Pacific Gas & Electric Co.  
Nuclear Regulatory Affairs  
77 Beale/333 Market/A6093  
San Francisco, CA 94106

Date: \_\_\_\_\_ Receipt of Controlled Copy \_\_\_\_\_  
Addenda 1 to Revision # 7 of the Diablo Canyon Unit 1  
ISI and IST Program Plan is hereby acknowledged.

\_\_\_\_\_  
RECIPIENT SIGNATURE

8909130365

