

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204140184    DOC. DATE: 91/12/31    NOTARIZED: NO    DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga    05000275  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga    05000323  
 AUTH. NAME    AUTHOR AFFILIATION  
 TOWNSEND, J.D.    Pacific Gas & Electric Co.  
 RECIP. NAME    RECIPIENT AFFILIATION

LEONARD, W.R.    California, State of

SUBJECT: "NPDES Discharge Monitoring Rept for 1991 for Diablo Canyon Power Plant." W/920226 ltr.

DISTRIBUTION CODE: IE48D    COPIES RECEIVED: LTR 1 ENCL 1    SIZE: 77  
 TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES: *See Enviro Rpts*

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL	
	PD5	LA	3	3		PD5	PD	1	1	
		ROOD, H	1	1						
INTERNAL:	ACRS		1	1		NRR/DREP/PRPB11		2	2	
	<del>REG FILE</del>	01	1	1		RGN5 DRSS/RPB		2	2	
	RGN5	FILE 02	1	1						
EXTERNAL:	BNL	TICHLER, J03	1	1		EG&G	SIMPSON, F	2	2	
		NRC PDR	1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 16

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

1952

10/10

10/10

10/10

1

10/10

Pacific Gas and Electric Company

Diablo Canyon Power Plant  
P.O. Box 56  
Avila Beach, CA 93424  
805/545-6000

John D. Townsend  
Vice President-Diablo Canyon  
Operations and Plant Manager

February 26, 1992

PG&E Letter No. DCL-92-046



William R. Leonard, Executive Officer  
California Regional Water Quality Control Board  
Central Coast Region  
81 Higuera, Suite 200  
San Luis Obispo, CA 93401-5414

Dear Mr. Leonard:

Discharge Monitoring and Reporting Program  
Diablo Canyon Power Plant -- NPDES No. CA0003751

Enclosed is the annual summary report for the period January 1 through December 31, 1991, of the Diablo Canyon Power Plant Discharge Monitoring Program, in accordance with Order 90-09, NPDES No. CA0003751.

I certify under penalty of law that this document and its enclosure were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. The results of the influent and effluent monitoring presented are the observed results of the measurements and analyses required by the monitoring program, and is neither an assertion of the adequacy of any instrument reading or any analytical result, nor an endorsement of the appropriateness of any analytical result, nor an endorsement of the appropriateness of any analytical or measurement procedure. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


If you have any further questions, please contact Thomas Wilson of my staff at (805) 545-4439.

Sincerely,

*John D. Townsend*  
John D. Townsend

Enclosure

5663S/85K/ERK/935



*IFAB*  
*1/c*



2

1

3

February 26, 1992

cc: Chief, Environmental Services Division  
California Department of Fish and Game  
Resources Building  
1416 Ninth Street  
Sacramento, California 95814

Regional Administrator, Region 9  
Environmental Protection Agency  
75 Hawthorne Street  
San Francisco, California 94103

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region 5  
1450 Maria Lane, Suite 21  
Walnut Creek, California 94596-5368

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Chief, Marine Resources Division  
California Department of Fish and Game  
Resources Building  
1416 Ninth Street  
Sacramento, California 95814

Enclosure

5663S/85K



100-100000

PACIFIC GAS & ELECTRIC COMPANY  
DIABLO CANYON POWER PLANT

ANNUAL SUMMARY REPORT ON  
DISCHARGE MONITORING AT  
DIABLO CANYON POWER PLANT

1991

...9204140184

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



## TABLE OF CONTENTS

	<u>Page</u>
Overview.....	1
Summary of Monitoring Program.....	1
A - Monitoring Of Plant Influent and Effluent.....	1
1 - Monitoring Data.....	1
2 - Facility Operating and Maintenance Manual.....	2
3 - Laboratories Used To Monitor Compliance.....	2
4 - Domestic Sanitary Waste System (Discharge, 001N).....	2
5 - Review Of Compliance Record And Corrective Actions.....	2
6 - Static Bioassays.....	5
7 - Chronic Bioassays.....	5
B - Monitoring Of Receiving Water.....	6
1 - Ecological Studies In The Vicinity of Diablo Canyon....	6
2 - Sediment Analysis.....	6
3 - Stratified Water Temperatures.....	6
4 - Dissolved Oxygen and pH.....	6
5 - In-Situ Bioassay.....	6
Appendix 1 - Tabular Summaries Of Influent And Effluent Monitoring	
Appendix 2 - Graphical Summaries Of Influent And Effluent Monitoring	
Appendix 3 - Graphical Summaries of Stratified Water Temperatures of Receiving Waters	
Appendix 4 - Graphical Summaries of Dissolved Oxygen and pH of Receiving Waters	

Vertical text on the left side of the page, possibly a page number or header.



## OVERVIEW

- A. This annual summary report follows the format used in the monthly and quarterly monitoring reports. During 1991, discharges occurred from all discharge paths except 001I, 001K, 016, 001N to 001P and 001P to 003.
- B. PG&E submitted its application for Environmental Laboratory Accreditation for the Diablo Canyon Chemistry Section Laboratories to the State Of California on October 11, 1991. The Department Of Health Services acknowledged receipt of the application on October 29, 1991.
- C. The substances listed in Table B of the 1990 Ocean Plan were each analyzed for and reported in either the permit renewal application for Diablo Canyon submitted in 1989, or the Engineering Report Evaluation of Diablo Canyon's compliance with the Ocean Plan, submitted in November, 1990.

There have been no changes in the activities conducted at the plant which would have significantly affected the results reported previously in the referenced documents.

- D. In all cases, chemical, radiochemical, and toxicity analyses were performed in accordance with chemical analysis procedures contained in the Diablo Canyon Power Plant, Units 1 and 2 Plant Manual, Volume 8, by State approved laboratories, or laboratories meeting the requirements specified in the California Regional Water Quality Control board Central Coast Region "Standard Provisions and Reporting Requirements" dated January 25, 1985. Receiving water monitoring was performed in accordance with approved biological and oceanographic procedures.

## SUMMARY OF MONITORING PROGRAM

### A. Monitoring of Plant Influent and Effluent

#### 1. Monitoring Data

- a. Appendix 1 contains data in tabular form. Appendix 2 contains data in graphical form.
- b. Annual oil and grease analyses were performed in October on Discharges 005, 008, 009, 013, 015, and 017. All results were <3 mg/l. No discharges occurred from 016 during 1991.
- c. The annual grab sample analysis results of Discharge 001D, Liquid Radioactive Waste Treatment System, for lithium, boron and hydrazine, were 0.059 mg/l, 0.510 mg/l and <0.020 mg/l respectively.



2. Facility Operating and Maintenance Manual

PG&E maintains a multiple volume plant manual at Diablo Canyon that contains procedures used for all of the operation and maintenance activities at the plant, including those activities that relate to wastewater handling, treatment, sampling, analysis and discharge.

The procedures are reviewed by the plant staff and approved by the Plant Management. The normal review cycle is two years.

3. Laboratories Used To Monitor Compliance

- a. Pacific Gas and Electric Co., Diablo Canyon Power Plant, Avila Beach, California
- b. Coast To Coast Analytical Services, San Luis Obispo, California
- c. SOCI, Inc., Auburn, California
- d. TMA/NORCAL, Richmond, California

4. Sanitary Wastewater Treatment System (Discharge 001N)

- a. The Sanitary Wastewater Treatment System (001N) is maintained and operated, under contract, by SOCI, Inc. The employees of SOCI are qualified by the state of California and hold the certifications identified below:

- 1) Michael Buckley --- Grade 3, #3512
- 2) James Wysong --- Operator In Training under Buckley

5. Review Of Compliance Record And Corrective Actions

- a. January
  - o All discharges were in full compliance.

1949年

1948年

1947年

1946年

1945年

1944年

1943年

1942年



b. February, March, April

- o During the months of February, March and part of April, 1991, the Sanitary Wastewater Treatment System, Discharge 001N, experienced an increase in the effluent suspended solids and settleable solids concentration. The daily maximum and monthly average settleable solids limits were exceeded in February and the monthly average suspended solids limit was exceeded in March. The increase in solids was attributed to changes made in the operation of the Sanitary Wastewater Treatment System to control foam. A reduction in the number of air blowers used during the aeration cycle was effective in reducing the foam, but led to an increase in solids concentration. Installation of a spray system then allowed the proper number of air blowers to be used while controlling the foam.

Prior to fully controlling the foaming in the system, some foam was blown onto the ground near the Sanitary Wastewater Treatment System. Water was used to wash down the area. Some of the water, along with the foam, entered a storm drain and entered Discharge 004, Biolab Discharge. Notification was made to a Regional Board Staff person who agreed with PG&E's assessment that the volume of sewage involved was very small and did not warrant special sampling of the Intake Cove.

An identification of waste streams entering the Sanitary Wastewater Treatment System that contained foaming agents was made. Efforts to reduce the introduction of excessive amounts of these domestic materials into the system were conducted.

Installation of a spray system and the reduction of foaming agents being introduced to Discharge 001N resulted in bringing the system's effluent quality within specified limits.

- o On March 15, 1991, approximately 50 gallons of diesel fuel oil was spilled onto the ground during a fuel truck tank filling operation. While most of the fuel absorbed into the soil, some of the light fraction of the fuel from the soil was washed by rain into a storm drain approximately 600 feet away (Discharge 006) and ultimately into the ocean. No sheen was visible in the ocean.

The drains were sandbagged and absorbent pads were used to stop the sheen from entering the storm drain.

10

11

12

13

14

15

16

17

18

19



Steps taken to prevent this situation from occurring again in the filling station area include:

- \* Posting of signs indicating response actions for emergencies;
  - \* Changes in plant operating procedures to improve awareness of proper steps in the event of a fuel spill;
  - \* New training program for all employees that identifies emergency response procedures; and
  - \* Plans for a concrete fueling slab that will contain any released fuel.
- o During the month of April, and again in October and November, several analyses for Total Residual Chlorine (TRC) using an amperometric titrator, performed on samples from the Main Circulating Water Pumps during routine chlorination, indicated concentrations that exceeded discharge limits. More complete details are provided in the second and fourth quarter reports for 1991.

Inspections and evaluations of the chlorine injection system did not reveal any abnormalities. Potential problems that could cause a bias in the analytical results were identified and corrected. However, it appears that other analytical errors exist that interfere with precise and accurate detection of low level chlorine. These were described in the fourth quarter report.

Analysis results using an Orion 1770 Chlorine Monitor, performed in conjunction with some of the samples analyzed on the amperometric titrator, show a very distinct, sharp rise, then a leveling, followed by a distinct, sharp fall of TRC values during the chlorination cycle. This pattern is consistent from day to day. The values from the titrator occasionally indicate an erratic TRC value which is not believed to be a true representation of the TRC concentration.

During the first quarter of 1992, PG&E plans to incorporate the use of the Orion 1770 Chlorine Monitor in place of the Amperometric Titrator, except when the Orion is not operational. We expect the results from the Orion will provide more consistent information and will allow PG&E to more accurately control the TRC concentrations in Discharge 001.

- o All other discharges were in full compliance.

1944

1945

1946



c. May

- o On May 22, 1991, during a routine chlorination of Main Circulating Water Pump 2-2, grab sample analysis results indicated the TRC concentration was above discharge limits. More complete details are provided in the second quarter report for 1991.

A review of the operation of the chlorine injection system revealed that the operator had used an incorrect chlorine injection rate. Personnel error was the cause for the incorrect setting. The individual received additional training in the correct operation of the system.

- o All other discharges were in full compliance.

d. June, July, August, September

- o All discharges were in full compliance.

e. October, November, December

- o Refer to section b. above for discussion about TRC compliance during October and November.
- o All other discharges were in full compliance.

6. Static Bioassays

Static bioassays of Discharge 001 were performed January 7, April 1, July 8, and October 21, 1991. Results were reported in the appropriate quarterly report. No toxicity was detected in any of the samples.

7. Chronic Bioassays

During 1991, three chronic bioassays using three test species were performed quarterly as required by the 1990 California Ocean Plan. Results are to be reported in a separate report to the Regional Water Quality Control Board.



Vertical text on the left side of the page, possibly bleed-through from the reverse side.

Small mark or text at the bottom center of the page.

Small mark or text in the upper middle section of the page.

Small mark or text in the middle section of the page.

Small mark or text in the lower middle section of the page.

Small mark or text in the right middle section of the page.

B. Monitoring of Receiving Waters

1. Ecological Studies at Diablo Canyon

Marine ecological monitoring continued during 1991 under the Thermal Effects Monitoring Program. The following table summarizes completed subtasks for the year. An annual report will be prepared and submitted by March 31, 1992. Fish observations during the first quarter were not completed due to consistent adverse weather conditions during February and March. However, they were completed in April.

<u>Subtask</u>	<u>Date Surveys Began</u>			
Horizontal Transects	01/25	05/15	07/12	11/04
Vertical Transects	01/13	05/14	07/09	11/20
Algal Scrape Surveys	01/16	05/17	07/29	11/04
Subtidal Benthic Surveys	02/08	05/07	08/20	10/23
Fish Observations		04/15	08/01	10/12
Black Abalone Surveys*	01/26		06/25	
Subtidal Red Abalone Surveys*		07/16	09/10	
Bull Kelp Population Census*				10/01

\* Abalone surveys are conducted twice annually and the Bull Kelp Census is conducted once annually.

2. Sediment Analysis

Annual sediment samples were collected on September 5, 1991. Analysis results were presented in the third quarter report. Values observed were within normal ranges.

3. Stratified Water Temperatures

Stratified water temperatures were measured on March 3, June 19, and October 3, 1991. Temperatures were not measured in February due to consistent adverse weather conditions. Results were reported in the appropriate quarterly reports, and summarized by station in Appendix 3.

4. Dissolved Oxygen and pH

Dissolved oxygen and pH monitoring was conducted on March 3, June 19, and October 3, 1991. Dissolved Oxygen and pH were not measured in February due to consistent adverse weather conditions. Results were reported in the appropriate quarterly reports, and are summarized by station in Appendix 4.

5. In-Situ Bioassay

Results of the Mussel Watch program are reported directly by the California Department of Fish and Game in their periodic report for this program.



APPENDIX 1

Tabular Summaries of Influent and Effluent Monitoring

K.

2

4

4

60



APPENDIX 1

TABLE OF CONTENTS

<u>Table</u>	<u>Page</u>
Discharge 001 Temperature, Flow.....	1
Discharge 001 Chlorine.....	1
Discharge 001 Ammonia (N).....	2
Discharge 001 Metals.....	2
Discharge 001 Various Annual Analyses.....	2
Monthly pH.....	3
Discharge 001F and 001N Grease and Oil, Suspended Solids, Settleables Solids.....	3
Discharge 001D, 001F, 001H, 001L Metals.....	4
Monthly Suspended Solids.....	5
Quarterly Grease and Oil.....	5
Discharge 001N Sludge Analyses.....	6



## DISCHARGE 001

## TEMPERATURE (DEG F)

## FLOW (MGD)

month	INFLUENT			EFFLUENT			MONTHLY DELTA T		FLOW (MGD)		
	high	low	avg	high	low	avg	high	avg	high	low	avg
JAN	55.2	54.2	54.9	74.4	68.3	73.3	19.5	18.4	2506	1956	2442
FEB	56.0	51.8	54.3	74.0	68.6	72.3	19.5	18.0	2103	655	1280
MAR	56.0	50.0	52.5	73.5	59.5	69.3	18.9	16.8	2492	914	1428
APR	51.7	48.1	49.6	70.1	59.9	65.9	19.4	16.3	2493	1869	2408
MAY	51.0	48.0	49.4	68.6	59.2	66.3	18.4	16.9	2493	1879	2420
JUN	54.5	50.0	50.1	72.0	67.2	67.1	18.1	17.1	2492	2492	2492
JUL	57.3	52.4	55.5	75.4	70.4	73.6	18.8	18.1	2569	2469	2505
AUG	57.5	53.0	54.9	76.8	67.1	73.5	19.4	18.6	2571	2465	2541
SEP	59.0	53.8	57.1	78.0	68.7	76.2	20.2	19.0	1757	932	1257
OCT	59.2	55.2	57.3	78.1	67.9	73.8	20.3	16.5	2557	1243	1789
NOV	57.2	53.3	55.5	75.9	71.4	74.1	19.6	18.5	2559	1923	2441
DEC	57.7	54.4	56.1	76.2	72.6	74.5	19.1	18.4	2574	2492	2550

limit:                    --                    --                    22                    2760

The INFLUENT and EFFLUENT "high" and "low" values correspond to the highest and lowest daily average value for that month. The INFLUENT high and low does not necessarily correspond to the same day as the high and low for the EFFLUENT for that month.

The "avg" for INFLUENT and EFFLUENT is the average for the entire month.

The Monthly Delta T "high" is the highest Delta T for a day of the month based on daily average INF and EFF values. The "avg" is calculated from INF and EFF monthly avg values.

## DISCHARGE 001

month	TOTAL CHLORINE RESIDUAL (ug/l)			TOTAL CHLORINE USED (lbs/day)		
	high	low	avg	high	low	avg
JAN	20	<20	<20	154	154	154
FEB	<20	<20	<20	31	31	31
MAR	<20	<20	<20	113	31	47
APR	100	<20	23	154	81	138
MAY	140	<20	23	250	39	146
JUN	*	*	*	*	*	*
JUL	<20	<20	<20	145	109	121
AUG	<20	<20	<20	145	27	133
SEP	30	<20	21	187	36	113
OCT	150	<20	32	360	90	230
NOV	80	20	39	360	331	346
DEC	70	<20	35	331	248	323

limit:                    75

\* - Chlorination did not occur during June

42

1000



## DISCHARGE 001

## METALS (ug/l)

month	COPPER		CHROMIUM		NICKEL		ZINC		TITANIUM
	INF	EFF	INF	EFF	INF	EFF	INF	EFF	EFF
JAN	1	<1	<1	<1	<1	<1	2	<1	
FEB	1	<1	<1	<1	1	1	4	<1	
MAR	<2	11	2	5	1	5	4	25	
APR	2	2	<2	<2	<1	<1	3	1	
MAY	1	1	<2	<2	1	3	2	<2	
JUN	1	1	<2	<2	2	2	2	<1	
JUL	2	1	3	6	1	4	10	1	
AUG	2	1	<2	<2	<1	<1	5	1	
SEP	<1	<1	<1	<1	<1	3	<1	<1	
OCT	<1	<1	<1	<1	1	1	<1	<1	<50
NOV	3	<1	<1	<1	<1	<1	6	<1	
DEC	<1	<1	<1	<1	<1	<1	5	<1	
limit:	--	10	--	10	--	30	--	70	--

Note: Order 90-09 changed the monitoring frequency of titanium from monthly to annually

Note: Value for March represent average values. Refer to first quarter report for values.

## DISCHARGE 001

month	AMMONIA (N) (mg/l)	
	INFLUENT	EFFLUENT
JAN	<0.041	<0.041
FEB		
MAR		
APR	<0.040	<0.040
MAY		
JUN		
JUL	<0.040	<0.040
AUG		
SEP		
OCT	<0.082	<0.082
NOV		
DEC		
limit:	--	3.06

DISCHARGE 001  
VARIOUS ANNUAL ANALYSES  
(ug/l)

PARAMETER	INFLUENT	EFFLUENT	EFF LIMIT
Arsenic	<5	<5	--
Cadmium	<1	<1	10
Cyanide	<5	<5	30
Lead	<1	<1	10
Mercury	<0.2	<0.2	0.2
Silver	<1	<1	2.9
Titanium	NA	<50	--
Phenolic Cmpds (non-chlorinated)	<5	<5	150
Phenolic Cmpds (chlorinated)	<1	<1	10
PCB's	<0.2	<0.2	--

Note: Annual samples were collected in October, 1991

100

100

100

100

100



MONTHLY pH

DISCHARGE: month	001		002	003	004	001P
	INFLUENT	EFFLUENT				
JAN	8.1	8.1	8.1	8.0	8.0	7.7
FEB	8.0	8.0	8.0	7.8	8.0	7.9
MAR	8.0	8.0	8.1	8.0	8.0	7.9
APR	7.8	7.8	8.0	7.9	7.9	7.8
MAY	7.9	7.8	7.8	7.6	7.9	7.8
JUN	8.1	8.1	8.1	8.1	8.1	8.1
JUL	8.1	8.1	8.3	8.3	8.2	7.8
AUG	7.9	7.9	8.0	7.8	8.0	7.8
SEP	8.0	8.0	7.4	7.7	7.7	7.9
OCT	7.9	8.0	8.0	8.0	8.1	7.9
NOV	8.1	8.1	8.1	7.9	8.1	8.0
DEC	8.1	8.1	8.1	8.0	7.9	8.0

DISCHARGES 001F AND 001N

month	DISCHARGE 001F			DISCHARGE 001N			DISCHARGE 001N			DISCHARGE 001N					
	high	low	avg	hi	low	avg	high	low	avg	high	low	avg	high	low	avg
JAN	<3	<3	<3	5	5	5	8	3	5	74	16	32	.2	.1	
FEB	<3	<3	<3	6	6	6	14	3	7	60	16	41	10	.1	2
MAR	16	<3	8	13	12	13	8	5	6	440	16	123	.6	.1	
APR	<3	<3	<3	4	4	4	7	3	4	190	10	48	6	.1	
MAY	<3	<3	<3	2	2	2	6	<3	4	22	16	20	<.1	<.1	<
JUN	5	5	5	6	6	6	4	<3	3	27	16	22	<.1	<.1	<.1
JUL	<3	<3	<3	4	4	4	5	<3	4	18	14	16	<.1	<.1	<.1
AUG	<3	<3	<3	2	2	2	3	<3	3	31	9	14	<.1	<.1	<.1
SEP	<3	<3	<3	10	10	10	7	3	5	42	18	29	.1	.1	
OCT	<3	<3	<3	4	4	4	7	3	5	40	23	31	<.1	<.1	<.1
NOV	6	6	6	7	7	7	10	3	6	36	16	24	<.1	<.1	<.1
DEC	3	3	3	3	3	3	10	<3	6	38	8	23	<.1	<.1	<.1
limit:	20	--	15	100	--	30	20	--	15	--	--	60	3	--	

Note: "high" limits based upon Daily Maximum limits  
 "avg" limits based upon Monthly Average limits

Note: The 001F Suspended Solid high value for December is listed as 137 mg/l, and represents an instantaneous value. More than one sample was analyzed on the same day. The actual Daily Average for that day was 70 mg/l.



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

DISCHARGE 001D, F, H, L, METALS  
(ug/l)

month	001D				001F				001H				001L			
	Ag	Cd	Cr	Cu	Ag	Cd	Cr	Cu	Ag	Cd	Cr	Cu	Ag	Cd	Cr	Cu
JAN	<8	<11	68	18	<8	<11	30	9	30	44	181	317	<8	<11	31	67
FEB																
MAR																
APR	<3	7	<7	24	<3	<5	23	146	23	22	362	279	<3	<5	<7	27
MAY																
JUN																
JUL	<2	7	17	31	<2	<3	<9	<19	31	31	365	288	<2	<3	<9	51
AUG																
SEP																
OCT	<1	4	19	15	<10	<3	11	9	14	35	345	261	<1	<1	12	9
NOV																
DEC																

limit: none

Note: 001D, 001H and 001L analyses performed on quarterly composites  
001F analyses performed on a weekly composite, once per quarter

DISCHARGE 001D, H, L, F, METALS  
(ug/l)

month	001D				001F				001H				001L			
	Hg	Ni	Pb	Zn	Hg	Ni	Pb	Zn	Hg	Ni	Pb	Zn	Hg	Ni	Pb	Zn
JAN	<3	32	5	138	<0.2	23	4	137	.8	186	186	95	<0.2	<14	1	<10
FEB																
MAR																
APR	8.4	<5	4	131	<0.2	15	18	218	.8	198	231	137	<0.2	<5	<1	14
MAY																
JUN																
JUL	.9	33	6	133	<0.2	<17	5	33	<0.4	164	144	295	<0.2	<17	<3	19
AUG																
SEP																
OCT	23	49	9	105	<0.2	<17	14	68	1.2	339	165	98	<0.2	<1	2	18
NOV																
DEC																

limit: none

Note: 001D, 001H and 001L analyses performed on quarterly composites  
001F analyses performed on a weekly composite, once per quarter

100

100

100



QUARTERLY GREASE & OIL  
averages by month  
(mg/l)


month	001D	001G	001H	001I	001J	001K	001L	001M	001P	002	003	004
JAN	<3	<3	<3	--	<3	--	<3	<3	<3	<3	5	<3
FEB				--	<3	--		<3				
MAR				--		--		<3				
APR	<3	<3	<3	--	<3	--	<3	5	<3	<3	<3	<3
MAY				--		--						
JUN				--		--		<3				
JUL	<3	<3	<3	--		--	<3		<3	<3	<3	<3
AUG				--		--						
SEP				--	<3	--		<3				
OCT	<3	<3	<3	--	4	--	<3		<3	<3	<3	<3
NOV				--		--		<3				
DEC				--		--		<3				
limit:	15	15	15	15	15	15	15	15	15	15	15	15

Note: No discharges occurred from 001I and 001K during 1991

MONTHLY SUSPENDED SOLIDS  
(mg/l)

month	001D	001G	001H	001I	001J	001K	001L	001M	001P	002	003
JAN	1	<1	6	--		--	2	16	17	1	2
FEB	<1	1	2	--	1	--	<1	23	<1	10	1
MAR	1	<1	3	--	1	--	<1	22	10	13	4
APR	<1	<1	1	--	<1	--	<1	15	9	3	3
MAY	<1	<1	6	--		--	<1		19	4	5
JUN	<1	<1	5	--		--	<1	6	22	11	8
JUL	<1	<1	2	--		--	<1		11	5	3
AUG	3	<1	4	--		--	<1		1	5	<1
SEP	<1	<1	13	--	<1	--	<1	6	3	4	14
OCT	<1	<1	5	--	<1	--	<1		5	2	1
NOV	20	<1	<1	--		--	<1	1	12	3	<1
DEC	<1	<1	5	--		--	<1	3	4	1	4
limit:	30	30	30	30	30	30	30	30	30	30	30

Note: No discharges occurred from 001I and 001K during 1991



DISCHARGE 001N  
SANITARY WASTEWATER TREATMENT SYSTEM

DATE	MOISTURE (%)	TOTAL KJELDAHL N (mg/l)	AMMONIA (N) (mg/l)	NITRATE (N) (mg/l)	TOTAL PHOSPORUS (mg/l)	pH	OIL & GREASE (mg/l)	BORON (mg/l)
08/07/91	NA	110	NA	<1	100	NA	NA	1.9
10/30/91	99.5	160	64	<0.1	83	6.1	18	1.1

DISCHARGE 001N  
SLUDGE REMOVED

DISCHARGE 001N  
SANITARY WASTEWATER TREATMENT SYSTEM

DATE	CADMIUM (mg/l)	COPPER (mg/l)	CHROMIUM (mg/l)	LEAD (mg/l)	NICKEL (mg/l)	MERCURY (mg/l)	ZINC (mg/l)
07/31/91	0.005	1.3	0.013	0.068	<0.05	NA	2.6
10/30/91	0.003	1.6	<0.01	<0.03	<0.1	0.0034	2.5

MONTH	DRY WEIGHT (lbs)
January	2264
February	5250
March	4425
April	2770
May	2896
June	2734
July	2695
August	3078
September	5238
October	5076
November	2636
December	2743
Total =	41,805 lbs (20.9 tons)

Discharge 001N sludge sample is obtained with the system's sludge holding tank in an aeration cycle while liquid from the react tank is being pumped into the holding tank, resulting in an overflow of the holding tank into the react tank. The sample of the "slurry" overflowing from the holding tank is sampled for the analysis.

Because the sample is a slurry rather than a dried sludge, the sample result units are mg/l rather than mg/kg as stated in the permit.

All sludge is taken to the Harold Walsh Sludge Disposal site, Orchard Road, Nipomo Mesa in San Luis Obispo County

The "dry weight" removed is calculated by analyzing the system influent suspended solids on a weekly basis. The volume of sludge removed is then multiplied by the suspended solid concentration to obtain weight removed.



APPENDIX 2

Graphical Summaries of Influent and Effluent Monitoring

1

2

3

4

5



APPENDIX 2


TABLE OF CONTENTS


<u>Graph</u>	<u>Page</u>
Discharge 001 Influent Temperature.....	1
Discharge 001 Effluent Temperature.....	2
Discharge 001 Effluent Flow.....	3
Discharge 001 Effluent Monthly Delta T.....	4
Discharge 001 Total Residual Chlorine.....	5
Discharge 001 Total Chlorine Used.....	6
Discharge 001 pH.....	7
Discharge 001 Ammonia (N).....	8
Discharge 001 Cooper.....	9
Discharge 001 Nickel.....	10
Discharge 001 Zinc.....	11
Discharge 001 Chromium.....	12
Discharge 002 pH.....	13
Discharge 003 pH.....	14
Discharge 004 pH.....	15
Discharge 001P pH.....	16
Discharge 001D Quarterly Metals.....	17
Discharge 001D Quarterly Metals.....	18
Discharge 001F Quarterly Metals.....	19
Discharge 001F Quarterly Metals.....	20
Discharge 001F Grease and Oil.....	21
Discharge 001F Suspended Solids.....	22
Discharge 001H Quarterly Metals.....	23
Discharge 001H Quarterly Metals.....	24
Discharge 001L Quarterly Metals.....	25
Discharge 001L Quarterly Metals.....	26
Discharge 001N Grease and Oil.....	27
Discharge 001N Suspended Solids.....	28
Discharge 001N Settleable Solids.....	29
Monthly Suspended Solids, Averages.....	30
Monthly Suspended Solids, Averages.....	31
Monthly Suspended Solids, Averages.....	32
Quarterly Grease and Oil, Averages.....	33
Quarterly Grease And Oil, Averages.....	34
Quarterly Grease and Oil, Averages.....	35



# DISCHARGE 001 INFLUENT


## TEMPERATURE (DEG F)





# DISCHARGE 001 EFFLUENT


## TEMPERATURE (DEG F)





# DISCHARGE 001 EFFLUENT


FLOW (MGD)





# DISCHARGE 001 EFFLUENT


MONTHLY DELTA T (DEG F)





# DISCHARGE 001


## TOTAL RESIDUAL CHLORINE





# DISCHARGE 001

## TOTAL CHLORINE USED






# DISCHARGE 001

pH

—+— INFLUENT  
—□— EFFLUENT



37





100 100

100 100 100 100

# DISCHARGE 001


## AMMONIA (N)






# DISCHARGE 001


## COPPER






# DISCHARGE 001


## NICKEL






# DISCHARGE 001


## ZINC





# DISCHARGE 001

## CHROMIUM




22



# DISCHARGE 002


pH





# DISCHARGE 003


pH





# DISCHARGE 004


pH






# DISCHARGE 001P


pH





# DISCHARGE 001D

quarterly metals





1/2



# DISCHARGE 001D


quarterly metals





# DISCHARGE 001F

quarterly metals




1



2

# DISCHARGE 001F

quarterly metals





1872

1873

1874




1875



# DISCHARGE 001F

## GREASE & OIL



1000

4

10000


1000

1000



# DISCHARGE 001F


## SUSPENDED SOLIDS





# DISCHARGE 001H


quarterly metals





# DISCHARGE 001H

quarterly metals






A

222

# DISCHARGE 001L


quarterly metals





# DISCHARGE 001L


quarterly metals







# DISCHARGE 001N


## GREASE & OIL






# DISCHARGE 001N SUSPENDED SOLIDS





# DISCHARGE 001N


## SETTLEABLE SOLIDS





# MONTHLY SUSPENDED SOLIDS

averages




- 30 -



# MONTHLY SUSPENDED SOLIDS


averages





# MONTHLY SUSPENDED SOLIDS


averages





# QUARTERLY GREASE & OIL


averages





# QUARTERLY GREASE & OIL


averages





# QUARTERLY GREASE & OIL

averages





APPENDIX 3

Graphical Summaries of Stratified Water Temperature  
Measurements of the Receiving Water



第

一、二、三、四、五、六、七、八、九、十、十一、十二、十三、十四、十五、十六、十七、十八、十九、二十、二十一、二十二、二十三、二十四、二十五、二十六、二十七、二十八、二十九、三十、三十一、三十二、三十三、三十四、三十五、三十六、三十七、三十八、三十九、四十、四十一、四十二、四十三、四十四、四十五、四十六、四十七、四十八、四十九、五十、五十一、五十二、五十三、五十四、五十五、五十六、五十七、五十八、五十九、六十、六十一、六十二、六十三、六十四、六十五、六十六、六十七、六十八、六十九、七十、七十一、七十二、七十三、七十四、七十五、七十六、七十七、七十八、七十九、八十、八十一、八十二、八十三、八十四、八十五、八十六、八十七、八十八、八十九、九十、九十一、九十二、九十三、九十四、九十五、九十六、九十七、九十八、九十九、一百

APPENDIX 3

TABLE OF CONTENTS

---

---


<u>Graph</u>	<u>Page</u>
Stratified Water Temperatures	Station 10.....1
Stratified Water Temperatures	Station 11.....2
Stratified Water Temperatures	Station 12.....3
Stratified Water Temperatures	Station 13.....4
Stratified Water Temperatures	Station 14.....5
Stratified Water Temperatures	Station 15.....6

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

100




# Stratified Water Temperatures Station 10






# Stratified Water Temperatures Station 11





Vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

# Stratified Water Temperatures Station 12



100-100000

100-100000


100-100000

100-100000

100-100000




# Stratified Water Temperatures Station 13



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



# Stratified Water Temperatures Station 14



100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000


100-100000

100-100000

100-100000



# Stratified Water Temperatures Station 15



--9--



APPENDIX 4

Graphical Summeries of Dissolved Oxygen  
Determinations and pH Measurements of the  
Receiving Water



1234

567

890

123

456  
789  
012  
345  
678  
901  
234  
567  
890  
123

456

789

012

345

678  
901  
234  
567

890  
123  
456  
789




APPENDIX 4

TABLE OF CONTENTS


---

---

<u>Graph</u>		<u>Page</u>
Dissolved Oxygen Determinations	Station 10.....	1
Dissolved Oxygen Determinations	Station 11.....	2
Dissolved Oxygen Determinations	Station 12.....	3
Dissolved Oxygen Determinations	Station 13.....	4
Dissolved Oxygen Determinations	Station 14.....	5
Dissolved Oxygen Determinations	Station 15.....	6
pH Measurements	Station 10.....	7
pH Measurements	Station 11.....	8
pH Measurements	Station 12.....	9
pH Measurements	Station 13.....	10
pH Measurements	Station 14.....	11
pH Measurements	Station 15.....	12




# Dissolved Oxygen Determinations Station 10



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100




# Dissolved Oxygen Determinations Station 11





# Dissolved Oxygen Determinations Station 12







Handwritten marks on the left margin.


Handwritten marks on the left margin.

# Dissolved Oxygen Determinations Station 13






# Dissolved Oxygen Determinations Station 14





# Dissolved Oxygen Determinations Station 15




100

100

100

100


# pH Measurements Station 10



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



# pH Measurements Station 11



2

3

4

5


6

7

8



# pH Measurements Station 12




1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

101




# pH Measurements Station 13



Vertical text or markings on the left side of the page, possibly bleed-through or a margin note.



# pH Measurements Station 14




1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

2  
3  
4



# pH Measurements Station 15



- 12 -

100-100000

