

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207240131 DOC. DATE: 92/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323
 AUTH. NAME AUTHOR AFFILIATION
 TOWNSEND, J.D. Pacific Gas & Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 LEONARD, W.

SUBJECT: "Rept on Discharge Monitoring Diablo Canyon Power Plant
 Second Quarter of 1992." W/920720 ltr.

DISTRIBUTION CODE: IE25D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 99
 TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES: *see Enviro Rpts*

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	PD5	LA	3	3	PD5	PD	1	1
	ROOD,	H	1	1				
INTERNAL:	ACRS		1	1	NRR/DREP/PRPB11		2	2
	<u>REG FILE</u>	01	1	1	RGN5 DRSS/RPB		1	1
	RGN5	FILE 02	1	1				
EXTERNAL:	EG&G	SIMPSON, F	2	2	NRC	PDR	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

Pacific Gas and Electric Company

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424
805/541-7616

John D. Townsend
Vice President—Diablo Canyon Operations
and Plant Manager

July 20, 1992



Mr. William Leonard, Executive Officer
California Regional Water Quality Control Board
Central Coast Region
81 Higuera Street, Suite 200
San Luis Obispo, California 93401-5414

Dear Mr. Leonard:

Discharge Monitoring and Reporting Program
Diablo Canyon Power Plant -- NPDES No. CA0003751

The report for the second quarter of 1992 of the Diablo Canyon Power Plant Discharge Monitoring Program, in accordance with Order 90-09 NPDES No. CA0003751 is enclosed.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. The results of the influent and effluent monitoring presented are the observed results of the measurements and analyses required by the monitoring program, and is neither an assertion of the adequacy of any instrument reading or any analytical result, nor an endorsement of the appropriateness of any analytical or measurement procedure. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

If you have further questions, please contact Mr. Thomas C. Wilson at (805) 545-4439.

John D. Townsend for

JDT:ksb

Enclosure

9207240131 920630
PDR ADDCK 05000275
R PDR

JDT



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

1

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100



cc: Chief, Environmental Services Division
California Department of Fish and Game
Resources Building
1416 Ninth Street
Sacramento, California 95814

Regional Administrator, Region 9
U. S. Environmental Protection Agency
75 Hawthorne Street
San Francisco, California 94105
Attention: Carey Houk (W-5-3)

Regional Administrator
U. S. Nuclear Regulatory Commission
Region 5
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Chief, Marine Resources Division
California Department of Fish and Game
Resources Building
1416 Ninth Street
Sacramento, California 95814

**PACIFIC GAS AND ELECTRIC COMPANY
NUCLEAR POWER GENERATION**

**REPORT ON
DISCHARGE MONITORING AT
DIABLO CANYON POWER PLANT
SECOND QUARTER OF 1992**

.....9207240131

1
2
3



TABLE OF CONTENTS

OVERVIEW	_____	1
SUMMARY OF MONITORING PROGRAM	_____	2
A.	Monitoring of Plant Influent and Effluent _____	2
B.	Monitoring of Receiving Waters _____	3

APPENDICES

1	Influent and Effluent Monitoring Data for April 1992
2	Influent and Effluent Monitoring Data for May 1992
3	Influent and Effluent Monitoring Data for June 1992
4	Diablo Canyon Acute Bioassay Report: April 13, 1992
5	Diablo Canyon Chronic Bioassay Report, First Quarter, 1992
6	Diablo Canyon Chronic Bioassay Report, Second Quarter, 1992
7	Stratified Water Temperature: June 29, 1992
8	Dissolved Oxygen and pH of Receiving Waters: June 29, 1992

1
2
3



OVERVIEW

- A. During the second quarter of 1992, discharges occurred from Discharge Paths 001 (once through cooling water), 001B, 001D, 001E, 001F, 001G, 001H, 001J, 001L, 001M, 001N, 001P, 002 through 016. No discharges occurred from Discharge Paths 001I, 001K, and 017.
- B. The substances listed in Table B of the 1990 Ocean Plan were each analyzed and reported in either the permit renewal application for Diablo Canyon submitted in 1989, or the Engineering Report Evaluation of Diablo Canyon's compliance with the Ocean Plan, submitted in November, 1990.

There have been no changes in the activities conducted at the plant which would have significantly affected the results reported previously in the referenced documents.

- C. In all cases, chemical, radiochemical, and toxicity analyses were performed in accordance with chemical analysis procedures contained in the Diablo Canyon Power Plant, Units 1 and 2 Plant Manual, Volume 8, by State approved laboratories, or laboratories meeting the requirements specified in the California Regional Water Quality Control Board Central Coast Region: "Standard Provisions and Reporting Requirements" dated January 25, 1985. Receiving water monitoring was performed in accordance with approved biological and oceanographic procedures.

SUMMARY OF MONITORING PROGRAM

- A. Monitoring of Plant Influent and Effluent
1. The results of the April, May and June plant influent and effluent monitoring are reported in Appendices 1, 2, and 3, respectively.
 2. Results from one acute bioassay on water sampled from Discharge 001, performed April 13, 1992, are included in Appendix 4.
 3. Results from two chronic bioassays performed January 7 and April 7, 1992, on water sampled from Discharge 001 are included in Appendices 5 & 6. These quarterly chronic toxicity bioassays were conducted in accordance with the 1990 California Ocean Plan.
 4. Listed below are the detection limits used for the analyses performed during the quarter. The limits are based upon published values, contract laboratory reports, or Diablo Canyon's analytical experience. Diablo Canyon submitted its application for laboratory accreditation to the State of California on



October 11, 1991. As part of the accreditation process, Diablo Canyon has proceduralized a method to formally determine method detection limits based upon the guidelines in 40 CFR 136; and is in the process of determining the limits.

<u>Parameter</u>	<u>Detection Limit (mg/l)</u>
Oil and Grease	3
Total Res Chlorine	0.020 (amperometric) 0.010 (electrode)
Suspended Solids	1
Settleable Solids	0.01 ml/l
Ammonia (N)	0.054
Metals (Chromium, Copper, Nickel, Zinc)	0.001 (chelation extraction)

5. Each of the Appendices 1 through 3 contain additional laboratory results located following the normal Q-2 forms that was used to develop "average" values reported on the Q-2 forms. This information is provided to ensure that all analytical data is reported "uncensored."

Normally, the additional data will include results for analyses performed several times in one day, such as Total Residual Chlorine, for which an average value is reported on the Q-2.

B. Monitoring of Receiving Waters

1. Ecological Studies at Diablo Canyon

Ecological studies conducted during the second quarter in the vicinity of Diablo Cove, referred to as the Diablo Canyon Thermal Effects Monitoring Program (TEMP), are summarized in the following table.

<u>Subtask</u>	<u>Month Completed</u>
Subtidal Fish Observations	June
Subtidal Benthic Stations	June
Intertidal Horizontal Bands	June
Intertidal Vertical Bands	May
Intertidal Algal Scrapes	June



2. Sediment Analysis

Annual sediment samples are collected in September. Results will be reported in the third quarter report.

3. Stratified Water Temperatures

Stratified water temperatures measured on June 29, 1992, are reported in Appendix 7.

4. Dissolved Oxygen and pH of Receiving Waters

Results of Dissolved Oxygen and pH sampling conducted on June 29, 1992, are reported in Appendix 8.

5. In Situ Bioassay

Results of the Mussel Watch program will be reported to the Board directly from the California Department of Fish and Game in their periodic report for this program.

x
y
z



APPENDIX 1

Influent and Effluent Monitoring

April 1992

z f
D z
v







GALIFORNIA REGIONAL WATER QUALITY
 CONTROL BOARD
 CENTRAL COAST REGION
 1102A LAUREL LANE
 SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
 DIABLO CANYON NUCLEAR POWER PLANT
 PO BOX 56
 AVILA BEACH, CALIF 93424
 PAGE (N) 3

FACILITY I.D.
 3 402003001

YEAR/ MO / DAY
 BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
 ENDING 92 / 04 / 30

STATE CODE
 06

NPDES PERMIT #
 CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFF 001N=>003	EFF 001N=>003	-----EFFLUENT 001D-----			-----EFFLUENT 001F-----		
	TOTL COLIFORM	FECAL COLIFORM	SUSPENDED SOLIDS			SUSPENDED SOLIDS		
	MPN/100ml	MPN/100ml	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB	GRAB	GRAB			GRAB		

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
										1	<1						7	<1													


MONTHLY AVG	NO DISCHARGE	NO DISCHARGE																													
MONTHLY HIGH																															
MONTHLY LOW																															

TIMES EXCEEDED	80% SMPLS>1K	MEAN>200=0	NO LIMIT	NO LIMIT	NO AVG 30= 0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED	=0	90% SMPLS>400			D MAX 100 =0			D MAX 100 =0
TIMES EXCEEDED	1 MAX >10K=0	=0						

S: (1) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
 JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Jack Krueger 7/15/92





CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (N) 5

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 001I-----			-----EFFLUENT 001J-----		
	SUSPENDED SOLIDS			SUSPENDED SOLIDS		
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB MONTHLY			GRAB MONTHLY		

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

MONTHLY AVG	NO DISCHARGE						NO DISCHARGE					
MONTHLY HIGH												
MONTHLY LOW												

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			D MAX 100 =0			D MAX 100 =0
TIMES EXCEEDED						

REMARKS: (#) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
JARR Kremer 7/15/92







CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (N) 8

FACILITY I.D. 3 402003001
YEAR/ MO / DAY BEGINNING 92 / 04 / 01
YEAR/ MO / DAY ENDING 92 / 04 / 30
STATE CODE 06
NPDES PERMIT # CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 002-----			-----EFFLUENT 003-----		
	SUSPENDED SOLIDS			SUSPENDED SOLIDS		
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET

	†	†	†	†	†	†	†	†	†	†	†
APRIL											
1											
2	7			1	27			19		8	
3		6									
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											

MONTHLY AVG				1							
MONTHLY HIGH				1							
MONTHLY LOW				<1							

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			1 MAX 100 =0			1 MAX 100 =0
TIMES EXCEEDED						

(*) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Joak Krueger 7/15/92









3 3
3 3
3 3



...



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (0) 6

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SNPL TYPE FREQ.	EFFLUENT 001D NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F NICKEL ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F SILVER ug/l 1 WEEK COMP JA/AP/JUL/OCT
--	--	--	--	---	--	--	--	---

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
	<63	242	<63	<63	<11	21	<11	<11																							

MONTHLY AVG	242	<63	<63	<63	21	<11	<11	<11
MONTHLY HIGH	245	<63	<63	<63	22	<11	<11	<11
MONTHLY LOW	238	<63	<63	<63	20	<11	<11	<11

TIMES EXCEEDED	NO LIMIT							
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: (*) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT
JAR Knevey
DATE
7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (Q) 7

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F ZINC ug/l 1 WEEK COMP JA/AP/JUL/OCT
--	--	--	--	---

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
	143	106																													

MONTHLY AVG	106	12
MONTHLY HIGH	114	15
MONTHLY LOW	97	<9

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED				
TIMES EXCEEDED				

3: (1) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Jack Kremer 7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (0) 8

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M COPPER mg/l 24-HR COMP. METAL CLNG
--	--	--	--	--	--

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

MONTHLY AVG	NO DISCHARGE				
MONTHLY HIGH					
MONTHLY LOW					

TIMES EXCEEDED	NO AVG 1 = 0				
TIMES EXCEEDED	D MAX 1 = 0				
TIMES EXCEEDED					

S: () Number_of_Samples_taken_during_the_day. _____

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Jack Krenney 7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN JOSE, CALIF. 95128

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (2) 9

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M IRON mg/l 24-HR COMP. METAL CLNG
--	--	--	--	--	--

APRIL	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

MONTHLY AVG	NO DISCHARGE				
MONTHLY HIGH					
MONTHLY LOW					

TIMES EXCEEDED	MD AVG 1 = 0				
TIMES EXCEEDED	D MAX 1 = 0				
TIMES EXCEEDED					

(MARKS: (#) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John R. Kremer 7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (A) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 04 / 01

YEAR/ MO / DAY
ENDING 92 / 04 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLUENT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLUENT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLUENT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLUENT ZINC ug/l GRAB OCTOBER
--	---	------------------------------------	------------------------------------	------------------------------------	--	---------------------------------	-------------------------------------	---------------------------------

APRIL	()	()	()	()	()	()
1												
2												
3												
4												
5												
6												
7											(2
8												
9												
10												
11												
12												
13												
14												
15												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												

MONTHLY AVG												
MONTHLY HIGH												
MONTHLY LOW												

TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MEAN 30 =0	NO LIMIT	6M-MEAN 10 =0	NO LIMIT	6M-MEAN 10 =0
TIMES EXCEEDED			D MAX 150 =0		D MAX 20 =0		D MAX 40 =0
TIMES EXCEEDED			I MAX 400 =0		I MAX 50 =0		I MAX 100 =0

REMARKS: (1) Number of Samples taken during the day. (11) Influent Zinc analyzed for comparison to effluent analysis. All other analysis will be performed in October.

PRINCIPAL EXECUTIVE OFFICER
JANES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT
JAR Krumey
DATE
7/15/92



Unit: 0 NPDES
001 EFFLUENT CHLORINATION

From: 4/01/92 0:01
Through: 4/30/92 23:59

Parameter:	CWP 1-1 1ST SMPL	CWP 1-1 2ND SMPL	CWP 1-2 1ST SMPL	CWP 1-2 2ND SMPL	CWP 2-1 1ST SMPL	CWP 2-1 2ND SMPL	CWP 2-2 1ST SMPL	CWP 2-2 2ND SMPL
Sample Time:	PPM							
4/01/92 10:00	<0.020	0.050	<0.020	0.070	<0.020	0.060	<0.020	0.040
4/02/92 10:00	0.080	0.070	0.070	0.080	0.050	0.060	0.070	0.070
4/03/92 10:00	0.060	0.050	0.060	0.070	0.060	0.070	0.070	0.060
4/06/92 10:00	0.020	0.050			0.060	0.060	0.070	0.080
4/07/92 10:00	0.020	0.020	0.070	0.080	0.040	<0.020	0.050	0.060
4/08/92 10:00	0.020	0.060	<0.020	0.090	0.050	0.090	0.070	0.080
4/09/92 10:00	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020
4/10/92 10:00	<0.020	0.030	0.070	0.090	0.050	0.080	0.070	0.100
4/13/92 10:00	<0.020	<0.020	<0.020	<0.020	0.020	<0.020		
4/20/92 11:00			<0.020	<0.020	0.050	0.090	0.050	0.070
4/21/92 10:00	0.120	0.090	0.080	0.070	0.060	<0.020	0.080	0.040
4/22/92 10:00	0.080	0.080	0.100	0.110	0.080	<0.020	<0.020	<0.020
4/23/92 10:00	<0.020	<0.020	<0.020	<0.020	0.060	0.060	0.050	0.070
4/24/92 10:00	<0.020	<0.020	0.080	0.100	0.080	0.080	0.100	0.090
4/27/92 10:04	<0.020	<0.020	0.060	0.050	0.030	0.060	0.070	0.060
4/29/92 10:00	0.060	0.080	0.080	0.070	<0.020	<0.020	0.020	<0.020
4/30/92 10:00	0.090	0.090	0.080	0.080	0.040	0.050	0.040	0.080

NOTE: Individual sample results for Total Residual Chlorine (TRC) are adjusted by the following formula to account for dilution by the unchlorinated Circulating Water Pumps on the opposite operating Unit. It is assumed that no chlorine demand exists in the seawater:

$$\text{ppm TRC} \times \frac{\# \text{ of operating pumps on chlorinated Unit}}{\# \text{ of operating pumps for both Units}}$$

The daily average TRC value reported on the Q2 forms is the average of the adjusted TRC results for the day, which could include up to eight individual results (two analyses per chlorination cycle for a maximum of 4 cycles per day)



PACIFIC GAS & ELECTRIC - DIABLO CANYON POWER PLANT
 SANITARY WASTEWATER TREATMENT SYSTEM
 CONTRACT # Z78-2104-86

(REV. 5/90)

Sanitation and Operation Consultants, INC.
 16340 E. Maplegrove Street
 La Puente, CA 91744

Pacific Gas and Electric Co.
 Contacts:
 Randy Falcke (805) 595-4362
 John Knemeyer (805) 595-4472

CONSTITUENTS	UNITS	FREQ.	LIMITS		SAMPLE		RESULTS
			MONTHLY AVERAGE	DAILY MAX	DATE	TIME	
1. GREASE & OIL	mg/l	WEEKLY	15	20	4-3	1038	5.7 mg/l Ave of 3
2. "	mg/l	"	15	20	4-10	1150	5.0 mg/l " " "
3. "	mg/l	"	15	20	4-16	1212	4.7 mg/l " " "
4. "	mg/l	"	15	20	4-21	1209	3.3 mg/l " " "
5. "	mg/l	"	15	20	4-28	1035	6.3 mg/l " " "
1. SUSPENDED SLDS	mg/l	WEEKLY	60	N/A	4-3	1012	17.0 mg/l
2. "	mg/l	"	60	N/A	4-10	1126	18.0 mg/l
3. "	mg/l	"	60	N/A	4-16	1158	25.0 mg/l
4. "	mg/l	"	60	N/A	4-21	1147	23.0 mg/l
5. "	mg/l	"	60	N/A	4-28	1017	12.0 mg/l
1. SETTLEABLE SLD	ml/l	WEEKLY	1.0	3.0	4-3	1026	< 0.1 ml/l
2. "	ml/l	"	1.0	3.0	4-10	1154	< 0.1 ml/l
3. "	ml/l	"	1.0	3.0	4-16	1208	0.8 ml/l
4. "	ml/l	"	1.0	3.0	4-21	1230	0.2 ml/l
5. "	ml/l	"	1.0	3.0	4-28	1037	< 0.1 ml/l

NOTE:

- ANALYSIS RESULTS ABOVE THE MONTHLY AVERAGE SHALL BE REPORTED VERBALLY, WITHIN 8 HOURS, TO A PG&E CONTACT LISTED ABOVE.
- G&O AND SUSP. SLDS. SAMPLES ARE COMPOSITES DURING 1 DISCHARGE CYCLE.

COMMENTS:

SLUDGE DISPOSAL DATA

MONTH REMOVED	VOLUME REMOVED	WEIGHT REMOVED	DISPOSAL SITE
APRIL 1992		4845 lbs	Walsh - Nipomo



APPENDIX 2

Influent and Effluent Monitoring

May 1992





CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (H) 2

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 003 pH pH UNITS GRAB MONTHLY	EFFLUENT 004 pH pH UNITS GRAB MONTHLY	EFFLUENT 001N OIL & GREASE mg/l COMPOSITE WEEKLY	EFFLUENT 001P OIL & GREASE mg/l GRAB WEEKLY (**)	EFFLUENT 003 OIL & GREASE mg/l GRAB WEEKLY (***)	EFFLUENT 001F OIL & GREASE mg/l GRAB MONTHLY	EFFLUENT 001 T CHLOR RES ug/l GRAB 2 per CYCLE	EFFLUENT 001 CHLORINE USED lbs/day RECORDED MONTHLY
MAY								
1							8 60	288
2								
3								
4								
5							8 <20	139
6							2 <20	36
7							6 <20	84
8			5				8 20	130
9								
10								
11							8 <20	144
12							8 <20	144
13			5				8 <20	144
14								
15								
16								
17								
18							8 <20	144
19	7.7	8.2					8 <20	144
20			3				8 <20	270
21							8 30	216
22							8 20	216
23								
24								
25							8 20	216
26							8 40	216
27			5				8 <20	216
28							8 <20	216
29							8 <10	147
30								
31								
MONTHLY AVG			5	NO DISCHARGE	NO DISCHARGE		23	172
MONTHLY HIGH			5				<10	288
MONTHLY LOW			3				60	36
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 15 =0	NO AVG 15 =0	NO AVG 15 =0	NO AVG 15 =0	I MAX 200 =0	NO LIMIT
TIMES EXCEEDED			D MAX 20 =0	D MAX 20 =0	D MAX 20 =0	D MAX 20 =0		
TIMES EXCEEDED								

KS: (*) Number of Samples taken during the day.
(**) When 001N is discharging to 001P. (***) When 001P is discharging to 003.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John Kremer 7/5/92





CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (M) 4

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 001G-----			-----EFFLUENT 001H-----		
	SUSPENDED SOLIDS					
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB MONTHLY			GRAB MONTHLY		

MAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
								8		3																					
		2		<1																											

MONTHLY AVG																																
MONTHLY HIGH																																
MONTHLY LOW																																

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			D MAX 100 =0			D MAX 100 =0
TIMES EXCEEDED						

S: (1) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John R. Kremer 7/5/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (M) 5

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SNPL TYPE FREQ.	-----EFFLUENT 001I-----			-----EFFLUENT 001J-----		
	SUSPENDED SOLIDS					
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB MONTHLY			GRAB MONTHLY		

MAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

MONTHLY AVG	NO DISCHARGE						NO DISCHARGE					
MONTHLY HIGH												
MONTHLY LOW												

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			D MAX 100 =0			D MAX 100 =0
TIMES EXCEEDED						

6: (*) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John R. Kremer 7/15/92





CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (K) 7

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 001M-----			EFFLUENT 001N	-----EFFLUENT 001P-----		
	SUSPENDED SOLIDS			SUSPENDED SLDS	SUSPENDED SOLIDS		
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET

MAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
								13				45	26	19																	
								10																							
								28																							
								8																							

MONTHLY AVG	NO DISCHARGE			15
MONTHLY HIGH				28
MONTHLY LOW				8

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO AVG 60 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			D MAX 100 =0				D MAX 100 =0
TIMES EXCEEDED							

KS: (*) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
[Signature] 7/5/92



CALIFORNIA REGIONAL WATER QUALITY
 CONTROL BOARD
 CENTRAL COAST REGION
 1102A LAUREL LANE
 SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
 DIABLO CANYON NUCLEAR POWER PLANT
 PO BOX 56
 AVILA BEACH, CALIF 93424
 PAGE (N) 8

FACILITY I.D.
 3 402003001

YEAR/ MO / DAY
 BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
 ENDING 92 / 05 / 31

STATE CODE
 06

NPDES PERMIT #
 CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 002-----			-----EFFLUENT 003-----		
	SUSPENDED SOLIDS					
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB MONTHLY			GRAB MONTHLY		

MAY	†	†	†	†	†	†	†	†	†	†	†	†
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19	15		12	2	3		28		16		12	
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												

MONTHLY AVG				3		
MONTHLY HIGH				4		
MONTHLY LOW				1		

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO LIMIT	NO LIMIT	NO AVG 30 =0
TIMES EXCEEDED			1 MAX 100 =0			1 MAX 100 =0
TIMES EXCEEDED						

S: (†) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
 JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Jack Krueger 7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (N) 9

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	-----EFFLUENT 003----- SUSPENDED SOLIDS			EFFLUENT 001N SETTL SOLIDS	EFFLUENT 001 T CHROMIUM	EFFLUENT 001 COPPER	EFFLUENT 001 NICKEL	EFFLUENT 001 ZINC
	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	ml/l	ug/l	ug/l	ug/l	ug/l
	GRAB			GRAB	GRAB	GRAB	GRAB	GRAB
	WEEKLY WHEN 001N & 001P => 003			WEEKLY	MONTHLY	MONTHLY	MONTHLY	MONTHLY
MAY	t	t	t	t	t	t	t	t
1								
2								
3								
4								
5					<1	<1	<1	<1
6								
7								
8					<0.1			
9								
10								
11								
12								
13					<0.1			
17								
18								
19								
20					<0.1			
21								
22								
23								
24								
25								
26								
27					<0.1			
28								
29								
30								
31								
MONTHLY AVG	NO DISCHARGE			<0.1				
MONTHLY HIGH				<0.1				
MONTHLY LOW				<0.1				
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 30 =0	NO AVG 1.0 =0	6M-MEAN 10 =0	6M-MEAN 10 =0	6M-MEAN 30 =0	6M-MEAN 70 =0
TIMES EXCEEDED			D MAX 100 =0	D MAX 3.0 =0	D MAX 40 =0	D MAX 50 =0	D MAX 100 =0	D MAX 380 =0
TIMES EXCEEDED					I MAX 100 =0	I MAX 140 =0	I MAX 260 =0	I MAX 990 =0

KS: (t) Number of Samples taken during the day.

PRINCIPAL EXECUTIVE OFFICER

JANES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT

DATE

J.R. Krueger

7/15/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (0) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT T CHROMIUM ug/l GRAB JA/AP/JUL/OCT	INFLUENT COPPER ug/l GRAB JA/AP/JUL/OCT	INFLUENT NICKEL ug/l GRAB JA/AP/JUL/OCT	INFLUENT AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 0016 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
--	---	---	---	--	--	--	--	--

MAY	†	†	†	†	†	†	†	†	†	†	†	†
1												
2												
3												
4												
5		<1 (**)	<1 (**)	<1 (**)								
6												
7												
8												
9												
10												
11												
12												
13												
14												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												

MONTHLY AVG												
MONTHLY HIGH												
MONTHLY LOW												
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MEAN 3060 =0	NO AVG 15 =0						
TIMES EXCEEDED					D MAX 12240 =0	D MAX 20 =0						
TIMES EXCEEDED					I MAX 30600 =0							

NOTES: (†) Number of Samples taken during the day. (**) Influent metal analysis performed for comparison to effluent analysis. ___ quarterly analysis were performed in April.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Jack Krenn 7/15/92

1
2
3



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (A) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 05 / 01

YEAR/ MO / DAY
ENDING 92 / 05 / 31

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLUENT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLUENT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLUENT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLUENT ZINC ug/l GRAB OCTOBER
--	---	------------------------------------	------------------------------------	------------------------------------	--	---------------------------------	-------------------------------------	---------------------------------

MAY	†	†	†	†	†	†	†	†
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								3 (**)

MONTHLY AVG
MONTHLY HIGH
MONTHLY LOW

TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MEAN 30 =0	NO LIMIT	6M-MEAN 10 =0	NO LIMIT	6M-MEAN 10 =0
TIMES EXCEEDED			D MAX 150 =0		D MAX 20 =0		D MAX 40 =0
TIMES EXCEEDED			I MAX 400 =0		I MAX 50 =0		I MAX 100 =0

KS: (†) Number of Samples taken during the day. (**) Influent Zinc analysis performed to compare with effluent analysis. All annuals will be performed in October.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John Krenn 7/15/92



Unit: 0 NPDES
001 EFFLUENT CHLORINATION

From: 5/01/92 0:01
Through: 5/31/92 23:59

Parameter:	CWP 1-1 1ST SMPL	CWP 1-1 2ND SMPL	CWP 1-2 1ST SMPL	CWP 1-2 2ND SMPL	CWP 2-1 1ST SMPL	CWP 2-1 2ND SMPL	CWP 2-2 1ST SMPL	CWP 2-2 2ND SMPL
Sample Time:	PPM							
5/01/92 10:00	0.090	0.120	0.130	0.100	0.130	0.120	0.140	0.130
5/05/92 10:00	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020
5/06/92 10:00								
5/07/92 10:00	<0.020	0.020	0.020	0.030	<0.020	0.050		
5/08/92 10:00	<0.020	0.050	<0.020	0.070	<0.020	0.090	<0.020	0.040
5/11/92 10:00	0.020	0.030	0.020	0.030	<0.020	0.020	<0.020	<0.020
5/12/92 10:00	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	0.030
5/14/92 10:00	<0.020	0.020	0.020	0.020	<0.020	<0.020	<0.020	<0.020
5/18/92 10:00	<0.020	0.030	0.020	0.030	<0.020	<0.020	<0.020	<0.020
5/19/92 10:00	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020
5/20/92 10:00	<0.020	<0.020	<0.020	0.020	<0.020	<0.020	<0.020	0.040
5/21/92 10:00	0.070	0.100	0.060	0.060	0.040	0.050	0.050	0.050
5/22/92 10:00	0.040	0.040	0.030	0.040	0.030	0.040	0.050	0.050
5/25/92 10:00	<0.020	0.050	0.040	0.050	0.040	0.050	0.050	0.050
5/26/92 10:00	0.050	0.080	<0.020	0.110	0.060	0.120	0.060	0.120
5/27/92 10:00	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020	<0.020
5/28/92 10:00	0.020	0.020	<0.020	<0.020	0.020	<0.020	0.030	0.020
5/29/92 10:00	<0.010	<0.010	<0.010	<0.010	0.020	0.020	0.015	0.030

NOTE: Individual sample results for Total Residual Chlorine (TRC) are adjusted by the following formula to account for dilution by the unchlorinated Circulating Water Pumps on the opposite operating Unit. It is assumed that no chlorine demand exists in the seawater:

$$\text{ppm TRC} \times \frac{\# \text{ of operating pumps on chlorinated Unit}}{\# \text{ of operating pumps for both Units}}$$

The daily average TRC value reported on the Q2 forms is the average of the adjusted TRC results for the day, which could include up to eight individual results (two analyses per chlorination cycle for a maximum of 4 cycles per day)

7/15/92 16:16

Requested by John Knemeyer

Page: 1



PACIFIC GAS & ELECTRIC - DIABLO CANYON POWER PLANT
 SANITARY WASTEWATER TREATMENT SYSTEM
 CONTRACT # Z78-2104-86

(REV. 5/90)

Sanitation and Operation Consultants, INC.
 16340 E. Maplegrove Street
 La Puente, CA 91744

Pacific Gas and Electric Co.
 Contacts:
 Randy Falcke (805) 595-4362
 John Knemeyer (805) 595-4472

CONSTITUENTS	UNITS	FREQ.	LIMITS		SAMPLE		RESULTS
			MONTHLY AVERAGE	DAILY MAX	DATE	TIME	
1. GREASE & OIL	mg/l	WEEKLY	15	20	5-8	11:01	4.7 mg/l Ave of 3
2. "	mg/l	"	15	20	5-14	12:18	4.7 mg/l Ave of 3
3. "	mg/l	"	15	20	5-20	12:36	3.3 mg/l Ave of 3
4. "	mg/l	"	15	20	5-27	12:44	4.7 mg/l Ave of 3
5. "	mg/l	"	15	20			
1. SUSPENDED SLDS	mg/l	WEEKLY	60	N/A	5-8	10:37	13mg/l
2. "	mg/l	"	60	N/A	5-14	12:02	10 mg/l
3. "	mg/l	"	60	N/A	5-20	12:10	28 mg/l
4. "	mg/l	"	60	N/A	5-27	12:28	8 mg/l
5. "	mg/l	"	60	N/A			
1. SETTLEABLE SLD	ml/l	WEEKLY	1.0	3.0	5-8	11:03	<0.1 ml/l
2. "	ml/l	"	1.0	3.0	5-14	12:10	<0.1 ml/l
3. "	ml/l	"	1.0	3.0	5-20	12:20	<0.1 ml/l
4. "	ml/l	"	1.0	3.0	5-27	12:36	<0.1 ml/l
5. "	ml/l	"	1.0	3.0			

NOTE:

- ANALYSIS RESULTS ABOVE THE MONTHLY AVERAGE SHALL BE REPORTED VERBALLY, WITHIN 8 HOURS, TO A PG&E CONTACT LISTED ABOVE.
- G&O AND SUSP. SLDS. SAMPLES ARE COMPOSITES DURING 1 DISCHARGE CYCLE.

COMMENTS:

SLUDGE DISPOSAL DATA

MONTH REMOVED	VOLUME REMOVED	WEIGHT REMOVED	DISPOSAL SITE
MAY 1992		1913 lbs	WALSH - NIPOMO



APPENDIX 3

Influent and Effluent Monitoring

June 1992



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (N) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 06 / 01

YEAR/ MO / DAY
ENDING 92 / 06 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 TEMPERATURE DEGREES F METERED CONTINUOUS	DELTA TEMP TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 FLOW MGD RECORDED DAILY	INFLUENT pH pH UNITS GRAB MONTHLY	EFFLUENT 001 pH pH UNITS GRAB MONTHLY (***)	EFFLUENT 001P pH pH UNITS GRAB MONTHLY	EFFLUENT 002 pH pH UNITS GRAB MONTHLY
JUNE	†	†	†	†	†	†	†	†
1	53.7	72.8	19.1	2557				
2	53.8	72.7	18.9	2557				
3	53.8	72.7	18.9	2554				
4	54.2	73.0	18.8	2556				
5	56.0	74.7	18.7	2554				2 8.0
6	56.8	75.6	18.8	2558				
7	55.3	74.5	19.2	2556				
8	54.1	72.9	18.8	2552				
9	53.7	72.6	18.9	2550	8.1	8.0		
10	55.0	73.7	18.7	2538				
11	53.7	72.8	19.1	2551				
12	52.1	71.0	18.9	2558				
13	50.9	69.6	18.7	2542				
14	50.7	67.4	16.7	2357				
	50.7	69.3	18.6	2558				
	50.5	69.2	18.7	2556				
17	50.6	69.2	18.6	2552				
18	51.0	69.7	18.7	2555			7.8	
19	51.0	69.7	18.7	2554				
20	50.6	69.3	18.7	2555				
21	51.8	70.4	18.6	2554				
22	52.1	70.9	18.8	2550				
23	51.8	71.1	19.3	2527				
24	52.1	70.5	18.4	2558				
25	52.1	70.8	18.7	2551				
26	51.8	70.6	18.8	2557				
27	51.6	70.4	18.8	2553				
28	52.2	70.9	18.7	2555				
29	53.1	71.8	18.7	2550				
30	54.8	73.5	18.7	2550				
31								
MONTHLY AVG	52.7	71.4	18.7	2546				8.0
MONTHLY HIGH	56.8	75.6	19.3	2558				8.0
MONTHLY LOW	50.5	67.4	17	2357				8.0
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MAX 22 = 0	MAX 2760 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED			(**)					
TIMES EXCEEDED								

REMARKS: (†) Number of Samples taken during the day. (**) Except During Demusseling.
(***) Daily when discharging chemical cleaning wastes from discharges 001D, F, I, L and/or M.

PRINCIPAL EXECUTIVE OFFICER
JANES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John Krenn 7/15/92



22
23

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (M) 2

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 06 / 01

YEAR/ MO / DAY
ENDING 92 / 06 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SHPL TYPE FREQ.	EFFLUENT 003 pH pH UNITS GRAB MONTHLY	EFFLUENT 004 pH pH UNITS GRAB MONTHLY	EFFLUENT 001H OIL & GREASE mg/l COMPOSITE WEEKLY	EFFLUENT 001P OIL & GREASE mg/l GRAB WEEKLY (††)	EFFLUENT 003 OIL & GREASE mg/l GRAB WEEKLY (†††)	EFFLUENT 001F OIL & GREASE mg/l GRAB MONTHLY	EFFLUENT 001 T CHLOR RES ug/l GRAB 2 per CYCLE	EFFLUENT 001 CHLORINE USED lbs/day RECORDED MONTHLY
--	---------------------------------------	---------------------------------------	--	--	--	--	--	---

JUNE	†	†	†	†	†	†	†	†	†	†
1									8 <10	216
2									8 <10	216
3										
4				4					8 20	216
5	7.7	8.0							8 <10	216
6										
7										
8									8 10	216
9									8 20	216
10				<3					8 10	216
11									8 10	216
12									8 10	216
13										
14										
17									8 10	216
18									8 20	216
19				4					8 10	216
20										
21										
22										
23										
24										
25				4					8 20	216
26									8 <10	216
27										
28										
29									8 15	216
30									8 <10	216
31										
MONTHLY AVG			4	NO DISCHARGE	NO DISCHARGE				13	216
MONTHLY HIGH			4						20	216
MONTHLY LOW			<3						<10	216

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO AVG 15 =0	I MAX 200 =0	NO LIMIT			
TIMES EXCEEDED			D MAX 20 =0					
TIMES EXCEEDED								

†K: (†) Number of Samples taken during the day.
 (††) When 001H is discharging to 001P. (†††) When 001P is discharging to 003.

PRINCIPAL EXECUTIVE OFFICER
 JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John Krenney 7/5/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (M) 3

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 06 / 01

YEAR/ MO / DAY
ENDING 92 / 06 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFF 001N=>003	EFF 001N=>003	-----EFFLUENT 001D-----			-----EFFLUENT 001F-----		
	TOTL COLIFORM	FECAL COLIFORM	SUSPENDED SOLIDS			SUSPENDED SOLIDS		
	MPH/100ml	MPH/100ml	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET	mg/l 1st FLTR	mg/l 2nd FLTR	mg/l NET
	GRAB	GRAB	GRAB			GRAB		

JUNE	†	†	†	†	†	†	†	†	†	†	†	†	†
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
17										19		<1	19
18													
19													
20													
21													
22													
23													
24													
25						6		<1		6			
26													
27													
28													
29													
30													
31													

MONTHLY AVG	NO DISCHARGE	NO DISCHARGE											
MONTHLY HIGH													
MONTHLY LOW													
TIMES EXCEEDED	80% SMPLS>1K	MEAN>200=0	NO LIMIT	NO LIMIT	NO AVG 30= 0	NO LIMIT	NO LIMIT	NO AVG 30 =0					
TIMES EXCEEDED	=0	90% SMPLS>400			D MAX 100 =0			D MAX 100 =0					
TIMES EXCEEDED	1 MAX >10K=0	=0											

TESTS: (†) Number of Samples taken during the day. _____

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
Joel Knevey 7/15/92















CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (0) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 06 / 01

YEAR/ MO / DAY
ENDING 92 / 06 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT T CHROMIUM ug/l GRAB JA/AP/JUL/OCT	INFLUENT COPPER ug/l GRAB JA/AP/JUL/OCT	INFLUENT NICKEL ug/l GRAB JA/AP/JUL/OCT	INFLUENT AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001G OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
--	---	---	---	--	--	--	--	--

JUNE	1	2	3	4	5	6	7	8	9	10	11	12	13	14	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
									<6 (**)	<1 (**)	<2 (**)																		

MONTHLY AVG
MONTHLY HIGH
MONTHLY LOW

TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MEAN 3060 =0	MO AVG 15 =0	MO AVG 15 =0	MO AVG 15 =0
TIMES EXCEEDED					D MAX 12240 =0	D MAX 20 =0	D MAX 20 =0	D MAX 20 =0
TIMES EXCEEDED					I MAX 30600 =0			

S: (**) Number of Samples taken during the day. (**) Influent metal analysis performed for comparison to effluent analysis. Quarterly analysis were performed in April.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
James D. Shiffer 7/5/92



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424
PAGE (A) 1

FACILITY I.D.
3 402003001

YEAR/ MO / DAY
BEGINNING 92 / 06 / 01

YEAR/ MO / DAY
ENDING 92 / 06 / 30

STATE CODE
06

NPDES PERMIT #
CA0003751

STATION ANALYSIS UNITS SKPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLUENT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLUENT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLUENT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLUENT ZINC ug/l GRAB OCTOBER
--	---	------------------------------------	------------------------------------	------------------------------------	--	---------------------------------	-------------------------------------	---------------------------------

JUNE	†	†	†	†	†	†	†	†	†
1									
2									
3									
4									
5									
6									
7									
8									
9									2 (**)
10									
11									
12									
13									
14									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									

MONTHLY AVG
MONTHLY HIGH
MONTHLY LOW

TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MEAN 30 =0	NO LIMIT	6M-MEAN 10 =0	NO LIMIT	6M-MEAN 10 =0
TIMES EXCEEDED			D MAX 150 =0		D MAX 20 =0		D MAX 40 =0
TIMES EXCEEDED			I MAX 400 =0		I MAX 50 =0		I MAX 100 =0

REMARKS: (†) Number of Samples taken during the day. (**) Influent Zinc analyzed for comparison to effluent analysis. All other analysis will be performed in October.

PRINCIPAL EXECUTIVE OFFICER
JAMES D. SHIFFER

SIGNATURE OF AUTHORIZED AGENT DATE
John R. Kennedy 7/15/92



Unit: 0 NPDES
001 EFFLUENT CHLORINATION

From: 6/01/92 0:01
Through: 6/30/92 23:59

Parameter:	CWP 1-1 1ST SMPL	CWP 1-1 2ND SMPL	CWP 1-2 1ST SMPL	CWP 1-2 2ND SMPL	CWP 2-1 1ST SMPL	CWP 2-1 2ND SMPL	CWP 2-2 1ST SMPL	CWP 2-2 2ND SMPL
Sample Time:	PPM							
6/01/92 10:00	<0.010	0.030	<0.010	0.030	<0.010	<0.010	<0.010	0.030
6/02/92 10:00	0.020	0.030	0.020	0.020	<0.010	<0.010	0.030	0.020
6/04/92 10:00	0.040	0.040	0.040	0.040	0.030	0.030	0.030	0.040
6/05/92 10:00	<0.010	0.020	0.010	0.030	<0.010	<0.010	<0.010	<0.010
6/08/92 10:00	0.020	0.030	0.030	0.030	0.020	0.030	0.020	0.030
6/09/92 10:00	0.030	0.030	0.030	0.040	0.020	0.030	0.030	0.030
6/10/92 10:00	0.020	0.030	0.020	0.030	0.020	0.020	0.020	0.030
6/11/92 10:00	0.020	0.020	0.030	0.030	0.020	0.020	0.020	0.020
6/12/92 10:00	0.030	0.030	0.030	0.040	0.020	0.020	0.020	0.030
6/15/92 10:00	0.020	0.040	0.030	0.040	0.020	0.030	0.020	0.020
6/16/92 10:00	0.020	0.040	0.040	0.050	0.030	0.040	0.040	0.040
6/19/92 10:00	0.020	0.020	0.010	0.030	0.010	0.020	0.010	0.030
6/25/92 10:00	0.030	0.030	0.030	0.040	0.030	0.040	0.030	0.040
6/26/92 10:00	0.020	0.030	<0.010	<0.010	0.030	0.040	<0.010	<0.010
6/29/92 10:00	0.010	0.020	0.020	0.030	0.010	0.010	0.010	0.030
6/30/92 10:00	<0.010	0.020	0.020	0.020	0.010	0.020	0.015	0.020

NOTE: Individual sample results for Total Residual Chlorine (TRC) are adjusted by the following formula to account for dilution by the unchlorinated Circulating Water Pumps on the opposite operating Unit. It is assumed that no chlorine demand exists in the seawater:

The daily average TRC value reported on the Q2 forms is the average of the adjusted TRC results for the day, which could include up to eight individual results (two analyses per chlorination cycle for a maximum of 4 cycles per day)

$$\text{ppm TRC} \times \frac{\# \text{ of operating pumps on chlorinated Unit}}{\# \text{ of operating pumps for both Units}}$$



PACIFIC GAS & ELECTRIC - DIABLO CANYON POWER PLANT
 SANITARY WASTEWATER TREATMENT SYSTEM
 CONTRACT # Z78-2104-86

(REV. 5/90)

Sanitation and Operation Consultants, INC.
 16340 E. Maplegrove Street
 La Puente, CA 91744

Pacific Gas and Electric Co.
 Contacts:
 Randy Falcke (805) 595-4362
 John Knemeyer (805) 595-4472

CONSTITUENTS	UNITS	FREQ.	LIMITS		SAMPLE		RESULTS
			MONTHLY AVERAGE	DAILY MAX	DATE	TIME	
1. GREASE & OIL	mg/l	WEEKLY	15	20	6-4	12:32	4.0 MG/L AVE OF
2. "	mg/l	"	15	20	6-10	1:08	< 3.0 MG/L " "
3. "	mg/l	"	15	20	6-19	9:46	4.0 MG/L " "
4. "	mg/l	"	15	20	6-25	10:07	4.0 MG/L " "
5. "	mg/l	"	15	20			
1. SUSPENDED SLDS	mg/l	WEEKLY	60	N/A	6-4	12:08	8.0 MG/L
2. "	mg/l	"	60	N/A	6-10	12:44	15.0 MG/L
3. "	mg/l	"	60	N/A	6-19	9:28	33.0 MG/L
4. "	mg/l	"	60	N/A	6-25	9:45	26.0 MG/L
5. "	mg/l	"	60	N/A			
1. SETTLEABLE SLD	ml/l	WEEKLY	1.0	3.0	6-4	12:25	< 0.1 ML/L
2. "	ml/l	"	1.0	3.0	6-10	1:10	< 0.1 ML/L
3. "	ml/l	"	1.0	3.0	6-19	9:52	< 0.1 ML/L
4. "	ml/l	"	1.0	3.0	6-25	10:22	< 0.1 ML/L
5. "	ml/l	"	1.0	3.0			

NOTE:

- ANALYSIS RESULTS ABOVE THE MONTHLY AVERAGE SHALL BE REPORTED VERBALLY, WITHIN 8 HOURS, TO A PG&E CONTACT LISTED ABOVE.
- G&O AND SUSP. SLDS. SAMPLES ARE COMPOSITES DURING 1 DISCHARGE CYCLE.

COMMENTS:

SLUDGE DISPOSAL DATA

MONTH REMOVED	VOLUME REMOVED	WEIGHT REMOVED	DISPOSAL SITE
JUNE 1992		1897 LBS	WALSH - NIPOMO

DATA SHEET COMPLETED BY: *Melody J. Beckley* DATE: 7-6-92



APPENDIX 4

Diablo Canyon Acute Bioassay Report

April 13, 1992



PACIFIC GAS AND ELECTRIC COMPANY
NOS Onsite Dosimetry and Environmental Services
-P.O. Box 56
Avila Beach, California 93424

LABORATORY TEST REPORT

SUBJECT: ACUTE TOXICITY ASSESSMENT OF DISCHARGE WATER FROM
DIABLO CANYON POWER PLANT, SECOND QUARTER OF 1992

Introduction:

One acute toxicity bioassay was conducted at the Nuclear Operations Support Diablo Canyon Biological Laboratory on water sampled on April 13, 1992, from Diablo Canyon Power Plant's discharge 001. This bioassay satisfies the quarterly requirement for acute toxicity testing in Diablo Canyon Power Plant's NPDES Permit.

Methods:

The bioassay was a standard 96-hour static acute toxicity test conducted using the guidelines in Kopperdahl (1976) and EPA (1985). The concentrations tested were 100 percent effluent and a dilution water control. Juvenile red abalone (Haliotis rufescens) were used as the test species.

Results:

The bioassay (DCPP-185) was begun within twenty-four hours of sample collection. Toxicity was 0 (no mortality was observed). All measured chemical and physical parameters fell within accepted limits. The data sheet is attached.

SUMMARY OF RESULTS

<u>Assay No.</u>	<u>Date Sampled</u>	<u>Location</u>	<u>Toxicity (TU)</u>
DCPP-185	April 13, 1992	Discharge 001	0 (no mortality)

References:

Kopperdahl, Fredric R. 1976. Guidelines for Performing Static Acute Toxicity Fish Bioassays in Municipal and Industrial Wastewaters. State Water Resources Control Board, and California Department of Fish and Game.

EPA, 1985. Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms. Third Edition. EPA/600/4-85/013.

Distribution: JVBoots
DCSommerville
RWLorenz
TCWilson
RMS Indexer

DATE May 13, 1992
TESTED BY James L. Kelly
APPROVED [Signature]
FILE NO. _____



PACIFIC GAS & ELECTRIC COMPANY

DIABLO CANYON BIOLOGICAL LABORATORY
 STATIC BIOASSAY REPORT SHEET

ASSAY NO. DCPP-185

One Concentration

TEST ORGANISM DATA

TEST SPECIES RED ABALONE, HALIOTIS RUFESCENS
 SOURCE CAYUCAS ABALONE FARM
 AVERAGE LENGTH 16.9 mm RANGE 13-23 mm
 ACCLIMATION TIME 3 mo. TEMPERATURE 13.9°C
 WATER SOURCE DCPP BIOLOGICAL LAB PUMP

TEST SOLUTION DATA

SOURCE OF TEST SOLUTION DIABLO CANYON POWER PLANT UNIT 1 AND UNIT 2 DISCHARGE EFFLUENT GRAB SAMPLE
 DATE/TIME SAMPLED 13 APRIL 1992 / 10:15 am BKC

DATE STARTED 13 APRIL 1992
 VOLUME/DEPTH OF TEST SOLUTION 16 LITER / 19 cm
 TYPE OF AERATION RING COMPRESSOR

TIME STARTED 15:30 HRS.
 RENEWAL OF TEST SOLUTION AT 7 HR. INTERVALS
 NUMBER OF ORGANISMS PER CONCENTRATION 30
 DILUTION WATER SOURCE CONTROL, BIO LAB PUMP

TEST CONCENTRATIONS

	100%	CONTROL	INITIALS
<u>0 HOURS</u>			
TEMP.	<u>14.3°C</u>	<u>14.3°C</u>	<u>BKC</u>
D.O.	<u>7.6</u>	<u>8.0</u>	<u>BKC</u>
PH	<u>8.0</u>	<u>8.0</u>	<u>BKC</u>
SALINITY/HARDNESS	<u>33.5</u>	<u>32.5</u>	<u>BKC</u>
<u>24 HOURS</u>			
ORGANISMS SURVIVING	<u>30</u>	<u>30</u>	<u>BKC</u>
% SURVIVAL	<u>100</u>	<u>100</u>	<u>BKC</u>
TEMP.	<u>13.2</u>	<u>13.2</u>	<u>BKC</u>
D.O.	<u>7.8</u>	<u>8.0</u>	<u>BKC</u>
PH	<u>7.9</u>	<u>8.0</u>	<u>BKC</u>
<u>48 HOURS</u>			
ORGANISMS SURVIVING	<u>30</u>	<u>30</u>	<u>BKC</u>
% SURVIVAL	<u>100</u>	<u>100</u>	<u>BKC</u>
TEMP.	<u>12.7</u>	<u>12.7</u>	<u>BKC</u>
D.O.	<u>8.0</u>	<u>8.2</u>	<u>BKC</u>
PH	<u>7.8</u>	<u>7.8</u>	<u>BKC</u>
<u>72 HOURS</u>			
ORGANISMS SURVIVING	<u>30</u>	<u>30</u>	<u>BKC</u>
% SURVIVAL	<u>100</u>	<u>100</u>	<u>BKC</u>
TEMP.	<u>12.8</u>	<u>12.8</u>	<u>BKC</u>
D.O.	<u>8.2</u>	<u>8.0</u>	<u>BKC</u>
PH	<u>7.7</u>	<u>7.5</u>	<u>BKC</u>
<u>96 HOURS</u>			
ORGANISMS SURVIVING	<u>30</u>	<u>30</u>	<u>BKC</u>
% SURVIVAL	<u>100</u>	<u>100</u>	<u>BKC</u>
TEMP.	<u>12.1°C</u>	<u>12.1°C</u>	<u>BKC</u>
D.O.	<u>8.4</u>	<u>8.2</u>	<u>BKC</u>
PH	<u>7.7</u>	<u>7.6</u>	<u>BKC</u>
SALINITY/HARDNESS	<u>34.5</u>	<u>34.0</u>	<u>BKC</u>

TU: 0, No MORTALITY
 Procedure No. 2.3
 Temp. Probe No. 054
 Cal. Due Date 20 MAY 1992

TESTED BY BK CUNNINGHAM

Reviewed by James L. Kelly



APPENDIX 5

Diablo Canyon Chronic Bioassay Report

First Quarter 1992



PACIFIC GAS AND ELECTRIC COMPANY
 NOS Onsite Dosimetry and Environmental Services
 -P.O. Box 56
 Avila Beach, California 93424

LABORATORY TEST REPORT

**SUBJECT: CHRONIC TOXICITY ASSESSMENT OF DISCHARGE WATER FROM
 DIABLO CANYON POWER PLANT, FIRST QUARTER OF 1992**

Introduction:

One chronic toxicity bioassay was conducted at the Nuclear Operations Support Diablo Canyon Biological Research Laboratory on water sampled January 14 through 15, 1992, from the discharge of Diablo Canyon Power Plant (DCPP). This bioassay satisfies the quarterly requirement for chronic toxicity testing in the 1990 California Ocean Plan.

Methods:

The assay was a 48-hour chronic test conducted using state approved protocols developed by the Water Resources Control Board. Larval red abalone (*Haliotis rufescens*) were used as the test organism.

Results:

The bioassay (DCPP-184) was begun within twenty-four hours of sample collection. The highest concentration that was not significantly different from the Control was the 100% dilution (No Observed Effect Concentration (NOEC) = 100%). Toxicity (TUc) = 100/NOEC = 1. All measured chemical and physical parameters fell within accepted limits. Data sheets are attached.

SUMMARY OF RESULTS

<u>Assay No.</u>	<u>Date Sampled</u>	<u>Location</u>	<u>Toxicity (TUc)</u>
DCPP-184	January 14, 1992	Discharge	1 (NOEC = 100%)

The calculated effluent concentration limit from Chapter IV, Section A of the 1990 California Ocean Plan is 5.11. Since the measured toxicity (1) is below this limit, DCPP is in compliance with the 1990 California Ocean Plan.

References:

State of California. October 1990. Procedures Manual for Conducting Toxicity Tests Developed by the Marine Bioassay Project. Water Resources Control Board.

Distribution: JVBoots
 DCSommerville
 RWLorenz
 JWarrick
 TCWilson
 RMS Indexer

DATE February 11, 1992
 TESTED BY James L. Kelly
 APPROVED [Signature]
 FILE NO. _____




Test Container Number	Effluent Concentration Percent	Number Abnormal Larvae	Number Normal Larvae	Percentage of Normal Larvae	Mean % Normal Larvae	Standard Deviation Normal L.	Mean less Standard Deviation	Mean plus Standard Deviation	Percentage of Abnormal Larvae	Mean % Abnormal Larvae
14	0.0%	1	199	99.50%	0.975	0.013	0.962	0.988	0.50%	0.025
35		6	194	97.00%					3.00%	
44		4	196	98.00%					2.00%	
49		6	194	97.00%					3.00%	
68		8	192	96.00%					4.00%	
1	10.0%	8	192	96.00%	0.943	0.024	0.919	0.967	4.00%	0.057
18		8	192	96.00%					4.00%	
25		8	192	96.00%					4.00%	
67		15	185	92.50%					7.50%	
69		18	182	91.00%					9.00%	
4	20.0%	11	189	94.50%	0.964	0.018	0.946	0.982	5.50%	0.036
7		3	197	98.50%					1.50%	
20		10	190	95.00%					5.00%	
43		4	196	98.00%					2.00%	
64		8	192	96.00%					4.00%	
6	32.0%	11	189	94.50%	0.938	0.034	0.904	0.972	5.50%	0.062
12		5	195	97.50%					2.50%	
38		19	181	90.50%					9.50%	
41		20	180	90.00%					10.00%	
61		7	193	96.50%					3.50%	
3	56.0%	10	190	95.00%	0.947	0.024	0.923	0.971	5.00%	0.053
9		6	194	97.00%					3.00%	
40		6	194	97.00%					3.00%	
59		14	186	93.00%					7.00%	
65		17	183	91.50%					8.50%	
10	100.0%	12	188	94.00%	0.945	0.020	0.925	0.965	6.00%	0.055
21		16	184	92.00%					8.00%	
29		13	187	93.50%					6.50%	
48		8	192	96.00%					4.00%	
53		6	194	97.00%					3.00%	




Test Container Number	Effluent Concentration ug per Liter	Number Abnormal Larvae	Number Normal Larvae	Percentage of Normal Larvae	Mean % Normal Larvae	Standard Deviation Normal L.	Mean less Standard Deviation	Mean plus Standard Deviation	Percentage of Abnormal Larvae	Mean % Abnormal Larvae
14	0.0	1	199	99.50%	0.975	0.013	0.962	0.988	0.50%	0.025
35		6	194	97.00%					3.00%	
44		4	196	98.00%					2.00%	
49		6	194	97.00%					3.00%	
68		8	192	96.00%					4.00%	
8	18.0	15	185	92.50%	0.939	0.019	0.920	0.958	7.50%	0.061
11		17	183	91.50%					8.50%	
36		9	191	95.50%					4.50%	
45		8	192	96.00%					4.00%	
55		12	188	94.00%					6.00%	
17	32.0	13	187	93.50%	0.935	0.033	0.902	0.968	6.50%	0.065
31		19	181	90.50%					9.50%	
51		5	195	97.50%					2.50%	
57		8	192	96.00%					4.00%	
66		20	180	90.00%					10.00%	
2	56.0	182	18	9.00%	0.145	0.081	0.064	0.226	91.00%	0.855
39		172	28	14.00%					86.00%	
46		149	51	25.50%					74.50%	
50		162	38	19.00%					81.00%	
70		190	10	5.00%					95.00%	









1
2
3
4
5



PHYSICAL / CHEMICAL MEASUREMENTS
Red Abalone Chronic Bioassay
Diablo Canyon Biological Laboratory

Test Start Date/Time : 15 January 1992 , 14:30.

Bioassay Number (s) : DCPP-184 , MBPP-45

Test Finish Date/Time : 17 January 1992 , 14:30

Collection Date (s) : 14 Jan. 1992 - 15 Jan. 1992

Test Organism : *Halotis rufescens*

MEASUREMENTS AT START OF ASSAY

MEASUREMENTS AT FINISH OF ASSAY

	PH	D.OXYGEN	SALINITY	CONTAINER	PH	D.OXYGEN	SALINITY
CONTROL	7.98	7.69	32.5	68	7.97	7.48	34

REFERENCE TOXICANT : ZnSO4

18ug / L	8.04	7.68	34	55	7.96	7.88	34.5
32ug / L	8.04	7.72	32	51	8.00	7.89	34.5
56ug / L	8.06	7.86	33.5	46	8.04	7.75	35

Effluent Source : DCPP Unit 1, Unit 2 Discharge

Collection Date/Time : 14-15 Jan.1992, 08:30

10%	8.03	7.76	33	18	8.00	7.86	35.5
20%	8.04	7.75	34	7	7.95	7.70	34.5
32%	8.05	7.78	33.5	38	7.97	7.68	36
56%	8.06	7.65	33	9	7.98	7.81	35
100%	8.08	7.32	33	21	8.01	7.59	35.5

Effluent Source : MBPP Composite Discharge

Collection Date/Time : 14-15 Jan. 1992, 07:00

10%	8.02	7.72	33.5	47	7.98	7.71	34
20%	8.05	7.37	34	34	8.00	7.64	36
32%	8.05	7.90	34	26	8.00	7.66	35.5
56%	8.04	7.66	34.5	62	7.99	7.69	35
100%	8.06	8.01	33.5	54	8.01	7.86	35

Hourly Temperature Data

Hour 01	Hour 13	Hour 25	Hour 37
14.92	15.09	14.91	15.15
14.84	15.11	14.96	15.10
14.93	15.09	14.99	15.16
15.02	15.11	15.05	15.08
15.12	15.04	15.16	15.11
15.13	15.09	15.21	15.13
15.09	15.10	15.25	15.10
15.11	15.22	15.23	15.16
15.16	14.92	15.21	15.11
15.10	14.65	15.14	15.08
15.11	14.77	15.16	14.99
15.14	14.85	15.16	14.93
Hour 12	Hour 24	Hour36	Hour48

Mean Temperature 48 Hour Static Test

15.07

Degrees Celcius

Analyzed By : BK CUNNINGHAM

Reviewed by : James L. Kelly

Date Analyzed : 15 January 1992 , 17 January 1992

Date Reviewed : January 23, 1992



ABALONE SPAWN AND FERTILIZATION WORKSHEET

Red Abalone Chronic Bioassay
Diablo Canyon Biological Laboratory

Test Start Date/Time : 15 JAN 1992, 14:30 Bioassay Number(s) : DCPP - 184, MBPP - 45

Test Finish Date/Time : 17 JAN 1992, 14:30 Effluent Source (s) : DCPP, MBPP, DISCHARGE

Test Organism : Haliotis rufescens Collection Date/Time : 14 JAN - 15 JAN 1992

Males Used			Females Used		
	Gonad Index	Date Last Used		Gonad Index	Date Last Used
1	UNMARKED	4	1	UNMARKED	4
2)	4	2)	4
3)	3	3)	4
4)	3	4)	3

Method of spawning : Peroxide () UV irradiated seawater () Other _____

Beginning of spawning treatment : 10:25

First male spawns : 12:30

ADDITION OF SPERM TO EGGS 13:20

First female spawns : 12:55

Multiple spawners : Male : 12:40 Female : 13:10

Condition of spawn : Males : () light moderate () heavy : Females : () light () moderate heavy

Time fertilization complete : 13:40

Condense the fertilized eggs into a beaker and determine the density. Counts of 1 ml samples :

1: 517 2: 616 3: 549 4: 601 5: 623

Mean : 581.2 STD : _____

$\Sigma = 2906$

Add 1000 embryos to each test container :
Pipette the volume calculated below from the well-mixed beaker sampled above.

(1000 embryos/test container) / (581 #embryos/ml) = 1.72 ml/test container

Temperature of embryos : 15.5° Celcius Temperature of test containers : 14.87° Celcius

Time all containers in incubator : 14:30

Comments : FOLLOWING FERTILIZATION APPROXIMATELY 15-20
SPERM IN CONTACT WITH OUTER MEMBRANE OF EGG.
1.8 MILLILITERS OF EMBRYO SOLUTION ADDED TO EACH TEST CONTAINER

Prepared By : BK CUNNINGHAM

Reviewed By : James I. Kelly

Date Prepared : 15 JANUARY 1992

Date Reviewed : January 23, 1992



DCPP First Quarter 1992 Chronic
File: DCPP-184 Transform: ARC SINE(SQUARE ROOT(Y))

Shapiro Wilks test for normality

D = 0.072

W = 0.934

Critical W (P = 0.05) (n = 30) = 0.927

Critical W (P = 0.01) (n = 30) = 0.900

Data PASS normality test at P=0.01 level. Continue analysis.

DCPP First Quarter 1992 Chronic
File: DCPP-184 Transform: ARC SINE(SQUARE ROOT(Y))

Bartlett's test for homogeneity of variance

Calculated B statistic = 1.11

Table Chi-square value = 15.09 (alpha = 0.01)

Table Chi-square value = 11.07 (alpha = 0.05)

Average df used in calculation ==> df (avg n - 1) = 4.00

Used for Chi-square table value ==> df (#groups-1) = 5

Data PASS homogeneity test at 0.01 level. Continue analysis.



DCPP First Quarter 1992 Chronic

File: DCPP-184

Transform: ARC SINE(SQUARE ROOT(Y))

ANOVA TABLE

SOURCE	DF	SS	MS	F
Between	5	0.033	0.007	2.333
Within (Error)	24	0.072	0.003	
Total	29	0.105		

Critical F value = 2.62 (0.05,5,24)

Since F < Critical F FAIL TO REJECT Ho:All groups equal

DCPP First Quarter 1992 Chronic

File: DCPP-184

Transform: ARC SINE(SQUARE ROOT(Y))

DUNNETTS TEST - TABLE 1 OF 2

Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	MEAN CALCULATED IN ORIGINAL UNITS	T STAT	SIG
1	Control	1.418	0.975		
2	10%	1.334	0.943	2.448	*
3	20%	1.385	0.964	0.959	
4	32%	1.327	0.938	2.636	*
5	56%	1.343	0.947	2.166	
6	100%	1.337	0.945	2.340	

Dunnett table value = 2.36 (1 Tailed Value, P=0.05, df=24,5)

DCPP First Quarter 1992 Chronic

File: DCPP-184

Transform: ARC SINE(SQUARE ROOT(Y))

STEELS MANY-ONE RANK TEST

Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	RANK SUM	CRIT. VALUE	df	SIG
1	Control	1.418				
2	10%	1.334	16.50	16.00	5.00	
3	20%	1.385	23.00	16.00	5.00	
4	32%	1.327	19.00	16.00	5.00	
5	56%	1.343	19.00	16.00	5.00	
6	100%	1.337	17.50	16.00	5.00	

Critical values use k = 5, are 1 tailed, and alpha = 0.05



MBPP & DCPD First Quarter 1992 Reference Toxicant
File: ZMBDC-45.184 Transform: ARC SINE(SQUARE ROOT(Y))

Shapiro Wilks test for normality

D = 0.093

W = 0.986

Critical W (P = 0.05) (n = 20) = 0.905

Critical W (P = 0.01) (n = 20) = 0.868

Data PASS normality test at P=0.01 level. Continue analysis.

MBPP & DCPD First Quarter 1992 Reference Toxicant
File: ZMBDC-45.184 Transform: ARC SINE(SQUARE ROOT(Y))

Bartlett's test for homogeneity of variance

Calculated B statistic = 5.02

Table Chi-square value = 11.34 (alpha = 0.01)

Table Chi-square value = 7.81 (alpha = 0.05)

Average df used in calculation ==> df (avg n - 1) = 4.00

Used for Chi-square table value ==> df (#groups-1) = 3

Data PASS homogeneity test at 0.01 level. Continue analysis.



ANOVA TABLE

SOURCE	DF	SS	MS	F
Between	3	3.598	1.199	199.833
Within (Error)	16	0.093	0.006	
Total	19	3.691		

Critical F value = 3.24 (0.05,3,16)
 Since F > Critical F REJECT Ho:All groups equal

DUNNETTS TEST - TABLE 1 OF 2 Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	MEAN CALCULATED IN ORIGINAL UNITS	T STAT	SIG
1	Control	1.418	0.975		
2	18 ug/l	1.324	0.939	1.934	
3	32 ug/l	1.320	0.935	2.004	
4	56 ug/l	0.379	0.145	21.220	*

Dunnett table value = 2.23 (1 Tailed Value, P=0.05, df=16,3)

STEELS MANY-ONE RANK TEST - Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	RANK SUM	CRIT. VALUE	df	SIG
1	Control	1.418				
2	18 ug/l	1.324	15.50	17.00	5.00	*
3	32 ug/l	1.320	18.50	17.00	5.00	
4	56 ug/l	0.379	15.00	17.00	5.00	*


Critical values use k = 3, are 1 tailed, and alpha = 0.05



APPENDIX 6

Diablo Canyon Chronic Bioassay Report

Second Quarter 1992



PACIFIC GAS AND ELECTRIC COMPANY
NOS Onsite Dosimetry and Environmental Services
 P.O. Box 56
 Avila Beach, California 93424

LABORATORY TEST REPORT

**SUBJECT: CHRONIC TOXICITY ASSESSMENT OF DISCHARGE WATER FROM
 DIABLO CANYON POWER PLANT, SECOND QUARTER OF 1992**

Introduction:

One chronic toxicity bioassay was conducted at the Nuclear Operations Support Diablo Canyon Biological Research Laboratory on water sampled April 14 through 15, 1992, from Diablo Canyon Power Plant's Discharge 001. This bioassay satisfies the quarterly requirement for chronic toxicity testing in the 1990 California Ocean Plan.

Methods:

The bioassay was a 48-hour chronic test conducted using a state approved protocol developed by the Water Resources Control Board. Larval red abalone (Haliotis rufescens) were used as the test organism.

Results:

The bioassay (DCPP-186) was begun within thirty-six hours of sample collection. The highest concentration that was not significantly different from the Control was the 100% concentration (No Observed Effect Level (NOEL) = 100%). Toxicity (TUC) = 100/NOEL = 1. Reference toxicant toxicity and all measured chemical and physical parameters fell within accepted limits. The data were analysed using ANOVA with Dunnet's Test. The test met all specified acceptance criteria. Data sheets are attached.

SUMMARY OF RESULTS

<u>Test Solution</u>	<u>Assay No.</u>	<u>Date Sampled</u>	<u>Toxicity (TUC)</u>
Discharge 001	DCPP-186	April 14-15, 1992	1.0 (NOEL = 100%)
Reference Toxicant	NA	April 16, 1992	3.13 (NOEL = 32%)

The calculated effluent concentration limit from Chapter IV, Section A of the 1990 California Ocean Plan is 5.11. Since the measured toxicity (1) is below this limit, DCPP is in compliance with the 1990 California Ocean Plan.

References:


State of California. October 1990. Procedures Manual for Conducting Toxicity Tests Developed by the Marine Bioassay Project. Water Resources Control Board.

Distribution: JVBoots
 DCSommerville

RWLorenz
 JWWarrick

TCWilson
 RMS Indexer

DATE May 13, 1992
 TESTED BY James L. Kelly
 APPROVED [Signature]
 FILE NO. _____




Test Container Number	Effluent Concentration Percent	Number Abnormal Larvae	Number Normal Larvae	Percentage of Normal Larvae	Mean % Normal Larvae	Standard Deviation Normal	Mean less Standard Deviation	Mean plus Standard Deviation	Percentage of Abnormal Larvae	Mean % Abnormal Larvae
5	0.0%	2	198	99.00%	0.985	0.012	0.973	0.997	1.00%	0.015
6		1	199	99.50%					0.50%	
24		3	197	98.50%					1.50%	
38		2	198	99.00%					1.00%	
40		7	193	96.50%					3.50%	
32	10.0%	8	192	96.00%	0.977	0.013	0.964	0.990	4.00%	0.023
45		4	196	98.00%					2.00%	
46		1	199	99.50%					0.50%	
52		4	196	98.00%					2.00%	
61		6	194	97.00%					3.00%	
16	20.0%	2	198	99.00%	0.972	0.025	0.947	0.997	1.00%	0.028
17		8	192	96.00%					4.00%	
51		13	187	93.50%					6.50%	
69		1	199	99.50%					0.50%	
70		4	196	98.00%					2.00%	
29	32.0%	4	196	98.00%	0.972	0.030	0.942	1.002	2.00%	0.028
31		5	195	97.50%					2.50%	
37		2	198	99.00%					1.00%	
49		16	184	92.00%					8.00%	
60		1	199	99.50%					0.50%	
18	56.0%	4	196	98.00%	0.977	0.015	0.962	0.992	2.00%	0.023
43		9	191	95.50%					4.50%	
44		3	197	98.50%					1.50%	
47		1	199	99.50%					0.50%	
58		6	194	97.00%					3.00%	
8	100.0%	3	197	98.50%	0.985	0.009	0.976	0.994	1.50%	0.015
15		1	199	99.50%					0.50%	
34		6	194	97.00%					3.00%	
36		3	197	98.50%					1.50%	
59		2	198	99.00%					1.00%	



Test Container Number	Effluent Concentration ug per Liter	Number Abnormal Larvae	Number Normal Larvae	Percentage of Normal Larvae	Mean % Normal Larvae	Standard Deviation Normal L.	Mean less Standard Deviation	Mean plus Standard Deviation	Percentage of Abnormal Larvae	Mean % Abnormal Larvae
5	0.0	2	198	99.00%	0.985	0.012	0.973	0.997	1.00%	0.015
6		1	199	99.50%					0.50%	
24		3	197	98.50%					1.50%	
38		2	198	99.00%					1.00%	
40	7	193	96.50%	3.50%						
4	18.0	4	196	98.00%	0.981	0.010	0.971	0.991	2.00%	0.019
10		2	198	99.00%					1.00%	
27		2	198	99.00%					1.00%	
50		7	193	96.50%					3.50%	
57		4	196	98.00%					2.00%	
1	32.0	3	197	98.50%	0.986	0.012	0.974	0.998	1.50%	0.014
23		4	196	98.00%					2.00%	
30		6	194	97.00%					3.00%	
39		1	199	99.50%					0.50%	
62		0	200	100.00%					0.00%	
7	56.0	139	61	30.50%	0.279	0.091	0.188	0.370	69.50%	0.721
11		138	62	31.00%					69.00%	
21		147	53	26.50%					73.50%	
35		173	27	13.50%					86.50%	
66		124	76	38.00%					62.00%	




April 16 - 18, 1992





April 16 - 18, 1992





PHYSICAL / CHEMICAL MEASUREMENTS
Red Abalone Chronic Bioassay
Diablo Canyon Biological Laboratory

Test Start Date/Time : 16 April 1992 @ 14:30

Bioassay Number (s) : DCP - 186

Test Finish Date/Time : 18 April 1992 @ 14:30

Collection Date (s) : April 14-15, 1992 @ 11:00

Test Organism : *Haliotis rufescens*

MEASUREMENTS AT START OF ASSAY

MEASUREMENTS AT FINISH OF ASSAY

	PH	D.OXYGEN	SALINITY	CONTAINER	PH	D.OXYGEN	SALINITY
CONTROL	7.9	7	34	5	7.8	7.3	35.5

REFERENCE TOXICANT : ZnSO4

18ug / L	7.9	7.3	34	50	7.8	7.4	35
32ug / L	7.9	7.3	34	39	7.8	7.5	35
56ug / L	7.9	7.2	34	66	7.8	7.4	35

Effluent Source : DCP Unit 1 and Unit 2 Discharge.

Collection Date/Time : April 14-15, 1992 @ 11:00

10%	7.9	7.2	33	45	7.7	7.5	34
20%	7.8	7.1	33	70	7.7	7.3	34
32%	7.9	7.1	32.5	37	7.8	7.4	34.5
56%	7.9	7.1	32.5	43	7.8	7.3	34
100%	7.9	6.9	32.5	36	7.8	7.2	35

Hourly Temperature Data

Hour 01	Hour 13	Hour 25	Hour 37
15.33	14.94	14.77	15.01
15.30	14.94	14.92	15.02
15.16	14.95	14.99	14.99
15.02	14.93	14.90	14.99
14.95	14.92	14.86	14.99
14.90	14.85	14.84	14.94
14.87	14.78	14.87	14.86
14.89	14.68	14.92	14.74
14.88	14.60	14.92	14.66
14.90	14.61	14.91	14.65
14.89	14.67	14.94	14.65
14.90	14.64	14.98	14.65
Hour 12	Hour 24	Hour 36	Hour 48

Mean Temperature 48 Hour Static Test

14.88 Degrees Celcius

Standard Deviation Hourly Temperature

0.16

Analyzed By : BK Cunningham

Reviewed by : *James L. Kelly*

Date Analyzed : April 15, 1992 . April 18, 1992

Date Reviewed : *April 22, 1992*



ABALONE SPAWN AND FERTILIZATION WORKSHEET
 Red Abalone Chronic Bioassay
 Diablo Canyon Biological Laboratory

Test Start Date/Time : 16 Apr 1992, 14:30 Bioassay Number(s) : DCPP-186, MBPP-46

Test Finish Date/Time : 18 Apr 1992, 14:30 Effluent Source(s) : DCPP Discharge, MBPP Discharge

Test Organism : Haliotis rufescens Collection Date/Time : Apr.14-15, 1992 : 24 Hr Composite

	<u>Males Used</u>	<u>Gonad Index</u>	<u>Date Last Used</u>		<u>Females Used</u>	<u>Gonad Index</u>	<u>Date Last Used</u>
1	<u>Unmarked</u>	<u>4</u>	<u></u>	1	<u>19F</u>	<u>4</u>	<u></u>
2	<u>Unmarked</u>	<u>3</u>	<u></u>	2	<u>Unmarked</u>	<u>4</u>	<u></u>
3	<u>Unmarked</u>	<u>3</u>	<u></u>	3	<u>Unmarked</u>	<u>4</u>	<u></u>
4	<u>Unmarked</u>	<u>3</u>	<u></u>	4	<u>Unmarked</u>	<u>4</u>	<u></u>

Method of spawning : Peroxide () UV irradiated seawater () Other _____

Beginning of spawning treatment : 09:20

First male spawns : 12:35

First female spawns : 12:50

Comments : PEROXIDE FLUSHED OUT 12:00
NO SECOND MALE, 1 of 7 SPAWNED

Multiple spawners : Male : 0 Female : 13:10

Condition of spawn : Males : light () moderate () heavy : Females : () light () moderate heavy

Sperm Added to Egg Container : 13:20 Time fertilization complete : 13:35

Condense the fertilized eggs into a beaker and determine the density. Counts of 1 ml samples :

1: 242 2: 289 3: 213 4: 275 5: 211
 Mean : 246 STD : _____

Add 1000 embryos to each test container :
 Pipette the volume calculated below from the well-mixed beaker sampled above.

(1000 embryos/test container) / (246 #embryos/ml) = 4.06 ml/test container

Temperature of embryos : 14.5° Celcius Temperature of test containers : 15.13° Celcius

Time all containers in incubator : 14:30

Comments : Due to failure to induce successful spawn of males on previous day, 3 Additional Unmarked males, gonad index 3, placed in a second isolated spawn bucket and treated with peroxide (same time interval.) in order to increase potential for male spawn. 4.0 ml of EMBRYO SOLUTION ADDED.

Prepared By : B K Cunningham

Reviewed By : James L. Kelly

Date Prepared : April 16, 1992

Date Reviewed : April 22, 1992



DCPP-186 DCPD 2nd Quarter 1992 Chronic Bioassay
File: DCPD-186 Transform: ARC SINE(SQUARE ROOT(Y))

Shapiro Wilks test for normality

D = 0.085

W = 0.959

Critical W (P = 0.05) (n = 30) = 0.927

Critical W (P = 0.01) (n = 30) = 0.900

Data PASS normality test at P=0.01 level. Continue analysis.

DCPP-186 DCPD 2nd Quarter 1992 Chronic Bioassay
File: DCPD-186 Transform: ARC SINE(SQUARE ROOT(Y))

Bartlett's test for homogeneity of variance

Calculated B statistic = 3.51

Table Chi-square value = 15.09 (alpha = 0.01)

Table Chi-square value = 11.07 (alpha = 0.05)

Average df used in calculation ==> df (avg n - 1) = 4.00

Used for Chi-square table value ==> df (#groups-1) = 5

Data PASS homogeneity test at 0.01 level. Continue analysis.



ANOVA TABLE

SOURCE	DF	SS	MS	F
Between	5	0.007	0.001	0.250
Within (Error)	24	0.085	0.004	
Total	29	0.092		

Critical F value = 2.62 (0.05,5,24)
 Since F < Critical F FAIL TO REJECT Ho:All groups equal

DUNNETTS TEST - TABLE 1 OF 2 Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	MEAN CALCULATED IN ORIGINAL UNITS	T STAT	SIG
1	Control	1.454	0.985		
2	10%	1.425	0.977	0.740	
3	20%	1.416	0.972	0.950	
4	32%	1.419	0.972	0.881	
5	56%	1.426	0.977	0.706	
6	100%	1.453	0.985	0.043	

Dunnett table value = 2.36 (1 Tailed Value, P=0.05, df=24,5)

STEELS MANY-ONE RANK TEST - Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	RANK SUM	CRIT. VALUE	df	SIG
1	Control	1.454				
2	10%	1.425	22.50	16.00	5.00	
3	20%	1.416	23.50	16.00	5.00	
4	32%	1.419	24.50	16.00	5.00	
5	56%	1.426	23.00	16.00	5.00	
6	100%	1.453	26.50	16.00	5.00	

Critical values use k = 5, are 1 tailed, and alpha = 0.05



ZnSO4 Reference Toxicant for DCCP-186
File: ZDCMB186.46 Transform: ARC SINE(SQUARE ROOT(Y))

Shapiro Wilks test for normality

D = 0.072

W = 0.928

Critical W (P = 0.05) (n = 20) = 0.905

Critical W (P = 0.01) (n = 20) = 0.868

Data PASS normality test at P=0.01 level. Continue analysis.

ZnSO4 Reference Toxicant for DCCP-186
File: ZDCMB186.46 Transform: ARC SINE(SQUARE ROOT(Y))

Bartlett's test for homogeneity of variance

Calculated B statistic = 5.31

Table Chi-square value = 11.34 (alpha = 0.01)

Table Chi-square value = 7.81 (alpha = 0.05)

Average df used in calculation ==> df (avg n - 1) = 4.00

Used for Chi-square table value ==> df (#groups-1) = 3

Data PASS homogeneity test at 0.01 level. Continue analysis.



ZnSO4 Reference Toxicant for DCPP-186
 File: ZDCMB186.46 Transform: ARC SINE(SQUARE ROOT(Y))

ANOVA TABLE

SOURCE	DF	SS	MS	F
Between	3	3.036	1.012	253.000
Within (Error)	16	0.072	0.004	
Total	19	3.107		

Critical F value = 3.24 (0.05,3,16)
 Since F > Critical F REJECT Ho:All groups equal

ZnSO4 Reference Toxicant for DCPP-186
 File: ZDCMB186.46 Transform: ARC SINE(SQUARE ROOT(Y))

DUNNETTS TEST - TABLE 1 OF 2 Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	MEAN CALCULATED IN ORIGINAL UNITS	T STAT	SIG
1	Control	1.454	0.985		
2	18 ug/l	1.436	0.981	0.451	
3	32 ug/l	1.462	0.986	-0.186	
4	56 ug/l	0.551	0.279	22.576	*

Dunnett table value = 2.23 (1 Tailed Value, P=0.05, df=16,3)

ZnSO4 Reference Toxicant for DCPP-186
 File: ZDCMB186.46 Transform: ARC SINE(SQUARE ROOT(Y))

STEELS MANY-ONE RANK TEST - Ho:Control<Treatment

GROUP	IDENTIFICATION	TRANSFORMED MEAN	RANK SUM	CRIT. VALUE	df	SIG
1	Control	1.454				
2	18 ug/l	1.436	23.50	17.00	5.00	
3	32 ug/l	1.462	28.00	17.00	5.00	
4	56 ug/l	0.551	15.00	17.00	5.00	*

Critical values use k = 3, are 1 tailed, and alpha = 0.05



APPENDIX 7

Stratified Water Temperature

June 29, 1992



**DIABLO CANYON POWER PLANT
RECEIVING WATER
STRATIFIED WATER TEMPERATURES**

June 29, 1992

On June 29, 1992, stratified water temperatures were measured at six stations inside Diablo Cove (Figure 1). Swell was from the northwest at a height of about 2-3 feet. There was light wind during the sampling. Air temperature was approximately 65 - 70 degrees Fahrenheit.

Water temperatures were measured at one meter depth intervals utilizing a Pacer Systems, Inc. Model 1003/TDR temperature and depth recorder. This instrument was used in place of the electronic bathythermograph, which was malfunctioning. The Pacer TDR is a self-contained unit with a temperature sensor which has a response time of 60 seconds at full scale, which is 30°C, and an accuracy to $\pm 0.1^\circ\text{C}$. Due to the slower response time of this unit when compared to the bathythermograph, the TDR was lowered to depth a meter at a time and held at that depth for 60 seconds. Response time within the temperature range recorded appeared to be less than 10 seconds. This procedure was followed at each station, except at Station 12 where the unit was lowered 2 meters at a time after the first 6 meters. Temperatures at all stations were recorded from the surface to bottom according to the requirements of the plant's NPDES Permit.

Instrument depth is determined by a pressure transducer with a resolution of 0.02% (full scale). The TDR's yearly temperature and pressure calibration is traceable to the National Institute of Standards and Technology.

Water temperatures (Table 1) ranged from a high of 68.2°F at the surface at Station 10 to a low of 52.6°F on the bottom at Stations 11 and 12. The range of water temperatures measured between the top and bottom at any one station varied from 15.4°F at Station 10 to 8.9°F at Station 14. Stratification of the water column is influenced by the thermal discharge plume.






Figure 1: Stratified Temperature, Disolved Oxygen and pH Stations




TABLE 1

DIABLO CANYON POWER PLANT
 OCEANOGRAPHIC STATIONS
 VERTICAL TEMPERATURE PROFILES

JUNE 29, 1992

STATION 10		STATION 11		STATION 12	
DEPTH(m)	TEMP(F)	DEPTH(m)	TEMP(F)	DEPTH(m)	TEMP(F)
0.0	68.2	0.0	67.2	0.0	64.8
1.0	68.2	1.0	65.0	1.0	64.4
2.0	67.0	2.0	64.0	2.0	63.2
3.0	63.0	3.0	63.4	3.0	61.1
4.0	60.9	4.0	60.9	4.0	54.7
5.0	59.6	5.0	59.5	5.0	53.3
6.0	57.1	6.0	53.0	6.0	53.1
7.0	52.9	7.0	52.9	7.0	
8.0	52.8	8.0	52.8	8.0	53.1
9.0	52.9	9.0	52.8	9.0	
		10.0	52.8	10.0	53.0
				11.0	
				12.0	52.9
				13.0	
				14.0	52.8
				15.0	
				16.0	52.6

STATION 13		STATION 14		STATION 15	
DEPTH(m)	TEMP(F)	DEPTH(m)	TEMP(F)	DEPTH(m)	TEMP(F)
0.0	63.7	0.0	62.7	0.0	62.7
1.0	63.6	1.0	62.6	1.0	62.1
2.0	62.9	2.0	61.9	2.0	58.9
3.0	60.9	3.0	60.4	3.0	57.0
4.0	57.7	4.0	54.0	4.0	53.8
5.0	57.4	5.0	53.8	5.0	53.3
6.0	55.0	6.0	53.8	6.0	53.1
7.0	54.4			7.0	53.0
				8.0	53.0



APPENDIX 8

Dissolved Oxygen and pH of Receiving Waters

June 29, 1992



DIABLO CANYON POWER PLANT
RECEIVING WATER
DISSOLVED OXYGEN DETERMINATIONS
and Ph MEASUREMENTS

June 29, 1992

On June 29, 1992 seawater samples were collected at six stations in Diablo Cove to determine dissolved oxygen concentrations and pH (Figure 1). Swell was from the northwest at a height of about 2-3 feet. There was light wind during the sampling. Air temperature was approximately 65-70 degrees Fahrenheit.

At each station, surface, mid-depth, and bottom water samples were collected using a hydrocast array of sampling bottles. Samples that were to be later analyzed for dissolved oxygen were preserved with magnesium sulfate and alkaline-azide immediately after collection. Analysis of the samples was conducted at the onsite oceanographic laboratory. Dissolved oxygen concentrations were determined using a modified Winkler titration method, with an accuracy of +0.1 ppm. A pH meter with an accuracy of ± 0.1 units is used to measure pH levels.

Dissolved oxygen values (Table 1) ranged from a high of 8.0 ppm at three depths mid-depth locations to a low of 6.7 at the surface of Station 12. Measured pH values (Table 2) were relatively uniform throughout the water column at all stations, varying between 7.8 and 8.0.

4
9
2



TABLE 1
DIABLO CANYON POWER PLANT
RECEIVING WATER
DISSOLVED OXYGEN DETERMINATIONS

June 29, 1992

Station	Surface	Mid-depth	Bottom
10	7.7	7.8	7.6
11	8.0	8.0	7.8
12	6.7	7.6	7.1
13	7.8	7.7	7.8
14	7.7	7.9	8.0
15	7.8	7.9	7.7

TABLE 2
DIABLO CANYON POWER PLANT
RECEIVING WATER
pH MEASUREMENTS

June 29, 1992

Station	Surface	Mid-depth	Bottom
10	7.8	7.8	7.8
11	7.9	7.9	7.9
12	7.9	7.9	7.9
13	7.9	7.9	7.9
14	7.9	7.9	8.0
15	7.9	7.9	7.9

