

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9411230082 DOC. DATE: 94/11/14 NOTARIZED: YES DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323
 AUTH. NAME AUTHOR AFFILIATION
 RUEGER, G.M. Pacific Gas & Electric Co. *See WCAP-13900, WCAP-14117 & P*
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) *WCAP-13878*

SUBJECT: Forwards LAR 94-11 to Licenses DPR-80 & DPR-82, revising TS 3/4.3.2, "ESFAS Instrumentation." Westinghouse nonproprietary repts WCAP-13900 & WCAP-14117 & proprietary rept WCAP-13878 also encl. Proprietary rept withheld.

DISTRIBUTION CODE: AP01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+470
 TITLE: Proprietary Review Distribution - Pre Operating License & Operating R

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD4-2 LA PETERSON, S	1 3	PD4-2 PD	1 1
INTERNAL:	ACRS OGC/HDS3	6 1	<u>FILE CENTER 01</u>	1 1
EXTERNAL:	NRC PDR	1	<i>NP</i>	

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 14 ENCL ~~12~~

13

AA2

P
R
I
O
R
I
T
Y
D
O
C
U
M
E
N
T



Pacific Gas and Electric Company

77 Beale Street, Room 1451-B14A
San Francisco, CA 94105

Mailing Address

Mail Code B14A
P.O. Box 770000
San Francisco, CA 94177
415/973-4684
Fax 415/973-2313

Gregory M. Rueger
Senior Vice President and
General Manager
Nuclear Power Generation

November 14, 1994



PG&E Letter DCL-94-254

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
License Amendment Request 94-11
Revision of Technical Specification 3/4.3.2 -
Slave Relay Test Frequency Relaxation

Gentlemen:


Enclosed is an application for amendment to Facility Operating License Nos. DPR-80 and DPR-82. The enclosed license amendment request (LAR) proposes a change to Technical Specification (TS) 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," to relax the slave relay test frequency from quarterly to a refueling frequency.

Diablo Canyon Power Plant (DCPP) is the lead plant for relaxation of the slave relay test frequency for the Westinghouse Owners Group. The relaxation of the slave relay test frequency is based on information contained in Westinghouse Electric Corporation (Westinghouse) reports WCAP-13878 (proprietary), "Reliability Assessment of Potter & Brumfield MDR Series Relays," June 1994, WCAP-13900 (nonproprietary), "Extension of Slave Relay Surveillance Test Intervals," April 1994, and WCAP-14117 (nonproprietary), "Reliability Assessment of Potter & Brumfield MDR Series Relays," June 1994.

WCAP-13878 contains information proprietary to Westinghouse. Accordingly, Attachment D to the enclosure includes a Westinghouse Application for Withholding Proprietary Information from Public Disclosure, a Proprietary Information Notice, a Copyright Notice, and an accompanying Affidavit CAW-94-739 signed by Westinghouse, the owner of the information. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission, and it addresses with specificity the considerations listed in paragraph (b)(4) of 10 CFR 2.790 of the Commission's regulations. PG&E requests that the Westinghouse proprietary information be withheld from public disclosure in accordance with 10 CFR 2.790.

9411230082 941114
PDR ADDCK 05000275
PDR

Change: NCC PDR W. Guel. ADD1
1 INP



November 14, 1994

Correspondence regarding the proprietary aspects of the Westinghouse reports listed above, the Copyright Notice, or the supporting affidavit should reference Westinghouse Letter CAW-94-739 and be addressed to N. J. Liparulo, Manager, Nuclear Safety Regulatory and Licensing Activities, Westinghouse Electric Corporation, P.O. Box 355, Pittsburgh, Pennsylvania, 15230-0355.

Although the changes proposed in this LAR are not required to address an immediate safety concern, PG&E plans to implement the requested changes as soon as possible for DCCP Units 1 and 2 to reduce the risk of reactor trips by reducing the number of surveillance tests performed at power. Additionally, the reduction in surveillance testing requirements will save PG&E more than \$100,000 over the life of the plant. Therefore, this LAR should be considered a cost beneficial licensing action. PG&E requests that review and approval of this LAR be given a medium priority. PG&E requests that the revised TS be made effective 30 days after issuance of a license amendment by the NRC.

Sincerely,



Gregory M. Rueger

Enclosure

cc: Edgar Bailey, DHS
L. J. Callan
Mary H. Miller
Kenneth E. Perkins
Sheri R. Peterson (w/enc.) (3)
Diablo Distribution

6688S/PTN/1664

