

CATEGORY 10

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9709090139 DOC.DATE: 97/09/02 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 AUTH.NAME . AUTHOR AFFILIATION
 WOMACK, L.F. Pacific Gas & Electric Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 97-005-01 re RHR sys being outside design basis due to inadequate administrative controls on refueling water storage tank level instrumentation allowed OOS time.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+10
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD4-2 PD	1		1	BLOOM, S	1		1
INTERNAL:	ACRS	1		1	AEOD/SPD/RAB	2		2
	AEOD/SPD/RRAB	1		1	FILE CENTER	1		1
	NRR/DE/ECGB	1		1	NRR/DE/EELB	1		1
	NRR/DE/EMEB	1		1	NRR/DRCH/HHFB	1		1
	NRR/DRCH/HICB	1		1	NRR/DRCH/HOLB	1		1
	NRR/DRCH/HQMB	1		1	NRR/DRPM/PECB	1		1
	NRR/DSSA/SPLB	1		1	NRR/DSSA/SRXB	1		1
	RES/DET/EIB	1		1	RGN4 FILE 01	1		1
EXTERNAL:	L ST LOBBY WARD	1		1	LITCO BRYCE, J H	1		1
	NOAC POORE, W.	1		1	NOAC QUEENER, DS	1		1
	NRC PDR	1		1	NUDOCS FULL TXT	1		1


NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL 25

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



Pacific Gas and Electric Company

245 Market Street, Room 836-N9B
San Francisco, CA 94105

Mailing Address
Mail Code N9B
P.O. Box 770000
San Francisco, CA 94177
415/973-0600 Fax 415/973-6567

Lawrence F. Womack
Vice President
Nuclear Technical Services

September 2, 1997

PG&E Letter DCL-97-139



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Licensee Event Report 1-97-005-01
Residual Heat Removal System Outside Design Basis Due to Inadequate Administrative Controls

Dear Commissioners and Staff:

Pursuant to 10 CFR 50.73(a)(2)(ii)(B), PG&E is submitting the enclosed revision to Licensee Event Report (LER) 1-97-005. This LER reported that the residual heat removal system was outside its design basis due to inadequate administrative controls on the refueling water storage tank level instrumentation allowed out of service time. This revision is being submitted to provide additional information on the analysis of the event.

This condition does not affect the health and safety of the public.

Sincerely,

A handwritten signature in cursive script that reads 'L. Womack for'. The signature is written in black ink.

Lawrence F. Womack

cc: Donald B. Allen
Steven D. Bloom
Ellis W. Merschoff
Kenneth E. Perkins
Diablo Distribution
INPO

Enclosure

dps/2246/NCR N0002020

9709090139 970902
PDR ADOCK 05000275
S PDR



Handwritten notes: 'DE-2-2' and a vertical line with a slash through it.

