

56-275/323

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

PSAR/FSAR AMDT DIST.

TO: Mr. John Stolz

FROM: PG&E  
San Francisco, Ca. 94106  
Phillip A. Crane

DATE OF DOCUMENT  
12/05/77

DATE RECEIVED  
12/07/77

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
1516200

DESCRIPTION  
Furnishing additional information concerning review of the temperature monitoring and recording system proposed for balance-of-plant electrical equipment... w/att description of the proposed system supplementing information dsubmitted in Amend. No. 55...

ENCLOSURE

10 ENCL \* / REPRO BALANCE

1p + 3p

PLANT NAME: DIABLO CANYON UNITS 1 & 2  
jvm 12/07/77

FOR ACTION/INFORMATION

ASSIGNED AD: (LTR)	VASSALLO
BRANCH CHIEF:	STOLZ
PROJECT MANAGER:	ALLISON
LICENSING ASST: (LTR)	HYLTON

INTERNAL DISTRIBUTION


REG FILE	LAINAS
NRC PDR	IPPOLITO
I & E	F. ROSA
OEID (LTR)	GAMMILL (2)
P. COLLINS	VOLLNER (LTR)
HOUSTON	BUNCH
HELTEMES	J. COLLINS
CASE (LTR)	KREGER
MIFC (LTR)	R. KIRKWOOD
KNIGHT (LTR)	
BOSNAK	
SIHWEIL	
PAWLICKI	
ROSS (LTR)	
NOVAK	
ROSZTOCZY	
CHECK	
TEDESCO (LTR)	
BENAROYA	

EXTERNAL DISTRIBUTION

LPDR: SAN LUIS OBISPO Co
TIC
NSIC
ACRS 16 CYS SENT CATEGORY #

CONTROL NUMBER

MA 4  
773410121  
60



PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY  
VICE PRESIDENT AND GENERAL COUNSEL

December 5, 1977

GILBERT L. HARRICK  
GLENN WEST, JR.  
CHARLES W. THIBBELL  
DANIEL E. GIBSON  
JOSEPH I. KELLY  
HOWARD V. GOLUS

EDWARD J. MCGANNEY  
ARTHUR L. HILLMAN, JR.  
ROBERT OHLBACH  
DAN GRAYSON LUSBOCK  
JACK F. FALLIN, JR.

MALCOLM H. FURBUSH  
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN  
PHILIP A. CRANE, JR.  
HENRY J. LAPLANTE  
RICHARD A. CLARKE  
JOHN S. GIBSON  
ASSISTANT GENERAL COUNSEL


JOSHUA BAR-LEV  
ROBERT L. BORDON  
LEIGH B. CASSIDY  
BRIAN B. DENTON  
JOSEPH S. ENGLERT, JR.  
JOHN N. FRYE  
KATHY GRAMM  
PETER W. HANSMEN  
JUAN M. JAYO  
F. RONALD LAUPHEIMER  
MESEK C. LIPSON  
JAMES C. LORSDON  
RICHARD M. MOSS  
ROBERT R. RICKETT  
SHIRLEY A. SANDERSON  
JACK W. SHUCK  
SHIRLEY WOOD

SENIOR COUNSEL

J. PETER BAUMGARTNER  
STEVEN P. BURKE  
BERNARD J. DELLABANTA  
WILLIAM M. EDWARDS  
DONALD ERICKSON  
BARBARA A. GOODE  
ANNETTE GREEN  
ROBERT L. HARRIS  
KERRIT R. KUBITZ  
THEODORE L. LINDBERG, JR.  
RICHARD F. LOCKE  
RICHARD L. MEISS  
DOUGLAS A. OLESBY  
IVON E. SAMSON  
SUS ANN SHIFF  
DAVID J. WILLIAMSON  
FRANCIS WORTHINGTON

Mr. John F. Stolz, Chief  
Light Water Reactors Branch No. 1  
Division of Project Management  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Docket No. 50-275-OL  
Docket No. 50-323-OL  
Diablo Canyon Units 1 & 2



Dear Mr. Stolz:

In support of our operating license application this letter and Attachment A provide additional information to the Staff for its review of the temperature monitoring and recording system proposed for balance-of-plant electrical equipment. The description of the proposed system in Attachment A supplements information submitted in Amendment No. 55.

The following procedures will also be instituted for the system:

1. Complete time history records of overtemperature occurrences will be maintained.
2. Each such occurrence will be reported.
3. An evaluation will be provided for each such occurrence to demonstrate the continued acceptability of the affected equipment.

This system, as described, will be installed and operational prior to loading fuel and a statement to this effect will be added to the FSAR. All components utilized in the temperature monitoring system will be of high quality, with power supplied from a reliable, safety-grade bus. The system will be capable of being tested at various points including the sensor and the plant operator alarm.

Very truly yours,

*Philip A. Crane, Jr.*

Enclosures (10)  
CC w/enc.: Service List

773410121

REGISTRY BOOKLET THE COPY

ATTACHMENT A  
TEMPERATURE MONITORING SYSTEM FOR ELECTRICAL EQUIPMENT

A temperature monitoring system shall be installed which shall measure the ambient air temperature in spaces containing Class I electrical equipment. The monitoring system shall sense the ambient air temperature and alert the plant operator if it exceeds some preset value. This value shall be based on the operating limits of the equipment.


In addition to providing a high temperature alarm, the monitoring system shall periodically record (at approximately 5-minute intervals) the ambient temperature of any and all spaces where the temperature exceeds the present value mentioned above.

Due to limited space in the main control room, the recorders will be mounted remotely. The recorder for the pump rooms will be located adjacent to the auxiliary building control board. This location is nearly always attended and is located nearer the pump rooms than the control room.

The recorder for the electrical equipment spaces will be located in the cable spreading room, which is just below the control room. This location is between the control room and the majority of the electrical equipment spaces.

The criteria for monitoring air temperature are given below:


- (1) Where only one class 1E redundant train or division of safety related balance of plant electrical equipment is in a given room or area and the ventilation there is neither redundant nor class 1E, the ambient air temperature monitoring system will be redundant and of a grade meeting class 1E criteria of supply and separation.



- (2) Where only one class 1E redundant train or division is in a given room or area and the ventilation is class 1E, but is not redundant within the area, then one temperature monitor of a grade meeting class 1E criteria of supply and separation will be placed in the area.
- (3) Where one or more class 1E redundant trains or divisions are in a given room or area and the ventilation is class 1E and redundant, then one non-redundant temperature monitor will be supplied.

Temperature monitors shall be arranged as follows:

<u>Monitor/Recorder A</u> (In Cable Spreading Room)	<u>Monitor/Recorder B</u> (At auxiliary building control board)
480V bus F	RHR Pump 11
480V bus G	RHR Pump 12
480V bus H	Spray Pumps
Battery Room 11	Charging Pumps 11 & 12
Battery Room 12	Charging Pump 13
Battery Room 13	CCW Pump 11
DC Equipment Room 11	CCW Pump 12
DC Equipment Room 12	CCW Pump 13
DC Equipment Room 13	SI Pump 11
Diesel Generator 11	SI Pump 12
Diesel Generator 12	Aux. F.W. Pumps
Diesel Generator 13	Battery Room 11
4kV bus F	Battery Room 12
4kV bus G	Battery Room 13
4kV bus H	Cable Spreading Room
Cable Spreading Room	





The Auxiliary Salt Water Pumps shall have individual thermostatically controlled recorders.

The monitoring system is not Design Class I, however, high quality components shall be utilized. The system will be testable. In addition, quality assurance procedures shall be employed in design, procurement and installation. All conductors shall be routed in seismically qualified raceways. Circuit routing shall be verified using existing computer checks. Installation data shall be returned to engineering for record keeping.

