

C06/13/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-275/323

REC: STOLZ J F
NRC

ORG: CRANE P A
PACIFIC GAS & ELEC

DOCDATE: 06/06/78
DATE RCVD: 06/12/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 40

FURNISHING INFO RE ACCEPTABILITY OF THE USE OF CASE EPOXY IN ELEC
PENETRATIONS...W/ATT SUPPORTING INFO.

PLANT NAME: DIABLO CANYON - UNIT 1
DIABLO CANYON - UNIT 2

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL: *al*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

J HANCHETT W/1 CY ALL MATERIAL
F HEBDON W/1 CY ALL SAFETY MATERIAL

PSAR/FSAR AMDTS AND RELATED CORRESPONDENCE
(DISTRIBUTION CODE B001)

FOR ACTION: ASST DIR VASSALLO**LTR ONLY
PROJ MGR ALLISON**W/ENCL

BR CHIEF LWR#1 BC**LTR ONLY
LIC ASST HYLTON**LTR ONLY

INTERNAL: REG FILE**W/ENCL
I & E**W/2 ENCL
OPERATOR LIC BR**W/ENCL
QAB**W/ENCL
MIPC**LTR ONLY
MECH ENG BR**W/ENCL
MATERIAL ENG BR**W/2 ENCL
REACTOR SYSTEMS BR**W/ENCL
CORE PERFORMANCE BR**W/ENCL
AUXILIARY SYS BR**W/ENCL
I & C SYSTEMS BR**W/ENCL
AD FOR SITE TECH**W/4 ENCL
ACCIDENT ANALYSIS**W/ENCL
RAD ASSESSMENT BR**W/ENCL

NRC PDR**W/ENCL
OELD**LTR ONLY
EMERGENCY PLAN BR**W/ENCL
CASE**LTR ONLY
AD FOR ENG**LTR ONLY
STRUCTURAL ENG BR**W/ENCL
AD FOR REAC SFTY**LTR ONLY
ANALYSIS BR**W/ENCL
AD FOR PLANT SYSTEMS**LTR ONLY
CONTAINMENT SYSTEMS**W/ENCL
POWER SYS BR**W/ENCL
AD FOR SITE ANLYS**LTR ONLY
EFFLUENT TREAT SYS**W/ENCL
KIRKWOOD**W/ENCL

EXTERNAL: LPDR'S
SAN LUIS OBISPO, CA**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT A**W/16 ENCL

MAH

DISTRIBUTION: LTR 56 ENCL 46
SIZE: 1P+1P

CONTROL NBR: 781640016

***** THE END *****

GP

REGULATORY DOCKET FILE COPY

PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY
VICE PRESIDENT AND GENERAL COUNSEL

June 6, 1978

GILBERT L. MARRICK
GLENN WEST, JR.
DAN GRAYSON LUSBOCK
JACK F. FALLIN, JR.

EDWARD J. MCDANNEY
DANIEL S. GIBSON
JOSEPH I. KELLY
HOWARD V. ODLUM
SENIOR COUNSEL

MALCOLM H. FURBUSH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
RICHARD A. CLARKE
JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.
ROBERT OHLBACH
CHARLES W. THISSELL
ASSISTANT GENERAL COUNSEL

JOSHUA BAR-LEV
ROBERT L. BORDON
LEIGH S. CASSIDY
BERNARD J. DELLASANTA
WILLIAM M. EDWARDS
JOSEPH S. ENGLERT, JR.
JOHN N. FAYE
PATRICK G. GILDEN
PETER W. HANSEN
JUAN M. JAYO
F. RONALD LAUFHEIMER
MEREK C. LIPSON
JAMES C. LOBSON
ROBERT S. MCLENNAN
RICHARD M. MOSS
ROGER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JACK W. SHUCK
SHIRLEY A. WOO

J. PETER BAUMGARTNER
STEVEN P. BURKE
PAMELA CHAPPELLE
BRIAN S. DENTON
GARY P. ENGINAS
DONALD ERICKSON
DAVID C. GILBERT
ANNETTE GREEN
ROBERT L. HARRIS
KERMIT R. KUBITZ
THEODORE L. LINDBERG, JR.
RICHARD P. LOCKE
HARRY W. LONG, JR.
RICHARD L. MEISS
DOUGLAS A. OILSEBY
J. MICHAEL REIDENBACH
IVOR E. SAMSON
SUE ANN LEVIN SCHIFF
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275-OL
Docket No. 50-323-OL
Diablo Canyon Units 1 and 2

Dear Mr. Stolz:

The following information is provided to address Staff concerns regarding the acceptability of the use of case epoxy in electrical penetrations.

The epoxy used in the cannister type electrical penetration seals was tested extensively to verify suitability for use in this application. Electrical insulating resistance tests were run over an extended period of time with resistance measured at 500 and 1000 volts. The results of this test are shown in the attachment identified as EPAQ-037. Forty copies of this test are enclosed with this letter. The attachment is a summary report and additional details are available for review at General Electric's design record file. In addition to the actual component level testing of the epoxy, a qualification test of the cannister type electrical penetration seal assembly was performed to verify suitability of epoxy to perform in a LOCA environment.

The extensive testing discussed above coupled with the fact that the type of penetration used at Diablo Canyon has been in service at operating reactors since 1969 demonstrates the suitability of the design of the equipment for the intended use.

Five copies of this submittal have been sent directly to Mr. Dennis Allison.

Kindly acknowledge receipt of the above material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,


Philip A. Crane

781640016

Attachment
CC w/attachment: Service List

RECEIVED
GENERAL SERVICES
MAY 12 1978

Boo 1/1404



REACTOR INSTRUMENTATION AND CONTROL



Attachment

TITLE: Epoxy Insulation Resistance Test -- Test #EPAQ-037

PRODUCT: Cast Epoxy Insulating Compounds

OBJECTIVE: Verify the vacuum cast epoxy can withstand a long term high humidity environment.

DESCRIPTION: Ten different epoxy formulations were tested. Fifty samples were made with electrodes cast in the epoxy. The samples were inserted in glass tubes which had water at the bottom of the tube. The tube was heated for the duration of the test to keep the relative humidity limits high.

Insulation resistance measured periodically at 500 and 1000 volts test voltage.

Relative humidity: approximately 100%

Duration: 19 months

RESULTS:

- (1) Three epoxy formulations broke down after six weeks exposure (epoxy became soft).
- (2) All other samples remained intact, some exhibiting a slight loss in hardness from Shore D 55 down to Shore D 25.
- (3) Insulation resistance levels: 1×10^{11} ohm-cm (except for formulations that broke down).

Results indicate the vacuum cast epoxy used in the penetration assemblies can withstand the long term effects of high humidity and still maintain insulation resistance levels which allow operation of electrical circuits.

DATE: 2/67

LOCATION: GE, Nuclear Instrumentation Department, San Jose, Calif.

CONDUCTED BY: GE, Nuclear Instrumentation Department, San Jose, Calif.

