

Kenneth B. Kilbourne

Post Office Box 813
1548 Lisa Street
Carpinteria, Calif. 93013



January 26, 1973

50-275
50-323

Directorate of Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545

Reference: Comments on Draft Environmental Statement
Dockets #50275 and #50323

Gentlemen:

The enclosed comments are directed to some of the more basic shortcomings in the Diablo installation. The comments are not inclusive in that time did not permit discussion of some areas which seem to need more muscle.

As a senior member of the American Society for Quality Control, with extensive experience in this field, and as the president of a small industrial manufacturing company, it is almost unbelievable that your report doesn't delve further into reliability and quality assurance. I am left with the impression that priorities may be mixed.

Very truly yours,


K. B. Kilbourne

KK:ho

Encl.

842
KW



24

[Faint, illegible text scattered across the page, possibly bleed-through from the reverse side.]

Kenneth B. Kilbourne

Post Office Box 813
1548 Lisa Street
Carpinteria, Calif. 93013

COMMENTS ON THE DRAFT ENVIRONMENTAL STATEMENT
BY THE DIRECTORATE OF LICENSING, UNITED STATES
ATOMIC ENERGY COMMISSION

DIABLO CANYON UNITS #1 AND #2
PACIFIC GAS AND ELECTRIC COMPANY

Submitted to:

Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

Docket Nos. 50275 and 50-323

Submitted by:

K. B. Kilbourne

January 26, 1973

K B Kilbourne



11

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

CONTENTS

GENERAL

NORMAL PLANT OPERATIONS

Primary and Secondary Cooling Systems

Effluent Discharge System

Offshore Discharge Line

Environmental Effects

CONSIDERATION OF PLANT FAILURES

Probability of Failure

Safety Considerations

CONCLUSIONS



THE
OFFICE OF THE
ATTORNEY GENERAL
STATE OF TEXAS
DALLAS, TEXAS

GENERAL

These comments on the draft environmental statement are concerned with the following:

1. Are the definitions of normal plant operation reasonable?
2. Are the possibilities of plant failures properly considered?

NORMAL PLANT OPERATIONS

The extent to which the power reactor conforms to the normal operations defined in the draft environmental statement will determine adverse environmental effects. In the short term, adverse effects may be mitigated. However, the long term, cumulative effects of "acceptable" levels of radioactive and other contamination that the plant will release are not well known. Anything other than trivial departure from the defined operating conditions could be serious and destructive in the short term, or the long term, or both.

The plant design, equipment and proposed controls are not sufficiently detailed in the draft report so that they may be evaluated. Consequently, these comments are not intended to judge whether the plant is safe or unsafe. At the same time, it should be noted that the limited description of the primary and secondary cooling systems, the proposed effluent discharge system, and the environmental evaluation of effects can in no way be considered confidence builders.



10

[Faint, illegible text scattered across the page, possibly bleed-through from the reverse side.]

Primary and Secondary Cooling Systems The draft

leads to the following conclusions:

1. There is no redundant cooling for the primary system, and presumably such is impossible, not feasible or uneconomic.

2. While the primary and secondary cooling systems are independent, radioactive and other contamination is possible between them. No radioactive or chemical inspection is provided from the turbine condenser.

3. The primary cooling liquid, after processing through the radioactive waste system, dumps into the secondary cooling system discharge line. There is no indication how this operates under emergency conditions.

4. Radiation monitoring is not operationally defined in the draft statement. It is not apparent whether radiation monitoring is informational sampling or provides to shut-down discrepant effluent flow, and in such cases, how rapidly the system will respond.

5. Chemical sampling of effluent will be after the fact (after discharge) and not from the discharge conduit, or at the radiation monitor stations.

Effluent Discharge System Outside of control of effluent from the turbine condenser, the steam generator blow-down tank, the boron recycle system and the waste disposal system, the environmental impact will depend upon the heat level of the discharge and various assumptions as to the characteristics of the discharge plume.



Draft report data and its interpretation on the discharge plume is unconvincing, theoretical and speculative. The size and shape of the cove, the average depth of sixteen (16) feet, the discharge velocity and turbulence and the discharge volume (five acre feet per minute) makes the data improbable. Other variables as wave and tidal action, the contour of the cove bottom, offshore and eddy currents, proximity to the South cove inlet, and variation in weather conditions raise real doubts that the discharge plume will in any respect approximate the geometrical form in the draft.

The discharge plume is more likely to encompass the entire cove and to tilt southerly to South cove most of the time. The temperature rise and level of contamination will necessarily, then, be a function of the daily temperature of the water in the cove, the temperature and volume of the discharge, the rate of change of water in the cove, and the heat dissipation to the ocean and to the atmosphere.

To assume that no substantial part of the plume will recirculate through South cove, and thereby changing temperature and contamination estimates, is sheer optimism.

The draft claims a two-fold dilution in 8 acres of water with an average depth of less than 16 feet. Using 16 feet for depth, eight acres is 128 acre feet of seawater. The discharge from two power reactors will equal 128 acre feet in twenty four minutes. While the dilution may be two-fold



11

[The main body of the page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.]

the first hour, it will be substantially less for succeeding hours...unless it can be established that a hundred (100) percent change of water occurs in the eight (8) acres every half hour...a very unlikely occurrence.

Offshore Discharge Line An offshore discharge line into the ocean rather than discharging into the cove was lightly considered and rejected. The arguments against appeared to be basically cost and not environmental. Loss of kelp and abalone and other adverse effects on the marine biota were accepted. Evaluation of the discharge plume data was uncritical or not accomplished, and comparisons between the proposed plant and one with an offshore discharge are not valid except for cost differences.

Environmental Effects The actual characteristic of the discharge plume and the percentage of effluent recirculated through the secondary cooling system will lead to a significantly higher water temperature and more contamination in Diablo cove than the draft report indicates. Marine biota will disappear from the cove, except for a few hardy survivors and some migrants that can stand the cold water between their home and this heated paradise. Requiring an offshore discharge line would eliminate these adverse effects.

CONSIDERATION OF PLANT FAILURES

Probability of Failure Section 7 of the draft

statement discusses environmental impact of postulated accidents (failures). However, it gives no information as to what is meant by "probability of occurrence." Reference is made to "low" and "high" occurrence rates without explaining what "low" and "high" is in numerical data and how it was obtained. Lacking such data, it must be assumed that "probability of occurrence" refers to engineering value judgements and not to statistically determined probabilities with appropriate confidence limits. As such, the conclusions of Section 7 may or may not be correct and have very limited value in evaluating the environmental impact of the reactor plant.

From a system standpoint there may be no available meaningful and reliable data which can be used to predict probability of failure. Treating all operating water cooled power reactors as a universe from which to draw probability data, or citing a no failure record on this basis, would be a specious and questionable procedure. In any case, with 28 power reactors in operation since the first went on stream in New Jersey in 1963, 52 under construction and some 70 on order, there simply are not enough facilities (too small a sample) upon which to establish a valid probability of failure from a system standpoint.

As the oil companies discovered with their platforms (a simple, safe technology compared to reactor plants) it is unrealistic and incredible to predict no failures

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

Furthermore, it is noted that the records should be kept in a secure and accessible format. Regular backups are recommended to prevent data loss in the event of a system failure or disaster.

In addition, the document highlights the need for a clear and consistent naming convention for all files and folders. This helps in organizing the data and makes it easier to locate specific information when needed.

It is also advised to limit the number of users who have access to the system. Only authorized personnel should be able to view or modify the records to maintain data integrity and confidentiality.

The second part of the document provides a detailed overview of the system's architecture. It describes the various components that make up the system, including the database, the application layer, and the user interface.

The database is designed to store all the transaction data in a structured and efficient manner. It is optimized for fast retrieval and supports complex queries. The application layer handles the logic of the system, ensuring that all operations are performed correctly.

The user interface is designed to be intuitive and easy to use. It provides a clear view of the data and allows users to perform all necessary operations. The system is also designed to be scalable, allowing it to handle a growing number of users and transactions.

Finally, the document concludes by stating that the system is designed to be secure and reliable. It includes various security measures to protect the data from unauthorized access and ensure that it is always available when needed.

where men, materials and machines are involved. The probability of minor and major failures exists, but objective measure of the level of probability does not. It can be assumed, however, that potential failure will increase with the number of plants constructed and their years of operation. A major failure in a water cooled reactor is more certain than uncertain, and the questions are mostly where, when and the consequences.

The draft statement does not deal adequately with the matter of failure, in particular the consequences and appropriate corrective action. A similar glaring omission is the lack of any description of the quality assurance program for operation of the plant.

Safety Considerations Section 7 of the draft refers to the staff's Safety Evaluations dated January 23, 1968 and November 18, 1969 and eight categories ranging from trivial to major postulated accidents.

No mention is made, or discussion of, AEC publication, "Water Reactor Safety Program Plan," (1970), which outlines 139 safety questions with water cooled power reactors, 44 of which are considered "very urgent, key problem areas, the solution of which would clearly have great impact, either directly or indirectly, on a major critical aspect of reactor safety."

Many of these 139 safety questions, including the 44 urgent and critical safety questions, remain unsolved. This report with appropriate response should be



incorporated in the environmental statement.

Table 7.2, Summary of Radiological Consequences of Postulated Accidents, lists under Class 8.1 loss-of-coolant accidents with an estimated dose to population in 50-mile radius of 120 man-rems. The draft states, "The probability of occurrence of large Class 8 accidents is very small."

The environmental statement should include a statement of the consequences and the corrective action for Class 8 accidents, particularly when it is considered that other doses listed in the table range from 0.1 to 12 man-rems.

CONCLUSION

The draft environmental statement is not adequate to properly evaluate the environmental impact of Diablo Canyon power reactors #1 and #2.

The definitions of normal plant operation are not reasonable. The possibilities of plant failures have not been sufficiently considered.