

PACIFIC GAS AND ELECTRIC COMPANY
DESIGN CALCULATION COVER SHEET

Procedure No. 3.3
Attachment A
Page 1 of 1

File No. : 140.061
Calculation No.: M-320

☐ Preliminary ☒ Final

Project: Diablo Canyon Date: 1/9/91
Engineering Discipline: NECS-ME

Structure, System or Component:
Component Cooling Water System

Type or Purpose of Calculation: Max AP across air + motor operated valves in the CCW system.

No. of Sheets: _____

Computer Program Name	:	_____	Version	:	_____
PC Model	:	_____	Serial No.	:	_____
Hard Disk File Name	:	_____	Date of Last	:	_____
(If Applicable)	:	_____	File Change	:	_____
Floppy Diskette Control No.	:	_____	Date of Last	:	_____
(If Applicable)	:	_____	Validation	:	_____

Signature

Discipline/Dept.

Date

PREPARER
CHECKER

*Check Method: _____

APPROVAL

Discipline Engineer
(if required)

GROUP SUPERVISOR

For civil calculation, enter the registered engineer's stamp or seal and expiration date of certificate or authority in this space.

For other calculation, enter the registered engineer's full name and registration number, or stamp, or seal in this space:

Large 2 and 7.220
ME 17,526 3.31.00
Gry O. Williams

RECORDS OF REVISIONS

Revision	Date	Reasons for Revision	Rev. By	Checked By	*Check Method	Approval
RMS						
INDEXED	1/10/91	Revise Sh. 1, 2, 5, 7, 8	U6H	AVZ	B	1/15/91
INDEXED	7/31/91	Revise Sh. 1, 2, 7, 12	U6H	AVZ	B	8/1/91
		Add Sh. A, 2A				
5	2.10.97	See Sheet i	ESB	U6H	B	4/7/97

- *A - Alternate Calculation (Note added pages)
- B - Detailed Check
- C - Critical Point Check

11 - 9/1/89

9807200120 980709
PDR ADDOCK 05000275
PDR

Subject CCW Valves dP Maximum

Made By K. Smith-Ratchford Date 12/10/96 Checked By J. Schimmels

Date 1-22-97

REVISION 5

PURPOSE: This calculation has been reviewed for impact on its conclusions as a result of the maximum allowable post-accident CCW supply temperature increase (Ref. 1). The intent of this calculation is to determine maximum dP across CCW system control valves.

EVALUATION OF IMPACT: The section of this calculation affected by the design bases temperature change is Section 3A "Valving in or Valving Out the Idle CCW Heat Exchanger When One CCW HX Is In-Service", which takes into consideration frictional losses in the piping between the pump discharge and outlet of the CCW heat exchanger. The temperatures used were:

after the CCW HX	132 F
before the CCW HX	188 F

As a result of the change in the maximum allowable peak CCW temperature to 140 F and more recent accident analyses evaluations on the CCW (refer to Calc M-305, Rev 9, App B), the maximum temperatures are:

before the CCW HX	~ 239 F
after the CCW HX	~ 140 F

The increase in temperatures would affect the density of the CCW (lowering the value by approx. 2% from the value used in the calculation for frictional losses upstream of the CCW HX and less than 0.05% on the downstream). The lower density value will result in a slightly higher friction factor, and thus frictional losses; however, the impacts on frictional losses are negligible and the impacts on the upstream and downstream side of the HX almost completely cancel each other out when determining the overall differential pressure. (Reference Crane Technical Paper 410, Eqn: 3-5)

CONCLUSION: There is no impact on Sections 1 and 2, since they do not take into consideration frictional losses in determining dP. For section 3, it has been determined to that the change in CCW system maximum design bases temperature will have an insignificant impact on the calculated frictional losses, since the value used has significant margin over the value calculated. Thus, the value of 20 psid for the FCV-430 and 431 remains conservative.

References: 1) DCP M-49291
2) Calculation M-305, R9, App B

THE UNIVERSITY OF CHICAGO



PACIFIC GAS AND ELECTRIC COMPANY
DESIGN CALCULATION COVER SHEET

File No. 140.061

Calculation No. 14-320

Project DIABLO CANYON UNIT 1 Date 3/23/83

Engineering Discipline M&E

Structure, System, or Component CCW SYSTEM

Type of or Purpose of Design Calculations MAX DP ACROSS
AIR OPERATED & MOTOR OPERATED
VALVES

No. of Sheets 23 + 4 ATTS.

SAR Change Required ☐ Yes ☒ No
(Nuclear Projects only)

	Signature	Discipline/Dept.	Date
Preparer	<u>CEW</u>	<u>M&E</u>	<u>3/23/83</u>
Checker	<u>[Signature]</u>	<u>M&E</u>	<u>3/30/83</u>
Approval:			
Discipline Engineer (if required)	<u>CEW</u>	<u>M&E</u>	<u>6/13/83</u>
Group Leader/Supervisor	<u>George Tibbels</u>	<u>M&E</u>	<u>6-14-83</u>

Record of Revisions

RMS
INDEXED
RMS ->
INDEXED ->

Rev. No.	Date	Reason for Revision	Rev. by	Checked by	Approval Engr.	GL/Supr.	Check Method
0	6-14-83	FINAL	CEW	[Signature]		[Signature]	
1	8-14-83	ADD PP 3, 17, 18, 19, 20, 21. CHANGE P. 1, 2. REJUNGEZ ORDER P. 2.	CEW	[Signature]	CEW	[Signature]	
2	7/10/85	REVISE 34 2, 113, 16, 7	CEW	[Signature]		[Signature]	D

A = ALT. CALC.
C = CRITICAL CHECK
D = DETAILED CHECK



SUBJECT CCW Valves ΔP_{max}

MADE BY D. Howland DATE 6/17/91 CHECKED BY SN Sathur DATE 7/11/91

Rev. 4

This Rev. was done to update the required closing ΔP_{max} for valves in the CCW system. Two new pages, A and 2A, were added for clarification. The maximum ΔP for closing the RCP L.O. + reactor vessel support cooler, and the excess letdown heat exchanger return containment isolation valves were revised. Thermal expansion due to inadvertent heat loading, and back leakage through check valves was considered for the above valves. The revision 4 version of M-320 will be used as a basis for the 89-10 generic letter valve ΔP calculations.

Sheets 1, 2, 7, and 12 were revised.

Note: Calculation M-573 (Unit 2 equivalent of M-320) establishes that the results of M-320 are applicable to Unit 2 due to the similarities between the Unit 1 and Unit 2 CCW systems. Any changes to M-320 should be checked against the conclusions in M-575 for possible impacts.



DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 1 OF 23
CALC. NO. M-320
REV. NO. 134

SUBJECT CCW VALVES ΔP_{max}

MADE BY C. W. Dand DATE 3/23/83 CHECKED BY SMW DATE 3/30/83 JOB NO. 15320

A. C. W. Dand 7/1/83
A. D. H. Dand 1/9/91
A. D. H. Dand 6/24/91

SMW 7/1/83
SMW 1/9/91
SMW 7/1/91

PROBLEM: TO DETERMINE THE MAXIMUM ΔP AIR
OPERATED & MOTOR OPERATED VALVES IN
THE CCW SYSTEM MUST OPEN AGAINST
AND CLOSE AGAINST.

ASSUMPTIONS:

1. CCW SURGE TANK IS VENTED TO ATMOSPHERE.
2. CCW SURGE TANK IS @ LOW LEVEL.
3. Isolated lines inside containment ARE @ RV LIFT PRESSURE
DUE TO THERMAL EXPANSION OF FLUID IN THE PIPE.
4. SOURCES OF MAKE-UP WATER TO CCW SYSTEM ARE
AT HIGH LEVEL (OVERFLOW), EXCEPT RAW WATER RESERVOIR (SEE
SECTION 3 A i)
5. PUMPS WHICH TRANSFER WATER TO CCW SYSTEM ARE
AT SHUT-OFF HEAD
6. MAX ΔP FOR VALVES IN CCW SYSTEM, EXCEPT ISOLATION
VALVES FOR CONTAINMENT (SEE ASSUMPTION 3) IS DUE
TO CCW P_s SHUT-OFF HEAD, AND CCW HX DISCHARGE
VALVES FCV-430 & 431 (SEE ASSUMPTION 9)
7. MAKE-UP WATER FLOW FROM RAW WATER STORAGE
RESERVOIRS TO CCW SURGE TANK IS GRAVITY FED.
8. RETURN HEADER PIPING IS AT STATIC PRESSURE DUE TO
THE SURGE TANK FOR CONSIDERATION OF ISOLATED
PIPING INSIDE CONTAINMENT.
9. OPERATION OF CCW HX DISCHARGE VALVES, FCV-430 & FCV-431,
CAN BE EITHER AGAINST SHUT-OFF HEAD OF CCW P_s OR
AGAINST PRESSURE DIFFERENTIAL ASSOCIATED WITH VALVING IN
OR OUT THE SECOND CCW HX W/ ONE CCW HX IN SERVICE.



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 2 OF 23

CALC. NO. M-320

REV. NO. 1 2/34

PROJECT CCW VALVES AP

MADE BY CE Ward DATE 3/23/83 CHECKED BY JM DATE 3/30/83 JOB NO. 15320

REFERENCES:
 1. CE Ward 7/1/83
 2. CE Ward 7/16/84

1. JME 7/18/83
 2. SNS 7/20/84
 3. JRE 1/9/91
 4. JN 7/11/91

1. P&ID 102014, REV 11
2. DC-663213-37-1
3. MEMO FROM TNCRAWFORD TO EC CONTELL, 3/9/83, CRON 14430
4. PG&E DWG 53093, REV 15, SHEET 57
5. PG&E DWG 101938, REV 1
6. P&ID 102016, REV 10
7. PG&E DWG 438038, REV 6 ; 7a PG&E DWG 500090, REV 13
8. PG&E DWG 438039, REV 4
9. DC-663062-39-1
10. DC-663062-22-1
11. MW KELLOGG DWG 19322, REV B
12. MW KELLOGG DWG 19323, REV B
13. MW KELLOGG DWG 19320, REV B
14. MW KELLOGG DWG 19321, REV B
15. MW KELLOGG DWG 1927, REV NOT GIVEN, 10/5/72
16. MW KELLOGG DWG 1443, REV A

17. PG&E DWG 438148, REV 6
 CONCLUSIONS: SEE NEXT PAGE FOR ADDITIONAL REFERENCES

1. MAX DP FOR ALL VALVES IN CCW SYSTEM, EXCLUDING MAKE UP VALVES, LCV 69 & LCV 70 & CONTAINMENT ISOLATION VALVES IS 81 psid

2. MAX DP FOR CCW SYSTEM MAKE UP VALVES LCV 69 & LCV-70 IS 380 ft (OR 165 psid)

3. i) MAX DP FOR CLOSED CONTAINMENT ISOLATION VALVES (i.e. TO OPEN THE VALVES) IS:

- a) FOR RCP L.O. & REACTOR VESSEL SUPPORT CLRS = 124 psid (INCLUDES INLET VALVE TO CONTAINMENT)
- b) FOR RCP THERMAL BARRIERS = 2453 psid
- c) FOR EXCESS LETDOWN Lx = 123 psid

100-100000

100-100000

100-100000





SUBJECT CCW Valves ΔP_{max}

MADE BY D. Howland DATE 6/26/91 CHECKED BY [Signature] DATE 7/11/91

3. i) Maximum ΔP for closed containment isolation valves (i.e. to open the valves) is:

- a) For RCP L.O. & reactor vessel support coolers = 124 psid (FCV-363, FCV-749) (excluding inlet valve to containment)
- b) For RCP Thermal barriers = 2458 psid (FCV-357, 755)
- c) For excess letdown hx = 123 psid (FCV-361)
- d) The inlet valve for RCP L.O. & reactor vessel support cooler = 81 psid* (FCV-356)

* A higher opening ΔP of 124 psid could occur if the CCW pumps are all shut down with the relief valves lifted in the lines downstream of FCV-356. The maximum credible ΔP is still 81 psid since there are always a minimum of 2 CCW pumps operating and there is no reason to open FCV-356 if the CCW pumps are not operating.

ii) Maximum ΔP for open containment isolation valves (i.e. to close the valves) is:

- a) To close the RCP L.O. & reactor vessel support coolers = 124 psid (FCV-363, FCV-749)
- b) To close the RCP Thermal barriers = 2458 psid (FCV-357, 755)
- c) To close the excess letdown heat exchanger = 123 psid (FCV-361)
- d) To close the inlet valve for RCP L.O. & reactor vessel support cooler = 81 psid (FCV-356)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 3 OF 23

CALC. NO. M-320

REV. NO. 1

SUBJECT CCW VALVES ΔP_{max}

MADE BY Δ CEward DATE 7/1/83 CHECKED BY Δ JML DATE 7/12/83 JOB NO. 15320

Δ CONCLUSIONS (CONT'D):

4. MAX ΔP FOR FCV-430 & FCV 431, WHEN VALVING IN OR OUT THE SECOND CCW HX W/ ONE ALREADY IN SERVICE, IS 20 psid

Δ REFERENCES (CONT'D):

18. CALCULATION M-299, REV 0
19. CALCULATION M-390, REV 0
20. VENDOR PRINT DC-663212-26-1
21. CALCULATION M-305, REV 2
22. CRANE TECHNICAL PAPER #410, 19th PRINTING, 1980
23. PAGE DWG 449316, REV 1

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 4 OF 23


CALC. NO. M-320


REV. NO. 0

SUBJECT CCW VALVES DP_{max}

MADE BY CEWand DATE 3/23/87 CHECKED BY JNN DATE 3/30/87 JOB NO. 15320

SOLUTION:





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 5 OF 23
CALC. NO. M-320
REV. NO. 03

PROJECT CCW VALVES

MADE BY CE Ward DATE 3/23/83 CHECKED BY ZNN DATE 3/30/83 JOB NO. 15320

1/7/91

3/11/91

1. VALVES OUTSIDE CONTAINMENT (EXCLUDING SURGE TANK MAKE-UP WATER VALVES AND CONTAINMENT ISOLATION VALVES)

AS SHOWN IN THE BASIC ARRANGEMENT DRAWING, CCW SURGE TANK STATIC HEAD IS TRANSMITTED TO BOTH SIDES OF ALL VALVES OUTSIDE CONTAINMENT - WHETHER THESE VALVES ARE OPEN OR CLOSED.

HENCE, THE MAXIMUM DP ACROSS THESE VALVES IS DETERMINED AS FOLLOWS:

- i) PRESSURE @ PUMP DISCHARGE, P_{PD} IS GIVEN BY THE FOLLOWING (ASSUMING PUMPS ARE @ SHUT-OFF HEAD):

$$P_{PD} + Z_{PD} = P_{PS} + Z_{PS} + TDH_{SO} \quad (\text{GENERAL EQN.})$$

WHERE Z_{PD} = ELEVATION @ PUMP DISCHARGE

Z_{PS} = ELEVATION @ PUMP SUCTION

P_{PS} = SUCTION PRESSURE @ PUMP

TDH_{SO} = PUMP SHUT-OFF HEAD


P_{PS} = ELEVATION OF SURGE TANK WATER LEVEL, Z_{ST} , LESS THE ELEVATION @ PP SUCTION, Z_{PPS}

UNITED STATES OF AMERICA
DEPARTMENT OF JUSTICE

THOMAS M. COOPER
ATTORNEY AT LAW

1964





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 6 OF 23
CALC. NO. M-320
REV. NO. 0

SUBJECT COW VALVES ΔP_{max}

MADE BY CE Ward DATE 3/23/83 CHECKED BY EMK DATE 3/30/83 JOB NO. 15320

$$\text{SO, } P_{ppl} = z_{st} - z_{pps} + z_{pps} - TDH_{so} - z_{ppl}$$

$$\text{OR } P_{ppl} = TDH_{so} + z_{st} - z_{ppl}$$

ii) @ ANY VALVE, MAX ΔP IS DUE TO SHUT-OFF HEAD OF PUMP. (BY ASSUMPTION.)

AT THE UPSTREAM SIDE OF THE VALVE, THE PRESSURE, P_v , IS GIVEN BY

$$P_v + z_v = P_{ppl} + z_{ppl} \quad (\text{ENERGY EQ'N})$$

SUBSTITUTING FOR P_{ppl} YIELDS

$$P_v + z_v = TDH_{so} + (z_{st} - z_{ppl}) + (z_{ppl})$$

$$\text{OR } P_v = TDH_{so} + z_{st} - z_v$$

AT THE DOWNSTREAM SIDE OF THE VALVE, THE PRESSURE, P_v , IS GIVEN BY

$$P_v + z_v = P_{pps} + z_{pps} \quad (\text{ENERGY EQ'N})$$

$$z_v = z_v$$

$$P_{pps} = z_{st} - z_{pps} \quad (\text{FROM PART 1, i})$$

$$\text{SO } P_v + z_v = z_{st} - z_{pps} + z_{pps}$$

SECRET
CONFIDENTIAL

SECRET
CONFIDENTIAL

SECRET
CONFIDENTIAL





DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 7 OF 23

CALC. NO. M-320

REV. NO. 234

SUBJECT CCW VALVES - ΔP_{max}

MADE BY Ceward DATE 3/23/83 CHECKED BY JH DATE 7/20/83 JOB NO. 15320

Δ Ceward 7/14/84
 Δ D. Howland 1/4/91 OR Δ D. Howland 6/26/91
 $P_{v2} = z_{st} - z_{v1}$ Δ SNS 7/20/84
 Δ JH 1/9/91 Δ JH 7/11/91

iii) ΔP_{max} ACROSS THE VALVE IS GIVEN BY

$$\Delta P_{max} = P_1 - P_2 = TDH_{50} + z_{st} - z_{v1} - (z_{st} - z_{v1})$$

OR

$$\Delta P_{max} = TDH_{50}$$

PER REFERENCE 2, $TDH_{50} = 186 \text{ ft OR } 81 \text{ psi}$

Δ 2. Valves inside containment (+ containment isolation valves)

a. Open valves that are closing will be exposed to $\Delta P_{max} = TDH_{50}$
 $= 186 \text{ ft or } 81 \text{ psi}$ except for the following:

1) RCP L.D. + reactor vessel support coolers $\Delta P_{max} = 124 \text{ psid}$ (due to back leakage from the RCP thermal barrier check valve pressurizing the piping to relief valve lift pressure minus the static head from the surge tank).

1) RCP thermal barrier isolation valves $\Delta P_{max} = 2458 \text{ psid}$ (due to thermal barrier rupture pressurizing the piping to relief valve lift pressure minus the static head from the surge tank)

2) Excess letdown heat exchanger isolation valve $\Delta P_{max} = 123 \text{ psid}$ (due to excess letdown heat exchanger tube rupture pressurizing the piping to relief valve lift pressure minus the static head from the surge tank)

b. CLOSED VALVES THAT ARE OPENING

AS SHOWN IN THE BASIC ARRANGEMENT DRAWING, PIPING INTO CONTAINMENT WHICH HAS AIR OR MOTOR-OPERATED ISOLATION CAPABILITY



DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 8 OF 23
CALC. NO. M-320
REV. NO. 03

SUBJECT CCW VALVES - DP

MADE BY CEW DATE 3/23/83 CHECKED BY JST DATE 3/30/83 JOB NO. 15320

1/4/90

1/9/91

HAS A CHECK VALVE UPSTREAM OF THE
COMPONENT SERVED.

As a result, when these valves are closed, the piping
upstream of the valve has the potential to go to the
pressure of the relief valve (protecting the upstream piping).
This would be due to thermal expansion if a heat load
were applied to the component.

THE AFFECTED PIPING & ASSOCIATED ISOLATION VALVES
SERVE THE FOLLOWING COMPONENTS

- 1) REACTOR COOLANT PUMP (RCP) L.O. COOLERS &
REACTOR VESSEL SUPPORT COOLERS (RVSC)
- 2) RCP THERMAL BARRIERS
- 3) EXCESS LETDOWN LIX

THE RV'S PROTECTING THESE LINES, AND THEIR
SETPOINTS, ARE LISTED BELOW (REF 1 & 3)

COMPONENT	RV NUMBER	RV SETPOINT (psid/ft)
RCP L.O. & RVSC	RV-51	150 / 347
RCP THERM. BAR.	RV-41, 42, 43, 44	2485 / 5740
EXCESS LETDOWN LIX	RV-52	150 / 347



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 9 OF 23

CALC. NO. M-320

REV. NO. 0

SUBJECT CCW VALVES

MADE BY OWand DATE 3/23/83 CHECKED BY JAK DATE 3/30/83 JOB NO. 15320

THE ΔP_{max} FOR THIS CASE IS DETERMINED AS
FOLLOWS

- i) THE PRESSURE ON THE UPSTREAM SIDE OF ANY ISOLATION VALVE, P_{V1} , IS GIVEN BY

$$P_{V1} + Z_{V1} = P_{RV} + Z_{RV} \quad (\text{ENERGY EQ'N})$$

WHERE P_{RV} = LIFT PRESSURE OF RV

Z_{RV} = ELEVATION OF RV

$$\text{OR } P_{V1} = P_{RV} + Z_{RV} - Z_{V1}$$

- ii) THE PRESSURE ON THE DOWNSTREAM SIDE OF THIS VALVE, P_{V2} , IS GIVEN BY

$$P_{V2} + Z_{V2} = P_{PPS} + Z_{PPS} \quad (\text{ENERGY EQ'N})$$

SEE NOTE BELOW

$$Z_{V2} = Z_{V1}$$

$$P_{PPS} = Z_{st} - Z_{PPS} \quad (\text{FROM SECTION 1 i OF THIS CALCULATION})$$

NOTE: THIS NEGLECTS FRICTION LOSSES & VELOCITY HEAD,
LOWERING, P_{V2} ... SEE DISCUSSION OF RESULTS, SECTION 4.

THE UNIVERSITY OF CHICAGO
LIBRARY

THE UNIVERSITY OF CHICAGO
LIBRARY

THE UNIVERSITY OF CHICAGO
LIBRARY





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 10 OF 23

CALC. NO. M-320

REV. NO. 0

SUBJECT CAN VALVES - ΔP_{max}

MADE BY CE Ward DATE 3/23/83 CHECKED BY JWA DATE 3/30/83 JOB NO. 15320

$$\text{SO } P_{V2} = Z_{st} - \cancel{Z_{PPS}} + \cancel{Z_{PPS}} - Z_{V1}$$

$$\text{OR } P_{V2} = Z_{st} - Z_{V1}$$

iii) MAX ΔP IS GIVEN BY

$$\Delta P_{max} = P_{V1} - P_{V2} = P_{rv} + Z_{rv} - Z_{V1} - (Z_{st} - Z_{V1})$$

$$\text{OR } \Delta P_{max} = P_{rv} + Z_{rv} - Z_{st}$$

iv) ELEVATION OF RV'S

RV NO.	ELEVATION (ABSOLUTE)	REFERENCE
RV-41	107'-5"	19322, REV B
RV-42	109' (APPROX)	19323, REV B
RV-43	108'-8"	19320, REV B
RV-44	104'-8"	19321, REV B
RV-51	109'-4"	1927, REV NOT GIVEN, 10/5/72
RV-52	106'-10"	1443, REV A

NOTE: REFERENCES ARE M.W. KELLOGG DWGS



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 11 OF 23

CALC. NO. M-320

REV. NO. 0

SUBJECT CCW VALVES - DP_{max}
MADE BY CEW and DATE 3/23/83 CHECKED BY JPH DATE 3/30/83 JOB NO. 15320

v) ELEVATION OF WATER LEVEL IN CCW SURGE TANK

PER REF 4 #5, THE ABSOLUTE ELEVATION OF WATER IN THE CCW SURGE TANK (E LOW LEVEL) IS GIVEN BY

$$Z_{st} = 171' - 2" - 5" = 170.75 \text{ ft} \approx 171 \text{ ft}$$

NOTE: -5" IS SETPOINT OF LOW LEVEL SWITCH

vi) BASED ON RV LIFT PRESSURE, P_{rv} , Z_{st} , & Z_{rv} ,

ΔP_{max} (EQ'N IN SECTION 2.iii) IS TABULATED AS GIVEN BELOW

RV No	P_{rv} (psi)	Z_{rv} (ft)	Z_{st} (ft)	ΔP_{max} (psi)	ΔP_{max} (psi)
RV-41	5740	108	171	5677	2458
RV-42	5740	109	171	5678	2458
RV-43	5740	109	171	5678	2458
RV-44	5740	105	171	5674	2456
RV-51	347	110	171	286	124
RV-52	347	107	171	283	123

SEE NEXT PAGE FOR NOTES

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 12 OF 23

CALC. NO. M-320

REV. NO. 04

SUBJECT CCW VALVES - ΔP_{max}

MADE BY C. Ward DATE 3/23/83 CHECKED BY J. H. H. DATE 3/30/83 JOB NO. 15320

A. D. Howland 7/11/91

J. H. H. 7/11/91

NOTES: 1. RV-41, 42, 43, & 44 ALL DISCHARGE INTO A COMMON LINE @ THE CONTAINMENT ISOLATION VALVE. HENCE THE MAXIMUM ΔP_{max} FOR THE 4 RV'S MUST BE CONSIDERED FOR ACTUATOR SIZING

2. IF RV-51 LIFTS, INLET VALVE TO CONTAINMENT, FCV 356 PER REF. 1, WILL ALSO HAVE MAX ΔP AS SHOWN, W/ HIGHER PRESSURE DOWNSTREAM OF VALVE. THIS ΔP_{max} IS WITH THE CCW PPS NOT RUNNING. IF CCW PUMPS ARE RUNNING, ΔP WOULD DECREASE, SINCE THE SUPPLY LINE WOULD BE PRESSURIZED. (see page 2A)

3. ALL RV VALVES ROUNDED UP, WHICH INCREASES ΔP_{max}

3. MAKE-UP WATER VALVES

A. THE PRIMARY SOURCES OF MAKE-UP TO THE CCW SYSTEM ARE AS FOLLOWS, PER REF 6

1. RAW WATER RESERVOIR (ESSENTIALLY CONSTANT PRESS)

2. CONDENSATE STORAGE TANK (THROUGH THE MAKE-UP WATER TRANSFER PUMPS)

3. PRIMARY WATER STORAGE TANK (THROUGH THE PRIMARY WATER MAKE-UP PUMPS)

i) WATER FROM SOURCE 1 ABOVE IS NOT PUMPED. THE ELEVATION OF WATER IN THE RAW WATER RESERVOIR IS 308' (REF 6, SHEET 1 & REF 17)

ii) MAX ELEVATION IN THE CONDENSATE STORAGE TANK (CST), SOURCE 2, IS $115' + 45' - 9'' = 160' - 9''$ (REF 7 & 8). THIS ELEVATION

THE
... ..

... ..

...





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 13 OF 23

CALC. NO. M-320

REV. NO. 2

SUBJECT CCW VALVES - ΔP_{mix}

MADE BY CEW DATE 3/23/83 CHECKED BY JNH DATE 3/30/83 JOB NO. 15320

CEW 7/16/84

JNH 7/20/84

IS TO THE CST OVERFLOW, SHUTOFF HEAD OF THE
MAKE-UP WATER TRANSFER PPS IS 390 ft (REF 9)

- iii) MAX WATER LEVEL IN PRIMARY WATER STORAGE
TANK (PWST), SOURCE 3, IS 152'-6" (REF 7A)
THIS ELEVATION IS TO THE PWST OVERFLOW, SHUTOFF HEAD
OF THE PRIMARY WATER MAKE-UP PUMPS IS 275 ft
(REF 10)

B.

AN EQUATION FOR ΔP_{mix} ACROSS THE CCW
SYSTEM MAKE-UP WATER VALVES, LCV-69 &
LCV-70 (REF 1), IS DEVELOPED BELOW.

- i) PRESSURE UPSTREAM OF VALVE, P_v

$$a) P_v + z_v = P_{ppd} + z_{ppd} \quad (\text{ENERGY EQ'N})$$

WHERE P_{ppd} = DISCHARGE PRESSURE OF TRANSFER
PUMP

z_{ppd} = ELEVATION OF TRANSFER PUMP
DISCHARGE

- b) ACROSS TRANSFER PP, THE ENERGY EQ'N
YIELDS:

$$P_{ppd} + z_{ppd} = P_{pps} + z_{pps} + TDH_{sa}$$



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 14 OF 23
CALC. NO. M-320
REV. NO. 0

SUBJECT CCW VALVES - 12" Pumps
MADE BY CE Ward DATE 3/23/83 CHECKED BY JHR DATE 3/29/83 JOB NO. 15320

WHERE P_{pps} = SECTION PRESSURE OF TRANSFER P_P

Z_{pps} = ELEVATION OF TRANSFER P_P SECTION

TDH_{so} = TRANSFER P_P SHUT-OFF HEAD

- c) FROM STORAGE TANK TO TRANSFER P_P SECTION, THE ENERGY EQ'N YIELDS:

$$Z_{stw} = P_{pps} + Z_{pps}$$

WHERE Z_{stw} = ELEVATION OF LIQUID SURFACE IN STORAGE TANK

- e) SUBSTITUTING EQ'N IN c) INTO EQ'N IN b) YIELDS

$$P_{psi} + Z_{psi} = Z_{stw} + TDH_{so}$$

- e) SUBSTITUTING EQ'N IN c) INTO EQ'N IN a) YIELDS

$$P_{vi} + Z_{vi} = Z_{stw} + TDH_{so}$$

$$\text{OR } P_{vi} = Z_{stw} + TDH_{so} - Z_{vi}$$


100-1000000

100-1000000

100-1000000

100-1000000





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 15 OF 23
CALC. NO. M-320
REV. NO. 0

SUBJECT CCW VALVES - ΔP_{max}
MADE BY CE Ward DATE 3/23/83 CHECKED BY JNH DATE 3/30/83 JOB NO. 15320

ii) PRESSURE DOWNSTREAM OF VALVE, P_{v2}

$$P_{v2} + Z_{v2} = Z_{st} \quad (\text{ENERGY EQN})$$

$$Z_{v2} = Z_{v1}$$

$$\text{SO } P_{v2} = Z_{st} - Z_{v1}$$

WHERE Z_{st} = SURGE TANK WATER LEVEL
(FROM BEFORE)

iii) ΔP_{max} ACROSS THE VALVES IS
GIVEN BY:

$$\Delta P_{max} = P_{v1} - P_{v2} = Z_{stw} + TDH_{so} - Z_{v1} - (Z_{st} - Z_{v1})$$

OR

$$\Delta P_{max} = Z_{stw} + TDH_{so} - Z_{st}$$

SECRET
NOFORN

SECRET
NOFORN

SECRET
NOFORN





DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 16 OF 23

CALC. NO. M-320

REV. NO. 2

SUBJECT RAW VALVES - ΔP_{max}

MADE BY CEW and

DATE 3/23/83

CHECKED BY STN

DATE 3/24/83

JOB NO. 15320

CEW and 7/16/84

STN 7/20/84

C. APPLYING THE ΔP_{max} EQ'N FROM PART B TO THE 3 SOURCES OF WATER YIELDS:

i) RAW WATER RESEVOIR (ASSUMED TO BE GRAVITY FEED)

$$\Delta P_{max} = 308' + 0 - 171' = 137 \text{ ft}$$

ii) CONDENSATE STORAGE TANK (MAKE-UP WATER TRANSFER PPS)

$$\Delta P_{max} = 160.75' + 390' - 171' = 380 \text{ ft}$$

SEE NOTE BELOW

iii) PRIMARY WATER STORAGE TANK (PRIMARY WATER TRANSFER PUMPS)

$$\Delta P_{max} = 152.6' + 275' - 171' = 256.5 \text{ ft}$$

HENCE, THE MAX DP WHICH LCV 69 & LCV 70 HAVE TO OPEN AGAINST IS 380 ft

SEE NOTE BELOW

NOTE: 380 ft IS BASED ON A VERY SIMPLIFIED ANALYSIS, I.E. CONSIDERING SHUT-OFF INSTEAD OF MAKE-UP WATER TRANSFER PPS. THIS VALUE SHOULD ONLY BE USED FOR CONSIDERING OPENING OF LCV'S AND FOR NO OTHER PURPOSE.

Page 10 of 10

10/10/2010 10:10:10 AM

10/10/2010 10:10:10 AM

10/10/2010 10:10:10 AM





DIABLO CANYON PROJECT
CALCULATION SHEET

CALC. NO. M-320

REV. NO. 1

SUBJECT CCW VALVES - ΔP valve

MADE BY CEWand

DATE 6/30/83

CHECKED BY JUL

DATE 7/18/83


JOB NO. 15320

3A

VALVING IN OR VALVING OUT THE IDLE
CCW HX WHEN ONE CCW HX IS IN SERVICE

(BASED ON REF 1)

THE FIGURE BELOW SHOWS THE ARRANGEMENT UNDER
CONSIDERATION, NOTE: EITHER HEAT EXCHANGER CAN BE CONSIDERED
WITH A SIMILAR RESULT.



$$\Delta P_{\text{valve}} = P_2 - P_3$$

(EQ'N 1)

CONSIDER ENERGY EQ'NS. (NEGLECTING VELOCITY HEAD,
WHICH IS SMALL; $V = 0.408 Q/d^2 = 0.408(6567)/(19.25)^2 = 7.2$; $V^2/2g = 0.8 \text{ ft}$)

$$P_2 + z_2 = P_1 + z_1$$

(EQ'N 2)

SEE p19 FOR FLOW

$$P_1 + z_1 = P_{3a} + z_{3a} + h_{L1-3}$$

(EQ'N 3)

NOTE $h_{L3a-3} = 0$, SO $h_{L1-3} = h_{L1-2}$

$$P_3 + z_3 = P_3 + z_{3a}$$


(EQ'N 4)

SECRET
NO. 100-100000

TELETYPE UNIT NO. 1000
NO. 100-100000

NO. 100-100000





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 18 OF 23

CALC. NO. 14-320

REV. NO. 1

SUBJECT CCW VALVES - ΔP_{max}

MADE BY Δ CEWand DATE 6/30/83 CHECKED BY Δ JML DATE 7/14/83 JOB NO. 15320

1

P = STATIC PRESSURE

z = ELEVATION

h_L = HEAD LOSS

SUBSTITUTING EQ'N 4 INTO EQ'N 3,

$$P_1 + z_1 = P_3 + z_3 + h_{L1-3} \quad (\text{EQ'N 5})$$

SUBSTITUTING EQ'N 2 INTO EQ'N 5,

$$P_2 + z_2 = P_3 + z_3 + h_{L1-3} \quad (\text{EQ'N 6})$$

REARRANGING EQ'N 6,

$$P_2 - P_3 = z_3 - z_2 + h_{L1-3}$$

PER REF, $z_3 = z_2$, HENCE

$$P_2 - P_3 = h_{L1-3}$$

h_{L1-3} INCLUDES BOTH PIPING LOSSES
& ΔP THRU CCW HX.



PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 19 OF 23

CALC. NO. M-320

REV. NO. 1

SUBJECT CCW VALVES - DP

MADE BY A. C. Ward DATE 6/30/83 CHECKED BY A. J. M. L. DATE 7/14/83 JOB NO. 15320

TO FIND FRICTION LOSSES, CONSIDER OPERATING MODE. WITH HIGHEST CCW HX ΔP , FROM REF 18 & 19, THE HIGHEST FLOW OCCURS. DUE TO LOSS OF AIR (CAUSING AIR OPERATED VALVES TO GO TO THEIR FAILURE POSITION), WITH 3 CCW PPS IN OPERATION. PER REF 19, 19,700 gpm IS LOSS OF AIR FLOW, HENCE FRICTION LOSSES WILL BE HIGHEST FOR THIS MODE. PER REF 20, CCW HX $\Delta P = 12$ psid FOR 19700 gpm. FOR SIMPLICITY, ASSUME 19,700 gpm FLOWS FROM POINT 1 TO POINT 3a, EXCEPT FOR LINE 3039, WHERE FLOW = $(1/3)19700 = 6567$ gpm. THIS IS CONSERVATIVE SINCE FLOW IN LINE 98 IS LESS THAN 19700.

PIPE FRICTION LOSSES ARE SUMMARIZED ON THE NEXT PAGE. SUMMARIZED BELOW ARE PARAMETERS & EQUATIONS USED TO FIND FRICTION LOSSES.

1. MAX CCW BEFORE CCW HX: TEMPERATURE = 108°F (REF 21, p 20)

$$\mu = 0.33 \text{ Cp (REF 22, p A-3)}$$

$$\rho = 60.4 \frac{\text{lb}}{\text{ft}^3} \text{ (REF 22, p. A-6)}$$

2. MAX CCW AFTER CCW HX: TEMPERATURE = 132°F (REF 21, p 20)

$$\mu = 0.50 \text{ Cp (REF 22, p A-3)}$$

$$\rho = 61.5 \frac{\text{lb}}{\text{ft}^3} \text{ (REF 22, p. A-6)}$$

$$f_{Re} = 50.6 \frac{Q}{du} \text{ (REF 22, p 3-2)}$$

$$h_L = KV^2/2g \text{ (REF 22, p 3-2)}, V = 0.408 Q/d^2 \text{ (REF 22, p 3-2)}$$

1944-1945

1944-1945





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 20 OF 23

CALC. NO. M-320

REV. NO. 1

SUBJECT CCW VALVES - ΔP_{max}

MADE BY A. CEWand DATE 6/30/83 CHECKED BY A. JML DATE 7/18/83 JOB NO. 15320

PRESSURE DROP DATA SHEET

LINE NUMBER	K-3039	K-95	K-101	K-98	
PIPE SIZE (inches)	20	30	30	24	
PIPE ID (inches)	19.25	29.25	29.25	23.25	
PIPE LENGTH (ft) ^(NOTES)	10	114	14	10	
FLOW (gpm)	6567	19,700	19,700	19,700	
Re	3.2×10^6	6.2×10^6	4.2×10^6	5.3×10^6	
f	0.012	0.0115	0.0115	0.012	
$K_{pipe} (= fL/D)$	0.07	0.51	0.07	0.06	
VELOCITY (ft/sec)	7.2	9.4	9.4	14.9	
$f_T =$	0.012	0.011	0.011	0.012	
FITTINGS					
QUANTITY / TOTAL "K"					
ELBOWS (NOTE 5)					
a) 90° ($K = 14f_T$)		4/0.62	1/0.15		
b) 45° ($K = 11f_T$)	1/0.13	4/0.48			
TEES (NOTES)					
a) BRANCH ($K = 60f_T$)	1/0.72		1/0.66	1/0.72	
b) RUN ($K = 20f_T$)				1/0.24	
VALVES (NOTE 5)					
a) BUTTERFLY ($K = 25f_T$)	1/0.30	1/0.28	1/0.28	2/0.60	
b) CHECK ($K = 100f_T$)	1/1.2				
OTHER					
TOTAL "K"	2.42	1.89	1.16	1.62	
h_L (ft)	2.0	2.6	1.6	5.6	

- NOTES:
1. K VALUES PER REF 22, UNLESS NOTED.
 2. f PER REF 22, P. A-25
 3. NEGLECT SMALL TEE'S.
 4. VALUES OF f_T PER REF 23, P. A-26 OR A-25
 5. PIPING ARRANGEMENT PER REF 23

1948-1949

1948-1949

1948-1949





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 21 OF 23

CALC. NO. M-320

REV. NO. 1

SUBJECT CAN VALVES - MAX DP

MADE BY A. C. Ward DATE 6/12/97 CHECKED BY A. J. Hall DATE 7/18/13 JOB NO. 15320



FROM THE PRESSURE DROP DATA SHEET

$$h_{L_{PIPE}} = 7.0 + 2.0 + 1.6 + 5.6 = 16.2 \text{ ft}$$

$h_{L_{HX}} = 12 \text{ psid}$ (ASSUMING VENDOR DATA INCLUDES LOSS @ INLET & OUTLET)

SO,

$$\Delta P_{value} = 12 \text{ psid} + \frac{16.2}{2.31} = 17.1 \text{ psid}$$

FOR CONSERVATISM, SAY $\Delta P_{value} = 20 \text{ psid}$

DATE: 11/11/11

TIME: 11:11 AM

11/11/11 11:11 AM



SUBJECT CCW VALVE DP

MADE BY CEWand DATE 3/23/83 CHECKED BY FRK DATE 3/24/83 JOB NO. 15320

4. DISCUSSION OF RESULTS

i) THE RESULTS FOR PART 1 OF THIS CALC ARE CONSERVATIVE, IN GENERAL, SINCE IT IS NOT VERY LIKELY THAT ANY VALVES IN THE SYSTEM WILL SEE PUMP SHUT-OFF HEAD.

FOR THE INDIVIDUAL COMPONENTS TO SEE SHUT-OFF HEAD, ALL OTHER COMPONENTS WOULD HAVE TO BE ISOLATED, WHICH IS VERY IMPROBABLE.

ii) SHOULD THE CCW LIX BE ISOLATED BY ITS DISCHARGE MOV, THE CCW PUMPS WILL GO ON RECIRCULATION (REF 1), HENCE PUMPS WILL NOT BE QUITE @ SHUT-OFF HEAD. FOR THESE VALVES TO SEE FULL SHUT-OFF HEAD, THE RECIRCULATION VALVES WOULD HAVE TO FAIL TO OPEN (THIS WOULD BE SECOND FAILURE, ASSUMING THAT THE CCW LIX DISCHARGE VALVE CLOSURE IS THE FIRST).


THE RESULTS IN PART 2 OF THIS CALC ARE CONSERVATIVE SINCE RETURN LINE PRESSURES, IN GENERAL, WILL BE ABOVE THE STATIC HEAD OF THE SURGE PANK, THIS ASSUMPTION INCREASES THE DP ACROSS THE VALVES IN QUESTION. SEE NOTE 2 ON PAGE 11 FOR AN ADDITIONAL COMMENT.

iii) THE RESULTS IN PART 3 ARE CONSERVATIVE SINCE IT IS UNLIKELY THAT THE MAKE-UP WATER PUMPS CONSIDERED WOULD BE

TO: DIRECTOR, FBI
FROM: SAC, NEW YORK
SUBJECT: [Illegible]

RE: [Illegible]





PACIFIC GAS AND ELECTRIC COMPANY
BECHTEL POWER CORPORATION

DIABLO CANYON PROJECT
CALCULATION SHEET

SHEET NO. 23 OF 23

CALC. NO. M-320

REV. NO. 0

SUBJECT CCW VALVE - ΔP_{max}

MADE BY CE Ward DATE 3/23/83 CHECKED BY EPH DATE 3/29/83 JOB NO. 15320

OPERATING & NOT SUPPLYING ANY OTHER
USERS (HENCE GOING TO SHUT-OFF HEAD).
ALSO, BOTH THE MAKE-UP WATER TRANSFER
PUMPS & PRIMARY WATER MAKE-UP PUMPS
HAVE CONTINUOUS FLOW RECIRCULATION
LINES. (REF (6)), HENCE, THESE PUMPS WILL
ALWAYS OPERATE WITH A TDH LESS THAN
SHUT-OFF HEAD.

- iv) THE LEVEL OF THE SURGE TANK ONLY ENTERS
INTO CALCULATION OF ΔP_{max} FOR SECTIONS
3 & 4 (ISOLATED VALVES IN CONTAINMENT &
MAKE-UP WATER VALVES). ASSUMING LOW LEVEL
IN THE SURGE TANK IS CONSERVATIVE, SINCE
IT LOWERS THE DOWNSTREAM PRESSURE OF THE
SUBJECT VALVES, INCREASING ΔP_{max} .

PC-66346


PRIMARY WATER TRANSFER P

50-1

C-4052

C-271-C

CUSTOMER PACIFIC GAS & ELEC		DESIGN CONDITIONS		CURVE 150VM3A C77	
PROPOSAL NO. 66-31677 ITEM 4		GPM 150	EFF	PUMP 1 1/2 VM-15	
SPECIAL NOTES 0372-8035 0372-8036		T.H. (FT.) 22.2	BHP	SG.	Curves are approximate. Pump is guaranteed for total of conditions. Capacity, head and efficiency guarantees are based on shop test and when handling clear, cold, fresh water at a temperature of not over 65 degrees and not over 15' suction lift.
		RPM 3550	DRIVER M	HP 15	
		DRAWN BY		DATE	



PACIFIC GAS AND ELECTRIC CO.
APPROVED FOR CONSTRUCTION
NOV 14 1972
DEPARTMENT OF ENGINEERING

MECHANICAL ENGINEERING
FILE COPY

THIRAKI HORSEPOWER
NPSH IN FEET

MEMORANDUM

014430


TO EC CONNELL / CEWARDLOCATION 45/10/D25

TN CRAWFORD / FICUCCO


DATE MAR 9 19 83JOB NO. 15320SUBJECT SETTINGS OF CCW RELIEF VALVES

FILE _____

A LIST OF RELIEF VALVES IN THE COMPONENT COOLING WATER SYSTEM AND THEIR CURRENT FIELD SETTINGS FOR UNIT 1 OF DIABLO CANYON IS ATTACHED. THESE SETTINGS WERE VERIFIED BY G.C. PERSONNEL AS BEING THE ACTUAL SETTINGS FROM THE G.C. TEST SHEETS (FORM E-22) VALID AS OF JANUARY 1983.



NO RESPONSE REQ'D



100

100



034430

SYS 14 RELIEF VALVE SETTINGS
AS VERIFIED BY G.C. 12/82 & 1/83

TAG #	SETTING	TAG #	SETTING
RV 41	2485 PSIG	RV 189	70 PSIG
RV 42	2485 PSIG	RV 191	50 PSID
RV 43	2485 PSIG	RV 192	70 PSID
RV 44	2485 PSIG	RV 194	50 PSID
RV 45	30 PSIG	RV 302	50 PSID
RV 46	70 PSID	RV 303	50 PSID
RV 47	70 PSID	RV 304	70 PSIG
RV 49	50 PSID	RV 305	70 PSIG
RV 51	150 PSIG	RV 307	50 PSID
RV 52	150 PSIG	RV 309	50 PSID
RV 55	50 PSID	RV 311	50 PSID
RV 186	50 PSID	RV 313	50 PSID
RV 187	50 PSID		
RV 188	50 PSID		

PSIG = POUNDS PER SQUARE INCH GAUGE

PSID = POUNDS PER SQUARE INCH DIFFERENTIAL

