

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 02-10		See me about this. Note and return.	For concurrence. For signature.	For action. For information.
TO (Name and unit) IE Chief, FS&EB IE:HQ (4) Licensing (4) <u>DR Central Files</u> J. Rizzo, IE:HQ		INITIALS	REMARKS Commonwealth Edison	
		DATE	Dresden Unit 2 50-237	
TO (Name and unit) A/D for Info. Processing Region I Region II PDR Local PDR		INITIALS	REMARKS	
		DATE		
TO (Name and unit) NSIC TIC Mr. A. Roisman		INITIALS	REMARKS	
		DATE		
FROM (Name and unit) G. Fiorelli IE:III		REMARKS Attached report of internal audit dated February 28, 1975.		
PHONE NO.	DATE 3-3-75			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-262

Missed (1) ✓



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

BBS Ltr. #121-75

Dresden Nuclear Power Station
R. R. #1
Morris, Illinois
February 28, 1975

Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations-Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Docket 59-237

SUBJECT: LICENSE DPR-19, DRESDEN NUCLEAR POWER STATION, UNIT 2. ADDITIONAL INFORMATION ON REPORT OF INSPECTION OF BERGEN-PATERSON SHOCK SUPPRESSORS AND RESTRAINTS

References: Letter from B. B. Stephenson to J. F. O'Leary dated June 20, 1974

Dear Mr. Keppler:

In response to an internal audit made by the off-site review function, the following additional information is supplied to complete the incident reporting requirement.

In light of the cumulative experience in which the previous snubbers failed as a result of the brittle polyurethane seal material, the continued 120 day inspection of these drywell snubbers will minimize the possibility of a more inoperable snubbers. In addition, as a result of the present (June 20, 1974) snubbers failures, a review of design loadings of the area where some of these snubbers are located is being made. The results of this review will be documented in a followup letter along with other snubber information as committed to in the June 20, 1974 letter referenced above.


B. B. Stephenson
Superintendent

BBS:RLW:smp

File/AEC

MAR. 3 1975

February 24, 1975

Commonwealth Edison Company
ATTN: Mr. J. S. Abel, Nuclear
Licensing Administrator
Boiling Water Reactors
P. O. Box 767
Chicago, Illinois 60690

Docket No. 50-237

Gentlemen:

In response to your February 10, 1975 letter, we are informing you that Mr. John Weeks of the Brookhaven Nuclear Laboratory and Mr. K. V. Seyfrit, Chief of the Technical Assistance Branch, Office of Inspection and Enforcement will participate in the meeting to discuss core spray safe ends and pipe cracks mentioned in your letter. You should expect direct communication from either in regards to obtaining specimens of the core spray pipes or safe ends.

Sincerely yours,

G. Fiorelli, Chief
Reactor Operations Branch

bcc: M. Kehnemuyi, HQ:TR
B. H. Grier, HQ:IE
J. G. Davis, HQ:IE
H. D. Thornburg, HQ:IE
K. V. Seyfrit, HQ:IE
R. F. Warnick, HQ:IE
J. G. Keppler, IE:III
Local PDR
PDR
DR Central Files
IE Files

IE:III

Fiorelli/pdc

2/24/75

Done
(1)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

FEB 12 1975

Commonwealth Edison Company
ATTN: Mr. Byron Lee, Jr.
Vice President
P.O. Box 767
Chicago, Illinois 60690

Docket No. 50-237
Docket No. 50-249
Docket No. 50-254
Docket No. 50-265

Gentlemen:

In reply to your letter of February 4, 1975, to Mr. Edison G. Case, this is to confirm the acceptability of your proposed schedules for conducting the required inspections at Dresden 2 and 3 and Quad-Cities 1 and 2 in response to IE Bulletin No. 75-01. It is our understanding that you have had additional telephone conversations with Mr. Edison G. Case and his staff regarding the Dresden 1 schedule, and that he will communicate with you separately regarding the acceptability of your proposed schedule for that facility.

Your request to use ASME Boiler and Pressure Vessel Code Section XI, 1971 Summer Addenda for the required inspections is consistent with IE Bulletin No. 75-01A.

Sincerely yours,

James G. Keppler
Regional Director

bcc: B. H. Grier, IE:HQ
J. G. Davis, IE:HQ
H. D. Thornburg, IE:HQ
R. Warnick, IE:HQ
IE:HQ (4)
Licensing (4)
DR Central Files

PDR

Local PDR

NSIC

TIC

Anthony Roisman, Esq.



Misc
(1)