

DK Central File

APR 1 1974

Commonwealth Edison Company
ATTN: Mr. Byron Lee, Jr.
Vice President
P. O. Box 767
Chicago, Illinois 60690

Docket Nos. 50-237
50-249

Gentlemen:

Thank you for your letter of March 15, 1974, informing us of corrective steps you have taken on the violations and commitments which we brought to your attention in our letter of February 21, 1974. With respect to your response, the following items were discussed with Mr. J. Abel of your staff who agreed that your letter should be clarified as shown below.

Response to Appendix A

Item II G - The AEC's interpretation of "commercial service" was not meant to be called "new".

Response to Appendix C

Item A.1 - Installation and testing of all level instrumentation included pump trip circuits. Documentation of the November 1973 testing, not a retest as stated, was completed on March 13, 1974. Retesting of both units is planned at the earliest opportunity. Retesting for Unit 3 will be completed prior to reactor restart.

Item A.3 - Installation was completed on November 1973 but not tested. Testing was completed on March 13, 1974.


Item D - The reference to February 23, 1973 should have read "February 23, 1974."

We will examine your actions on these matters during subsequent inspections.

bcc: L. M. Muntzing, DR	P. A. Morris, RO		L. Reeder, RO
L. V. Gossick, ADR	B. H. Grier, RO	Sincerely,	Regional Directors
L. Rogers, RS	R.C. DeYoung, L		DR Reading File
J. F. O'Leary, L	G. Roy, RO		DR Central File
E. G. Case, L	R. F. Fraley, ACRS	Original signed by	RO Files
A. Giambusso, L	J. Harris, IS	J. G. Davis	PDR LPDR NSIC TIC
J. M. Hendrie, L	J. Fouchard, IS	John G. Davis, Deputy Director	
D. F. Knuth, RO	F. Ingram, IS	for Field Operations	
J. G. Davis, RO	J. Murray, OGC	Directorate of Regulatory Operations	

cc: S. Stephenson	RO:FS/EB	RO:FS/EB,C	RO:DD/FO	RO:
OFFICE > Dresden Plant Superintendent	SEBryan:das	H. H. H. H. H.	JGDavis	
SURNAME >	3/28/74	3-28-74	3/29	
DATE >				

DL Central File



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TELEPHONE
(312) 858-2660

FEB 28 1974

Commonwealth Edison Company
ATTN: Mr. Byron Lee, Jr.
Vice President
P. O. Box 767
Chicago, Illinois 60690

Docket No. 50-237
Docket No. 50-249

Gentlemen:

This refers to the inspection conducted by Mr. Maura of this office on October 1-5, 11, 12 and 17, 1973, of activities at Dresden Units 2 and 3 authorized by AEC Operating Licenses No. DPR-19 and No. DPR-25 and to the discussion of our findings with Mr. Worden and members of his staff at the conclusion of the inspection and during a subsequent telephone conversation on December 3, 1973.

A copy of the inspection report referenced in the Regulatory Operations, Headquarter's letter of February 21, 1974, is enclosed and identifies the areas examined during the inspection.

The inspection included an examination of your design review of Units 2 and 3 main steam relief and safety valve stress calculations as identified in our letter of April 28, 1972. We have no further questions on this item at this time.

In accordance with Section 2.790 of the AEC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the AEC's Public Document Room. If this report contains any information that you or your contractors believe to be proprietary, it is necessary that you make a written application to this office, within twenty days of your receipt of this letter, to withhold such information from public disclosure. Any such application must include a full statement of the reasons for which it is claimed that the information is proprietary, and should be prepared so the proprietary information identified in the application is contained in a separate part of the document. Unless we receive an application to withhold information or are otherwise contacted within the specified time period, the written material identified in this paragraph will be placed in the Public Document Room.

fy

FEB 28 1974

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely yours,

James G. Keppler
Regional Director

Enclosure:

RO Inspection Rpt No. 050-237/73-05
and No. 050-249/73-06

cc: W. Worden
Dresden Station Superintendent, w/encl

bcc: RO Chief, FS&EB
RO:HQ (4)
Licensing (4)
DR Central Files
RO Files
PDR, w/encl
Local PDR, w/encl
NSIC, w/encl
DTIE, w/encl