

January 5, 1977

COMMONWEALTH EDISON COMPANY

DOCKET No. 50-237, 50-249, 50-254 and 50-265

BWR-3 Response

part a) The following peak local exposures were achieved as of December 1, 1976.

Dresden 2	28.3	GWD/MTU
Dresden 3	27.3	"
Quad Cities 1	27.2	"
Quad Cities 2	27.3	"

part b) Response to this question is provided by the generic information General Electric transmitted to USNRC. (Letter from G. G. Sherwood (GE) to D. F. Ross (NRC), dated December 22, 1976)

part c) Ditto part b). In the context of GE Figure 19, Edison BWR-3 reactors are classified as "long reflooding plants".

part d) Ditto part b).

ATTACHMENT 1