



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

December 12, 1990
G02-90-204

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21
RESPONSE TO GENERIC LETTER 89-10, SUPPLEMENT 3,
"CONSIDERATION OF THE RESULTS OF NRC-SPONSORED
TESTS OF MOTOR-OPERATED VALVES" (TAC NOs. 75738
AND 77801)**

Generic Letter 89-10, Supplement 3 requires that BWR licensees provide a written response to Reporting Requirement number one within 30 days of their receipt of the letter. The Supply System received the subject letter November 12, 1990. The purpose of this letter is to provide such response.

The Supply System has completed a plant specific safety assessment which addresses the factors described in Generic Letter 89-10, Supplement 3. The safety assessment is available on site for Staff review.

The subject Generic Letter also requested that BWR licensees notify the NRC staff whether they believe that there are MOVs with deficiencies of greater safety significance than the MOVs used to provide containment isolation in the steam supply lines of the HPCI and RCIC systems, in the supply line of the RWCU system, and in the line to the isolation condenser.

In light of the limited data from the INEL testing, at this time, no MOVs have been identified for WNP-2 with greater safety significance than those previously identified in IE Bulletin 85-03.

This completes the Supply System's response to Generic Letter 89-10, Supplement 3.

Very truly yours,


G. C. Sorensen, Manager
Regulatory Programs

cc: JB Martin - NRC RV
NS Reynolds - Winston & Strawn
PL Eng - NRC

DL Williams - BPA/399
NRC Site Inspector - 901A

RESPONSE TO GENERIC LETTER 8!


Subject: SUPPLEMENT 3

STATE OF WASHINGTON)

COUNTY OF BENTON)


I, G. C. SORENSEN, being duly sworn, subscribe to and say that I am the Manager, Regulatory Programs, for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM; the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE: 12 DEC, 1990


G. C. Sorensen, Manager
Regulatory Programs

On this date personally appeared before me G. C. SORENSEN, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 12th day of December 1990.


Notary Public in and for the
STATE OF WASHINGTON

Residing at Richland, WA
My commission expires 7/14/91