

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Open Session

Docket Number: N/A

Location: Rockville, Maryland

Date: April 6, 2017

Work Order No.: NRC-3009

Pages 1-112

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

642ND MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY

APRIL 6, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
 Regulatory Commission, Two White Flint North, Room
 T2B1, 11545 Rockville Pike, at 1:30 p.m., Dennis C.
 Bley, Chairman, presiding.

COMMITTEE MEMBERS:

- DENNIS C. BLEY, Chairman
- MICHAEL L. CORRADINI, Vice Chairman
- PETER RICCARDELLA, Member-at-Large
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR. Member

1 MARGARET CHU, Member
2 WALTER L. KIRCHNER, Member
3 JOSE A. MARCH-LEUBA, Member
4 DANA A. POWERS, Member
5 HAROLD B. RAY, Member
6 JOY REMPE, Member
7 GORDON R. SKILLMAN, Member
8 JOHN W. STETKAR, Member
9 MATTHEW W. SUNSERI, Member

10

11 DESIGNATED FEDERAL OFFICIAL:

12 CHRISTINA ANTONESCU

13 KENT HOWARD

14

15 ALSO PRESENT:

16 DONALD BRITTNER, NRR

17 LUIS BETANCOURT, NRO

18 STEVEN BLOOM, NRR

19 ANGELA BUFORD, NRR

20 DAVID CURTIS, NRO

21 JOE DONOGHUE, NRR

22 SARAH FIELDS, Public Participant*

23 ALLEN HISER, NRR

24 DAWN MATHEWS KALATHIVEETTIL, NRO

25 BILL ROGERS, NRR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MADHUMITA SIRCAR, RES
OMID TABATABAI, NRO
ANDREA VEIL, Executive Director, ACRS
GEORGE WILSON, NRR

*Present via telephone

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

NuScale Topical Report 1015-18653, "Highly Integrated Protection System Platform"

Remarks by the Subcommittee Chairman. 7

Briefing and discussions with representatives of the NRC staff and NuScale regarding the subject topical report. 9

Preparation of reports. N/A

Subsequent License Renewal

Gordon Skillman. 27

George Wilson. 27

Steven Bloom. 28

Allen Hiser. 29

Bill Rogers. 55, 76

Adjourn. 112

P R O C E E D I N G S

1:30 p.m.

CHAIRMAN BLEY: The meeting will now come to order. This is the first day of the 642nd meeting of the Advisory Committee on Reactor Safeguards.

Today's meeting the Committee will consider the following. Well, the first two we have already done, which was a meeting with the commissioners.

Three is a NuScale Topical Report, highly integrated protection system platform. Later this afternoon subsequent license renewal and then preparation of ACRS reports.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act, FACA. As such, this meeting is being conducted in accordance with the provisions of FACA.

That means that the Committee can only speak through its published letter reports. We hold meetings to gather information to support our deliberations.

Interested parties who wish to provide comments can contact our offices requesting time after the Federal Register notice describing the meeting is published.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That said, we also set aside 10 minute for
2 spur of the moment comments for members of the public
3 attending or listening to our meetings.

4 Written comments are also welcome. Ms.
5 Christina Antonescu is the designated federal official
6 for the initial portion of the meeting. There she is.

7 Portions of the session on NuScale Topical
8 Report may be closed in order to discuss and protect
9 information designated as proprietary.

10 When that happens, we will take public
11 comments at that time. We will finish this meeting
12 and then we will come back in a public session for the
13 next session at 3:15 p.m. later today.

14 The ACRS section of the U.S. NRC public
15 website provides our charter bylaws, letter reports
16 and transcripts of all Full and Subcommittee meetings
17 including slides presented at the meetings.

18 We have received no written comments or
19 requests to make oral statements for members of the
20 public regarding today's sessions.

21 There is a telephone bridge line to
22 preclude interruption of the meeting. The phone will
23 be placed in a listen-in mode during presentations and
24 Committee discussion.

25 A transcript of portions of the meeting is

1 being kept and it is requested that the speakers use
2 one of the microphones, identify themselves and speak
3 with sufficient clarity and volume so that they can be
4 readily heard.

5 At this time, I will turn the meeting over
6 to Professor Corradini for our first session.

7 VICE CHAIRMAN CORRADINI: Okay. Thank you
8 very much.

9 So for the members, this is our Full
10 Committee meeting following our Subcommittee meeting
11 on one of, I think, the second topical report coming
12 out of NuScale.

13 This topic is a highly integrated
14 protection system platform. This is a topical report
15 which will support the protection, the NuScale design
16 and certification application and all we are
17 considering today is the platform design and
18 associated architecture that will be discussed by the
19 staff.

20 NuScale should be on the line, okay, and
21 if we have questions of NuScale we can go to the - to
22 the private or should I say the private line into the
23 discussion.

24 We will plan to have an open session.
25 When we are done with that we will go to public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comments and then we will go to closed session to
2 discuss any issues relative to the design and our
3 questions in closed session that is proprietary.

4 CHAIRMAN BLEY: Pete.

5 MEMBER RICCARDELLA: Yeah. I need to
6 recuse myself from any deliberations on this subject.

7 CHAIRMAN BLEY: Okay. So we will start
8 with Omid Tabatabai. Omid -

9 MR. TABATABAI: Yes.

10 CHAIRMAN BLEY: - the floor is yours.

11 MR. TABATABAI: Thank you. Thank you, Dr.
12 Corradini. Thank you, ACRS members. I think you
13 covered all of the introductory material very well.
14 We have two separate bridge lines.

15 For the open session, members of the
16 public can ask questions and then once we start the
17 closed session we are going to hang that up and then
18 start the closed bridge line.

19 It's a separate number and it activates at
20 1:45. It's not activated right now.

21 As you mentioned, NuScale technical staff
22 are available online. If there are any questions we
23 will - if we need to we will defer to NuScale staff.

24 There are two sets of handouts here in
25 front of you. One is for the open and closed, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then there is a - there is an older size chart and
2 that goes with the closed session. And then for the
3 members of the public, the audience, we will provide
4 the closed session handouts after we close the open
5 portion of the meeting.

6 As you mentioned, we covered this topic
7 during a Subcommittee presentation back in February
8 and we issued our final safety evaluation report in
9 March.

10 And today is an opportunity for the Full
11 Committee members to ask questions and give us any
12 comments or suggestions before we finalize our safety
13 evaluation report.

14 I don't have anything else to cover. I
15 will turn the table to Mr. Dawnmathews and he will
16 start the presentation.

17 MR. KALATHIVEETTIL: All right. Thank
18 you, Omid. Good afternoon, members. I will be
19 presenting the open session of our presentation today.

20 So first slide. So with today's agenda we
21 will provide a brief background of the major
22 milestones during the review, a high-level description
23 of the HIPS platform, the scope of the staff's review
24 and evaluation and a summary of the staff's regulatory
25 findings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There is also a slide, slide number eight
2 on the presentation, which has all the acronyms
3 listed. All right. A little bit about the
4 background. In late 2015, the applicant submitted
5 Revision 0 of the topical report. In February 2016,
6 the staff docketed the initial version of the topical
7 report.

8 Since then, the staff has expended over
9 15,000 - I am sorry, 1,500 staff hours which involve
10 four engineers. The actual hours are consistent with
11 the estimated hours found in the acceptance letter.

12 During this time, the staff conducted
13 several public meetings and two audits in support of
14 the topical review. The first audit was here in
15 Rockwell and it focused on reviewing the requirements
16 specs of the platform.

17 The applicant responded to over 18 staff
18 questions in one round of RAIs. In November 2016, the
19 applicant submitted Revision 1 of the topical report
20 in which the applicant incorporated the responses to
21 the staff's RAIs.

22 The second audit was at Wimborne, United
23 Kingdom and it was to observe the factory acceptance
24 testing of the platform prototype. The staff
25 confirmed that the claims in the topical report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conformed to the applicable regulations and standards.
2 Also the staff had no new observations nor identified
3 any new RAIs in this audit.

4 So in January 2017 we shared the draft
5 evaluation and the final IC was published in March of
6 2017.

7 MEMBER SKILLMAN: Dawnmathews, is there
8 any location in the world or in the U.K. where this
9 exact system is being utilized?

10 MR. BETANCOURT: No, this is still in the
11 -

12 VICE CHAIRMAN CORRADINI: You have to
13 identify yourself, please.

14 MR. BETANCOURT: Oh, sorry. So my name is
15 Luis Betancourt. To answer your question, no. This
16 is still a design. The only thing that NuScale has
17 done is to build a prototype.

18 So we expect this will be the first design
19 that will be used by the NuScale application.

20 MEMBER SKILLMAN: Thank you. Okay.

21 MEMBER KIRCHNER: May I chime in on this?
22 I should have asked this is Subcommittee for
23 clarification. Is it the objective to essentially
24 confirm this design as we see it or the actual
25 hardware as they built in a prototype or what I am

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 struggling with, the word platform. So how do you
2 define platform here? Is it the actual architecture
3 of this design and the components that they would use?

4 MR. BETANCOURT: It is - if I can answer
5 the question.

6 MEMBER KIRCHNER: Yes, please.

7 MR. BETANCOURT: It is only the design of
8 the platform. The platform has not been built yet so
9 the only thing that we have here is a philosophy in
10 the way that if you build the platform this way then
11 that will be acceptable to the staff.

12 MEMBER KIRCHNER: So - and the prototype
13 is in the reports then - of a loaded module is just a
14 prototype?

15 MR. BETANCOURT: Well, right now we have
16 to do the prototype. But after the prototype they are
17 going to refine the requirements and that's going to
18 be given to us in the design notification and we are
19 going to review that again to see how the prototype
20 went in the final design of the platform.

21 VICE CHAIRMAN CORRADINI: So just one
22 thing. We are hearing background noise from the phone
23 line. So if you're on the phone line can you please
24 mute your phone? Thank you.

25 MR. BETANCOURT: As a follow-up, if I want

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to say something, if we reach out to -- if you look at
2 the title of the platform, it did not have the
3 designer. So we asked NuScale to add that because
4 this is still a design paper. It hasn't been built
5 yet.

6 MEMBER BROWN: So let me - let me take a
7 shot at something here. Platform versus architecture
8 - that's Walt's question.

9 MEMBER KIRCHNER: Yeah.

10 MEMBER BROWN: The platform is the
11 computing box.

12 MR. BETANCOURT: Yeah. The brains.

13 MEMBER BROWN: The SFMs - the safety
14 function module, the safety data - well, no, safety -
15 what is the SDB, what -

16 (Simultaneous speaking.)

17 MEMBER BROWN: They safetied that data bus
18 in the scheduling and building module, okay, and the
19 EIM, the equipment interface module.

20 MR. BETANCOURT: Right.

21 MEMBER BROWN: Those are - it's the
22 platform. That is not an architecture. That is
23 literally just the boxes in which you build the
24 architecture.

25 MR. BETANCOURT: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: That's the question he's
2 asking.

3 MR. BETANCOURT: Right. Okay.

4 MEMBER KIRCHNER: So when you have
5 approved this, the SER on this Topical, then what you
6 really have approved is those modules in this
7 configuration.

8 MR. BETANCOURT: Right. In the example
9 proposed in the Topical, right. But then, do people
10 feel you're --

11 MEMBER KIRCHNER: But as - but as my
12 fellow member corrects me, this is not the
13 architecture -

14 MR. BETANCOURT: Right.

15 MEMBER KIRCHNER: - for a bigger system.
16 It's just this building block set.

17 MR. BETANCOURT: Right. And in the
18 topical report you will also find a statement that you
19 can configure these models in different ways. So in
20 reality they propose to us on a sample of a proposed
21 architecture. But in reality, when they can reference
22 this they can propose on another one and then we will
23 take a look at that again once that -- and the license
24 amendment request was part of the disagreement.

25 MEMBER MARCH-LEUBA: So going back a step

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 - a step back, what is the value of the SER? I mean,
2 an SER gets issued so it can be referenced for
3 licensing purposes. Is this SER ever going to be
4 referenced?

5 MR. BETANCOURT: Yeah. In the design
6 package that's what they want to do. This is kind of
7 the same thing that happened at the electrical - at
8 the classification of the Class 1 report.

9 They wanted to come to the staff early in
10 the game to find out whether this design will be good
11 for us and that was the reason that we have the
12 topical report in house.

13 In reality, they could have waited all the
14 way to the design certification to come with the
15 platform. But they just wanted to see that - they
16 want to have the staff to look at ahead of time. That
17 is all.

18 MEMBER BROWN: Let me phrase that slightly
19 different. All they are going to get out of this is
20 that those modules in a configuration in the chassis
21 can be configured to produce a trip system and
22 safeguards path that meet independence redundancy, et
23 cetera - the fundamentals. That's all they are
24 getting out of this.

25 It doesn't define the architecture we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have in the final design. It doesn't cover any
2 connections to any safety/nonsafety connections. It
3 doesn't connect - doesn't talk about communications to
4 the main control room, network interfaces, security
5 blocks, fire walls, one-way data transmit - doesn't
6 talk about any of - other than within those boxes
7 themselves.

8 That's all, and they could make this six
9 channels. They could make it three or two, whether we
10 would accept - whether it's acceptable and relevant.
11 It's just that those boxes can be put together in a
12 manner that suit the fundamentals.

13 MEMBER KIRCHNER: In this configuration.

14 MEMBER BROWN: In this configuration.

15 MEMBER KIRCHNER: So they would -

16 MEMBER BROWN: And the - let me finish -
17 and the field programmable data raise can be put
18 together in a manner that is independent as well.

19 MEMBER STETKAR: Just remember that -

20 MEMBER BROWN: Go ahead, John.

21 MEMBER STETKAR: - that in a topical
22 report, John's reactor can use this topical report is
23 John's reactor wants to use this platform. So that
24 helps the staff's review of John's reactor and that
25 the staff doesn't need to review this part of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 platform. You need to review the application
2 specific, you know, to John's reactor.

3 So when you say just because this happens
4 to have the word NuScale on it it's the staff's
5 acceptance of this part of a conceptual design.

6 MR. BETANCOURT: Right. And I think at
7 the last meeting you mentioned, John, that a good way
8 to see this, to do this for NuScale, think about it
9 like Rock Creek came from the design. Right.

10 MEMBER STETKAR: And that's why I used
11 this motion of John - if John's reactor wanted to use
12 this platform as part of our My Safety system.

13 MEMBER KIRCHNER: Now, is this generic
14 enough at a component level that - because, you know,
15 the short - how much the electronics field changes
16 they could change out individual subcomponents in this
17 architecture?

18 MR. BETANCOURT: If they changed anything
19 from the modules then we have to take a look at that
20 one.

21 MEMBER KIRCHNER: Then you'd have to do
22 it. So they are kind of locking in on these modules
23 as defined in this report.

24 MR. BETANCOURT: Right.

25 MEMBER KIRCHNER: Okay. So I just wanted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be clear what exactly you're approving here.

2 MR. BETANCOURT: Right. And that was one
3 of the reasons -

4 MEMBER KIRCHNER: Thank you.

5 MR. BETANCOURT: - that we have a - an
6 ASI, the data departure from the models -

7 MEMBER KIRCHNER: Okay. Fine.

8 MR. BETANCOURT: - then it comes back to
9 us.

10 MEMBER KIRCHNER: Thank you.

11 MR. BETANCOURT: Shall we move on? Go
12 ahead.

13 MR. KALATHIVEETIL: All right. Moving
14 on. The HIPS platform, that's basically composed of
15 logic implemented using discrete logic and FPGA
16 technology. The platform consists of the HIPS chassis
17 which includes a back plane and a back panel and also
18 a system of modules that are interchangeable between
19 chassis.

20 The different module types can be seen on
21 the slide. The platform is designed to work with
22 different module types configured to individual
23 applications where multiple chassis can be connected
24 together to create a larger system.

25 The different HIPS modules and platform

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inputs and outputs are then connected to each other
2 through the back plane and the back panel of the
3 chassis. The purpose of the SFM is to provide signal
4 conditioning and actuation determination for safety
5 functions.

6 It also provides scaled value of input
7 processes through nonsafety controls and other safety
8 displays for monitoring purposes. This module
9 includes an FPGA as well as analog components in it.
10 The purpose of the CM is to control -

11 MEMBER BROWN: Before you - before you go
12 on, the safety function module in this design is the
13 meat and potatoes part. That's where the algorithms
14 for your reactor trip or safeguards actuations are
15 generated.

16 So they take the plant parameter data,
17 process it through the - in there where the set points
18 are contained and they produce a trip and all that's
19 then passed on via these digital data busses down
20 through the remaining communication modules.

21 MEMBER STETKAR: Charlie, for
22 clarification, the SFM only determines whether the
23 input satisfies an algorithm that says it is a - I'll
24 use the term - I don't want to use the term tripper
25 actuate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It is a not acceptable value. It has
2 nothing to do with reactor tripper safeguards
3 actuations. Is that true? Because that's determined
4 down in the SVMs.

5 MEMBER BROWN: The SVM votes.

6 MEMBER STETKAR: But there are -

7 MEMBER BROWN: And it doesn't trip.

8 MEMBER STETKAR: Well, if this is
9 proprietary we have to be careful. It's we are
10 getting -

11 (Simultaneous speaking.)

12 But on the - on the public stuff we have
13 to be careful that the SFMs, I don't believe, know
14 whether their output has anything to do with the
15 reactor trip or safeguards actuation.

16 MEMBER BROWN: Yes, it does.

17 MEMBER STETKAR: Do they?

18 MR. KALATHIVEETTIL: It just determines if
19 you need a trip or -

20 MEMBER STETKAR: It - don't use the word
21 trip because some people use the word trip as
22 synonymous with reactor trip. Use some other word
23 like - you'd say meets a protection system criterion
24 or something like that.

25 MR. BETANCOURT: We call that a channel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 drip and then we have two channels to a unit.

2 MEMBER STETKAR: Some people use the term
3 trip interchangeably with the words reactor trip.

4 MR. BETANCOURT: They are incorrect.

5 MEMBER STETKAR: It exceeds a set point.

6 MEMBER BROWN: It exceeds a set point.

7 That's a better way of phrasing it. It determines
8 whether it sees a set point or not and it passes that
9 information on.

10 VICE CHAIRMAN CORRADINI: I think the
11 members have had enough fun. Let's go.

12 MR. KALATHIVEETTIL: So as I was saying,
13 the CM is to control, collect and transmit information
14 between other HIPS modules and/or external components
15 from the platform. This module includes an FPGA as
16 well as analog components.

17 The purpose of the EIM is to provide final
18 equipment actuation output. This module includes
19 analog priorities logic circuitry on the board used
20 for automatic and manual actuation inputs.

21 This module as well includes FPGA and
22 analog components. The hardware module is used to
23 convert hardwired contact inputs into logic-level
24 signals to make them available on the back plane of
25 the chassis and its platform.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This module, however, only has analog
2 components.

3 All right. Scope of the review. The
4 scope of the staff's evaluation was a top-down review
5 approach as based on the fundamental I&C design
6 principles of independence, redundancy, predictability
7 and repeatability and, finally, diversity and defense
8 in depth.

9 These principles are outlined in the DSRs
10 for NuScale. This is the first time that the staff
11 used NuScale DSR's Chapter 7 to perform a review of
12 the topical report.

13 The design principles apply regardless of
14 the technology. These principles work hand in hand to
15 ensure that the safety functions will be accomplished
16 when needed. That is, that a design should
17 demonstrate compliance with all of them and not one
18 versus another one.

19 We also spent quite some time reviewing
20 the platform capabilities on calibration, testing and
21 diagnostics. The HIPS platform includes features to
22 detect and monitor the system's performance during
23 operation and to initiate alarms if the system fails
24 to perform deterministically and within the required
25 time frame.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Regulatory conformance - the staff finds
2 that the HIPS platform design supports meeting the
3 applicable regulatory requirements associated with the
4 fundamental I&C design principles.

5 The scope of the staff's review also had
6 65 ASAI's which have been established of which 55 are
7 proposed by the applicant and the staff added an
8 additional 10 of them to the list. The staff review
9 does not address quality assurance nor equipment
10 qualification because these are application-specific
11 activities that depend on the equipment vendor used to
12 implement the HIPS platform.

13 For those two aspects, the staff has
14 established ASAI's, which are application-specific
15 action items, for the users of this platform to
16 demonstrate that the HIPS platform QA processes is
17 complying with 10 CFR Appendix B and that the
18 equipment is qualified with the applicable EQ
19 requirements.

20 The staff was also able to review the
21 provisions for secure development in operational
22 environment, SDOE, at the platform level.

23 However, for the system level aspects of
24 SDOE the staff has established ASAI's to demonstrate
25 compliance with IEEE 603 clause 5.9.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The MWS, which is the maintenance work
2 station, and the PS, which is the protection system,
3 is already included to support the discussion on
4 monitoring indication testing and calibration.

5 That's pretty much what I have for the
6 open portion. So if you have any questions?

7 VICE CHAIRMAN CORRADINI: Do members have
8 any other further questions? I am sorry. John?

9 MEMBER STETKAR: I have one. One of the -
10 we had some discussion about - a little bit - in the
11 Subcommittee.

12 There is one of the ASAIs that says - it's
13 number 21 if you want to look it up in Table 4-1 - an
14 applicant or licensee referencing this SC must provide
15 redundant power sources to separately supply the
16 redundant power conversion features within the HIPS
17 platform.

18 We had some discussion about what the
19 staff's intent with the word redundant was in a
20 licensing situation and those words haven't changed.
21 Apparently, you decided there wasn't any need for any
22 further clarification of that.

23 MR. BETANCOURT: That's correct.

24 MEMBER STETKAR: And in the closed session
25 we can get into more details about different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interpretations of redundant. You looked at it and
2 you decided no further clarification was needed.

3 MR. BETANCOURT: Right. At this time.
4 Right.

5 MEMBER STETKAR: Okay. Thank you.

6 VICE CHAIRMAN CORRADINI: Other questions
7 from the members? Okay. What I want to do now is I
8 want to go to the - ask if anybody in the - in the -
9 here in the room wants to make a public comment and
10 can we please have the phone line open so that if
11 there is somebody on the phone line can make a public
12 comment. We seem to have a --

13 Thank you. Is anybody on the phone line?
14 Please acknowledge that you're there. Anyone?

15 MS. FIELDS: Yes.

16 VICE CHAIRMAN CORRADINI: Okay. Is that -
17 if you'd please identify yourself and give us your
18 comment.

19 MS. FIELDS: This is Sara Fields with
20 Uranium Watch in Utah. I did have a question of how
21 the approval of these various topical reports, which
22 in fact are generic, how they fit into the approval -
23 the overall design rule making approval specifically
24 for NuScale. Is this part of the - I mean, how does
25 that work? I mean -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN CORRADINI: So - so let me -
2 let me try to not answer your question directly but
3 give you the resource.

4 So Ms. Christina Antonescu from our staff,
5 you can communicate with her and she can get to your
6 question. We really take comments on the record now,
7 not questions. We will answer the question
8 appropriately after the fact and then you can get
9 copies of the view graphs. Does that help you?

10 MS. FIELDS: Thank you.

11 VICE CHAIRMAN CORRADINI: You're welcome.
12 Is anybody else on the public line that wants to make
13 a comment?

14 Okay. Hearing no one else, can we please
15 close the public line? Close the public line
16 completely. Let's go to closed session. I'd ask
17 staff and NuScale to please look in the room.

18 Make sure everybody in the room is either
19 from NuScale or they are associated contractors or NRC
20 and their associated contractors.

21 (Whereupon, the above-entitled matter went
22 off the record at 1:55 p.m. and resumed at 3:14 p.m.)

23 CHAIRMAN BLEY: The meeting will come to
24 order. At this time I will turn it over to Mr.
25 Skillman to lead us through the subsequent license

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 renewal presentation.

2 MEMBER SKILLMAN: Mr. Chairman, sir, thank
3 you.

4 Ladies and gentlemen, today we are here to
5 talk about subsequent license renewal. To date 87
6 plants in this country have had their licenses renewed
7 using a currently understood license renewal process.
8 Within the next 24 months the NRC will receive two
9 applications from two applicants that will apply to
10 extend from 60 to 80 years licenses for those plants,
11 and it's conceivable that over the course of the next
12 5 or 6 years there may be as many as 7 more plants
13 applying for this renewal. That is for 20 on top of
14 60.

15 And so we are here to talk about life
16 beyond 60, subsequent license renewal, and the
17 processes that the DLR has created and the documents
18 DLR has created for this process. And for this, I
19 will call on George Wilson to please lead us through
20 the process.

21 MR. WILSON: Thank you and good afternoon.
22 I am George Wilson, the Director of the NRR's Division
23 of License Renewal. Beside me is Joe Donoghue, my
24 deputy, who just started Monday.

25 We met with the ACRS Subcommittee on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 License Renewal three weeks ago. The meeting went to
2 Subcommittee focused on the changes we made from our
3 draft Subsequent License Renewal Guidance published
4 for public comment for the final guidance document
5 step we are proposing for publication in July.

6 The meeting today will focus on the final
7 Subsequent License Renewal Guidance Documents. These
8 draft guidance documents include the Generic Aging
9 Lessons Learned for Subsequent License Renewal, being
10 called GALL-SLR. The Standard Review Plan for Review
11 of Subsequent License Renewal for Nuclear Power
12 Plants, which we will now call SRP-SLR. And as I
13 stated earlier, we plan on publishing these documents
14 in July.

15 Today we will also brief you on an effort
16 within the division to evaluate the subsequent license
17 renewal application review process and develop
18 recommendations on how to make this process more
19 efficient and effective.

20 I'll now turn the presentation over to
21 Steve Bloom.

22 MR. BLOOM: Thank you, George, and thank
23 you to the members of the ACRS Committee. As he said,
24 my name is Steve Bloom. I'm the Branch Chief in
25 charge of the Subsequent Renewal Guidance And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Operations Branch in the Division of License Renewal
2 in the Office of Nuclear Reactor Regulation.

3 Today Dr. Allen Hiser will brief you on
4 development of our Subsequent License Renewal Guidance
5 Documents and the most significant technical changes
6 in our guidance documents from those that were in the
7 guidance documents which were for the initial license
8 renewal. Then Billy Rogers will discuss this
9 optimization of the SLR application review process.

10 As I previously discussed with Mr.
11 Skillman, we look forward to receiving the letter
12 after this meeting and/or in the near term.

13 I now turn over to Dr. Hiser.

14 DR. HISER: Good afternoon. Before
15 discussing the guidance documents for subsequent
16 license renewal I will provide a brief background on
17 how we've arrived to this point with the final
18 documents for SLR.

19 In the first bullet, the governing
20 regulation for license renewal is Part 54 of Title 10
21 of the Code of Federal Regulations, the License
22 Renewal Rule. With most plants having received their
23 new licenses to operate from 40 to 60, the question of
24 extending licenses to 80 years was raised by industry
25 about a decade ago. This is actually contemplated in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Part 54. Part 54.31(d) states that a renewed license
2 can be subsequently renewed and it doesn't give a
3 limit. So it just says you can renew, subsequently
4 renew licenses.

5 Beginning in 2011 the staff began to
6 consider the review that would be appropriate for
7 subsequent license renewal application and proposed
8 several options for changes to the License Renewal
9 Rule in a paper to the Commission in 2014. Although
10 the Commission did not approve the staff's proposal
11 for rulemaking, the Commission in part directed the
12 staff to address some merging technical issues in
13 operating experience through, in part, updates to the
14 License Renewal Guidance Documents.

15 In December of 2015 the staff issued for
16 public comment the draft Guidance Documents for SLR,
17 as George Wilson mentioned, the GALL-SLR and SRP-SLR.
18 The public comment period ended in February 2016.
19 Since that point the staff has been reviewing public
20 comments. We have held numerous public meetings and
21 we've worked to develop the final guidance documents
22 we are here to discuss today. At this point these
23 final guidance documents are ready for issuance.

24 Next slide. Now, the Commission SRM
25 regarding the staff paper on rulemaking proposals for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Part 54 directed the staff to keep the Commission
2 informed on the progress in resolving several
3 technical issues related to subsequent license
4 renewal, specifically the four items that are listed
5 on this slide. I will speak more on how we have dealt
6 with these issues in the guidance documents over the
7 next few slides.

8 Overall, industry is responsible for
9 developing the technical basis to demonstrate the
10 aging effects for these issues and other technical
11 issues will be managed for subsequent license renewal.
12 For those aspects of these technical issues that are
13 not fully resolved on a generic basis, applicants for
14 subsequent license renewal will need to address these
15 issues on a plant-specific basis.

16 Next slide. Now, ACRS reviews have been
17 a very important part of the staff's work in
18 subsequent license renewal going back to early 2014
19 just after issuance of the Commission paper by the
20 staff. This interaction has included both Sub and
21 Full Committee meetings, and one meeting about a year-
22 and-a-half ago addressed the status of research on the
23 subsequent license renewal technical issues that were
24 identified by the Commission.

25 Next slide. Dating back to the original

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 issuance of the License Renewal Rule in 1991, the NRC
2 identified several key principles for license renewal
3 that underpin the adequacy of the regulatory framework
4 for license renewal.

5 The first one is that the regulatory
6 process, the current ongoing regulatory process
7 ensures that the current licensing basis for each
8 plant provides and maintains an adequate level of
9 safety. There's one caveat to that: except for the
10 effects of aging on long-lived passive systems
11 structures and components.

12 In addition, each plant's licensing basis
13 must be maintained during the license renewal
14 operating period, as it has been throughout all of
15 plant operation. Now, the one main provision again is
16 that there's additional focus on management of aging
17 effects of in-scope passive long-lived structures and
18 components.

19 Next slide. For the subsequent license
20 renewal operating period existing regulations and
21 processes ensure plant operation. First the process
22 that's laid out in the License Renewal Rule ensures
23 that passive long-lived structures and components will
24 continue to perform their intended functions during
25 the subsequent period of extended operation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In addition, the process that's laid out
2 in Part 54 for the review of subsequent license
3 renewal applications has a thorough review that
4 includes both environmental and safety reviews and use
5 of audits. Throughout all of plant operation there's
6 continuous verification of plant safety through
7 reviews by the NRC and through the implementation of
8 the reactor oversight process.

9 Next slide. Now, to implement subsequent
10 license renewal the staff has developed two main
11 guidance documents: the GALL-SLR and the SRP-SLR, as
12 mentioned by George earlier. These documents parallel
13 similar documents that we developed for license
14 renewal. The main difference is that the SLR
15 documents are applicable for aging from 60 to 80
16 years, whereas the license renewal documents were for
17 40 to 60 years.

18 Now, the GALL-SLR as in -- similar to the
19 GALL report, provides a generic evaluation of aging
20 effects that need to be managed and provides
21 appropriate generic aging management programs to do
22 this aging. Now, plants are always free to propose
23 their own alternatives, but they have to have
24 sufficient justification for those, and they will be
25 reviewed by the staff on a detailed basis. Now, well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the GALL-SLR report document is geared towards use by
2 applicants, the SRP-SLR provides guidance to the staff
3 for its review of subsequent license renewal
4 applications.

5 Next slide. Now, in order for plants to
6 operate for 60 to 80 years, or during the subsequent
7 period of extended operation, we need to determine the
8 aging effects that could occur during the operating
9 period out to 80 years. Now, this conclude no
10 mechanisms that are found in new locations or are
11 found to be more severe than previously identified
12 possibly due to exceeding incubation times or
13 activation energies that govern the mechanism.
14 Further, there may be new phenomenon that induce
15 aging. And these are an additional concern for us.

16 Now, because we only have plant operation
17 that extends to less than 50 years, we can't utilize
18 operating experience alone to determine the aging
19 issues that we will need to -- the plants will need to
20 manage for 80 years. So we needed to use some
21 additional information sources.

22 Now, to do this we formed subsequent
23 license renewal expert panels from staff in the Office
24 of Nuclear Reactor Regulation and the Office of
25 Nuclear Regulatory Research beginning in about 2014.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 These panels reviewed and deliberated on information
2 that was provided from various sources.

3 The first item listed on the top there was
4 that we reviewed the information from the Expanded
5 Materials Degradation Assessment in which NRC,
6 industry and international experts identified the
7 areas that were believed to be the most challenging
8 for subsequent license renewal.

9 In addition, we reviewed reports from
10 audits that we performed at several plants that had
11 operated for several years into the period of extended
12 operation. These audits were intended to qualitative
13 assess the effectiveness of the implementation and to
14 identify any unexpected aging phenomena that the
15 plants had found during their inspections.

16 These audits reviewed all of the AMPs
17 implemented at the plants including those implemented
18 on a one-time basis that are used to ensure
19 effectiveness of preventive programs such as water
20 chemistry programs, as well as AMPs that are
21 implemented on a periodic recurring basis. In
22 addition, we reviewed operating experience from both
23 domestic and international plants. And finally, we
24 considered comments that we collected during public
25 meetings on SLR, as well as comments from the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Next slide. In the next several slides I
2 will describe some of the refinements in the GALL-SLR
3 and the SRP-SLR as compared to Revision 2 versions of
4 the GALL and SRP that we use for license renewal.
5 This is a little bit different from the Subcommittee
6 meeting where we focused on the differences between
7 the four comment versions of the reports and then the
8 final version. So this is a little more expansive.

9 Two new aging management programs are
10 included in the GALL-SLR report. One program that
11 addresses fluence monitoring of the reactor pressure
12 vessel and the reactor vessel internals as applied to
13 both time-limited aging analyses and aging management
14 review for the vessel and internals. This new program
15 provides a consistent generic approach for existing
16 plant programs that are used to monitor neutron
17 fluence.

18 In addition, a new program to manage aging
19 of high-voltage insulators is included in the GALL-SLR
20 report. Previously these insulators were addressed in
21 license renewal as a further evaluation item, but the
22 inclusion of the new AMP provides a generic aging
23 management approach in lieu of the previous treatment
24 on a plant-specific basis by each individual
25 applicant. This new AMP is an example of our use of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lessons learned from review of prior applications to
2 improve the efficiency of the applicant's development
3 of its subsequent license renewal application and also
4 the staff's review of the application.

5 Aging management for reactor vessel
6 internals of PWR, or pressurized water reactors, is a
7 challenging area. The aging management program for
8 the license renewal period in the GALL report utilizes
9 as its basis an industry report that addressed
10 conditions for license renewal at 60 years of
11 operation. This program uses a sampling approach to
12 inspect the components that are the leading indicators
13 for degradation; for example, those that maybe have
14 the highest neutron fluence or stress levels.

15 In the absence of a similar review to
16 address the conditions relevant to 80 years of
17 operation as needed for subsequent license renewal,
18 which the industry has indicated it will submit in
19 2020, the aging management program and the GALL-SLR
20 report state that applicants may use their existing
21 program for 60 years as long as they supplement the
22 program with gap analysis to identify the additional
23 aging management activities, if any, that would be
24 necessary to ensure adequate aging management for 80
25 years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The Reactor Vessel Surveillance Program is
2 intended to give an early indication of the
3 embrittlement trends for the reactor vessel due to
4 neutron irradiation and to ensure that the plant is
5 operated with appropriate safety margins against
6 vessel failure. The guidance for subsequent license
7 renewal states that plants should test the
8 surveillance capsule which bounds the expected neutron
9 fluence for 80 years. This capsule may have been
10 tested previously by the plant. It may be a capsule
11 that is currently scheduled for testing at an adequate
12 neutron fluence under the plant's current renewed
13 license or it may be a standby capsule that is
14 designated for testing at a sufficiently high neutron
15 fluence.

16 However, the guidance also notes that it
17 is not acceptable to redirect or postpone the
18 withdrawal and testing of a surveillance capsule
19 intended for license renewal in order to achieve a
20 higher neutron fluence needed for subsequent license
21 renewal. The next slide will illustrate this note.

22 Next slide. Now, illustrated are the
23 surveillance capsule statuses for two plants for the
24 license renewal period up to 60 years. Now, for each
25 figure the X axis is the date, either when the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 started or when the plant will exceed 60 or 80 years
2 of operation, and the Y axis is the neutron fluence.
3 So the vertical lines and horizontal lines indicate
4 the dates and approximate fluence levels,
5 respectively, for 60 and 80 years of plant operations
6 in blue and orange, respectively.

7 So for example, for 60 years the plant on
8 the left the neutron fluence that would be of interest
9 for the vessel is a little bit less than 6 times 10 to
10 the 19th neutrons per centimeter squared. For 80
11 years of operation it would be about 7.5 times 10 to
12 the 19th.

13 Now, the filled circles on each figure
14 indicate the withdrawal date and neutron fluence level
15 for the capsules that each plant has tested. For the
16 license renewal period of 60 years at least one data
17 point is desired to be above the blue horizontal line.
18 For the SLR operating period of 80 years at least one
19 data point should be above the orange fluence line.

20 MEMBER MARCH-LEUBA: I don't understand
21 the figure. Let me see if I -- the horizontal line is
22 the average fluence for the whole vessel and the black
23 dot is the fluence for the sample, which is higher?

24 DR. HISER: Yes.

25 MEMBER MARCH-LEUBA: Because -- that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what it is?

2 DR. HISER: Yes. Yes, the --

3 MEMBER MARCH-LEUBA: Okay. So the samples
4 are receiving higher fluence than the rest of the
5 vessel?

6 DR. HISER: The samples are located inside
7 of the vessel, so they may be in capsules that are
8 attached to the wall, they may be on the thermal
9 shield.

10 MEMBER MARCH-LEUBA: So the sample that
11 they received on the left one at 2010 is equivalent to
12 2030 when the 60-year life --

13 DR. HISER: That's correct.

14 MEMBER MARCH-LEUBA: I understand. I
15 understand.

16 DR. HISER: Yes, so the lead factor for
17 that capsule would be about 1.5.

18 MEMBER KIRCHNER: But for SLR they'd have
19 to test one more capsule, right?

20 DR. HISER: Right. And so for the plant
21 on the left --

22 MEMBER KIRCHNER: Yes.

23 DR. HISER: -- you can see the five data
24 points. They're fairly well spaced both in fluence
25 and time. So that was a very well organized program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: But it assumes that they
2 have another capsule in there?

3 DR. HISER: Right, this plant also has a
4 capsule. So it has one. It's still in the vessel and
5 the plant has stated that they will withdraw that
6 capsule when it exceeds the fluence for 80 years. So
7 they will put that in storage. If they choose to come
8 in for subsequent license renewal, then they will go
9 ahead and test that capsule.

10 MEMBER MARCH-LEUBA: And Plant B, why did
11 the fluence went down? They move the sample?

12 DR. HISER: The capsules are located in
13 different locations.

14 MEMBER MARCH-LEUBA: But it's not the same
15 capsule? Okay.

16 DR. HISER: Right. Yes, so it had a
17 different lead factor. In the case of Plant B, four
18 capsules have been tested. The fifth capsule was
19 actually in the renewed license. They were allowed to
20 delay withdrawal of that capsule until it achieved a
21 fluence equivalent to the 60-year fluence, or that
22 exceeds the 60-year fluence. So the one provision in
23 the program for SLR is that that plant could not
24 continue to take that point and push it out further.

25 In this case we believe that the fluence

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gap between the data that's available now and say
2 going out to 80 years would just be too much. We need
3 -- they need to have a data point. So that 60-year
4 capsule will be tested in -- I don't know, that's
5 maybe about 2025, something like that. So in about
6 eight years they will have the data for 60 years.

7 This plant then also has three other
8 untested capsules. They lead factor is not as high as
9 for Plant A, so they will need to remain the vessel
10 longer to get the 80-year fluence. But we would
11 expect that if this plant comes in for subsequent
12 license renewal that they would propose to withdraw
13 one of those capsules to achieve that fluence and
14 generate the data that they need.

15 Okay. Next slide. Now one program on
16 aging management of electrical cables that are
17 inaccessible, that are underground and not subject to
18 environmental qualification requirements, was expanded
19 into three AMPs to address aging of submerged cables
20 at different voltages. And this would include low and
21 medium voltages along with instrument and control
22 cables. This change was made to address the
23 differences in both the aging effects and testing for
24 the three types of cables.

25 For concrete we have made changes to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance to address aging management of alkali-silica
2 reaction, which you may have heard about, and also
3 irradiation of concrete, both of which are covered by
4 further evaluations that require plant-specific
5 attention in the GALL as are actually in I guess in
6 the SRP-SLR document. For alkali-silica reaction the
7 further evaluation identified in Revision 2 of the
8 GALL report for license renewal was updated to include
9 recent operating experience.

10 A new further evaluation on irradiation of
11 concrete provides a means for applicants to identify
12 plant-specific conditions that would indicate either
13 a need for aging management or would provide a
14 technical basis for concluding that irradiation of
15 concrete is not a relevant aging issue for the plant.

16 MEMBER POWERS: What are you looking for
17 there?

18 DR. HISER: What are we looking for?

19 MEMBER POWERS: Yes.

20 DR. HISER: I think maybe I will phone a
21 friend in the audience.

22 (Laughter.)

23 DR. HISER: Angie, can you -- yes, maybe
24 Angie can speak to that.

25 MS. BUFORD: This is Angie Buford with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff. The irradiated concrete further evaluation is
2 looking at the fluence and how much fluence gets to
3 the concrete and then the plant will have a plant-
4 specific analysis to identify whether there is
5 degradation that would impact the structural intended
6 function for the bio-shield area and also for the
7 support for the vessel depending on the layout of the
8 plant.

9 MEMBER POWERS: Well, I'm struggling to
10 understand what radiation damage could occur.

11 MS. BUFORD: I couldn't hear that
12 question.

13 MEMBER POWERS: I'm struggling to
14 understand what radiation damage could occur in the
15 concrete that would lead to substantial structural
16 degradation.

17 MS. BUFORD: Well, the neutron and gamma
18 radiation has an effect on the aggregates, potentially
19 an expansive effect that is currently undergoing
20 research in both NRC confirmatory research and also in
21 industry to determine what effect on the strength
22 capacity that expansion in the aggregates would have.

23 MEMBER POWERS: That's for sure true that
24 your irradiation, especially your radiation is going
25 to do -- cause atomic displacements with almost ipso

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 facto mean an expansion. Do you really think you get
2 into a regime where that would be enough to -- I mean,
3 the pour structure of the concrete is fairly
4 forgiving.

5 MS. BUFORD: What was the question? I'm
6 sorry.

7 MEMBER POWERS: Do you really think that
8 you get enough expansion of the aggregate to overwhelm
9 the plasticity --

10 MS. BUFORD: The crystalline structure?

11 MEMBER POWERS: -- of the gel water?

12 MS. BUFORD: And that's a question that's
13 under research right now. The research just isn't far
14 along enough to know --

15 MEMBER POWERS: Who's doing that?

16 MS. BUFORD: EPRI. I would probably want
17 industry just to make sure that they agree with me,
18 but I believe EPRI is undergoing research. Various --
19 NEI is sponsoring research and so is DoE. We have --
20 there's a joint consortium of NRC, DoE, EPRI and NEI
21 that meets regularly to discuss who's doing what in
22 terms of the research, but right now there's just not
23 enough research to conclude that there is -- how much
24 fluence actually gets to the concrete. And then once
25 we determine how much fluence gets to the concrete,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then you need to analyze to determine whether your --
2 a limiting stress area -- whether that -- the
3 expansion in the aggregate would even matter.

4 So the research is not far along enough
5 yet, which is why in the GALL -- the SRP-SLR there's
6 a further evaluation that we plan -- are going to have
7 to perform a plant-specific analysis to look into
8 this.

9 MEMBER POWERS: I'm just not sure what
10 they would analyze for.

11 DR. HISER: Well, there is available data
12 that indicates that the performance of the concrete
13 degrades as you irradiate it to higher fluences.

14 MS. BUFORD: Well, yes, but there -- but
15 right now there's not enough data to understand how
16 much fluence the concrete is actually seeing. So if
17 it's 10 to the -- 1 times 10 to the 19th, is that much
18 actually getting to the concrete? And if it is, does
19 that affect the strength or intended function of the
20 concrete?

21 And also what are the limiting areas of
22 concern? Is it right outside the belt line where
23 maybe the -- maybe it's not of concern there. Maybe
24 it's there's more of a concern for support structures,
25 which would see less fluence, and depending on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 configuration of the plant. So that's why right now
2 it's really a plant-specific analysis to even
3 determine whether it's an issue. We have enough
4 understanding right now that we don't believe for BWRs
5 that this would be a concern. Right now it's the
6 really the two-loop, three-loop plants that are really
7 engaging in most of the research.

8 MEMBER POWERS: I would think the biggest
9 concern would be activation in the aggregate. I think
10 -- I mean, cobalt-60.

11 MS. SIRCAR: Yes, can I add a few words to
12 Angie? Already there is some scoping -- oh, sorry.
13 I'm Madhumita Sircar and I work in Office of Research
14 and supporting NRR DLR, this particular topic of
15 research.

16 We -- as Angie correctly mentioned that
17 there is a joint road map between -- among NRC, EPRI
18 And DoE. The initial scoping study says that the
19 concrete start degrading at the fluence level of 1
20 into 10 to the 19, energy level 0.1 MeV and higher.
21 And fluence -- estimated fluence for 80 years is more
22 than 6 into 10 to the 19.

23 Current knowledge is very old, which is
24 from '70s, and also not very relevant to LWSR plants.
25 So with that knowledge there's a huge knowledge gap

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and the earlier knowledge shows that from 20 into 10
2 to the 19, or even before that, the concrete
3 compressive strength, the side strength, the modulus,
4 modulus of elasticity degrades. And there is also the
5 effect of gamma and thermal. And this expands. The
6 interfacial zone between the aggregates and cement
7 gets affected. Cement paste cracks because of
8 moisture transportation, temperature accumulates. So
9 all these things are there and it's already
10 established that concrete starts degrading after one
11 into 10 to the 19 and the expected fluence is 6 into
12 10 to the 19, energy level 0.1 MeV.

13 DoE is doing the material degradation
14 study and EPRI is doing the more applied side of it,
15 How the structural significance will be, and NRC is
16 doing the confirmatory study. And if there is a need
17 for collaboration that will expedite the process, NRC
18 is also part of that.

19 DR. HISER: And one of the reasons this is
20 further evaluation for each plant to evaluate is that
21 the conditions vary in each plant. And so they need
22 to do their own fluence calculations to understand the
23 fluence that would be on their concrete.

24 MS. BUFORD: Yes, I just wanted to
25 highlight that. Right now they're still determining

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whether the concrete itself would see that fluence.

2 MEMBER POWERS: I would think --

3 (Simultaneous speaking.)

4 MS. SIRCAR: -- see that because there is
5 no question about it. The concrete is going to see 1
6 -- 6 into 10 to the 19 energy level greater than 0.1
7 MeV. And the degradation threshold is by the exports
8 in this field they have fixed that threshold value as
9 1 into 10 to the 19th. So it's much higher than that
10 degradation starting point. And most all BWR plants
11 will see that much earlier than 80 years.

12 MEMBER POWERS: I would think that --

13 MS. SIRCAR: But the layout and the
14 overall aspect, if we consider, probably some plants
15 may be excluded and EPRI is doing that study. So the
16 plants that will be mostly affected are Westinghouse
17 two-loops and three-loops and particular type of
18 structure which has two types of support under the
19 nozzles directly on the sheet 1.

20 And the other aspect is concrete
21 constitution. Like what kind of aggregate is being
22 used in that concrete is very important. Not all
23 aggregates are susceptible to that. So it's a
24 combination of many factors, and research is ongoing.

25 DR. HISER: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Thank you.

2 DR. HISER: Next slide. Now we've -- most
3 of the changes I talked about on the prior two slides
4 related to the GALL report. I just wanted to hit some
5 of the changes to the SRP. As we've talked a little
6 bit about further evaluations we've been able to
7 eliminate some of the plant-specific further
8 evaluations which require substantial applicant
9 resources and also staff review resources so that they
10 point to a generic AMP to manage the aging effects.

11 So this takes a further evaluation, plant-
12 specific item to something that's consistent with
13 GALL. And so it's a much easier review by the staff.
14 And that would be based on having reviewed these items
15 for multiple plants and having find the generic AMP to
16 be acceptable.

17 For the second item the staff has
18 identified AMR -- or has added AMR items, aging
19 management review line items to the GALL-SLR that we
20 previously found to be acceptable in multiple
21 application reviews. This enables plants to identify
22 items that's consistent with GALL, thereby reducing
23 their burden in justifying an item that would
24 otherwise not be consistent. And it also reduces the
25 staff's review burden.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 With an SRP-SLR we broadened Section 4.3
2 on metal fatigue to provide guidance in other areas
3 such as flaw growth analyses that applicants may have.

4 MEMBER POWERS: So as what?

5 DR. HISER: Flaw growth analyses that may
6 have an aging effect associated with those. Stress
7 corrosion cracking, fatigue or may have irradiation
8 effects on the material properties.

9 Finally, in Section 4.7 of the SRP-SLR
10 we've added a table to list common plant-specific
11 time-limited aging analyses. These would be things
12 like leak before break that many plants have. And
13 also crane fatigue would be a couple of examples.

14 Next slide. Now we've also added a new
15 chapter on technical specification changes and
16 additions to the SRP-SLR. And this would be any
17 change to the tech specs or additions that are needed
18 to address aging management. Examples on this would
19 be testing requirements for fuel oil used for
20 emergency diesel fuel storage tanks that may be in the
21 tech specs. If they need to be changed because of the
22 AMP for diesel fuel oil, then that would have to be
23 addressed by the applicant and reviewed by the staff.
24 And also pressure temperature limits for the reactor
25 pressure vessel. If they're in the tech specs, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would require a tech spec change, potentially.

2 In addition, we've added a new Appendix
3 A.4 to the SRP-SLR which provides more detail on the
4 use of operating experience to maintain the plant's
5 aging management programs as true living programs.

6 MEMBER POWERS: Future operating.

7 DR. HISER: Future. Yes. So this is
8 intended to highlight the use of aging management as
9 a threshold for future evaluation of both plant-
10 specific and industry operating experience and
11 describes periodic assessments of the effectiveness of
12 AMPs as an important element of maintaining the aging
13 management programs. In addition, we've added more
14 detailed summary descriptions for the final safety
15 analyses report SLR supplement. So this would be for
16 AMPs, for TLAAs, for example.

17 Next slide. The guidance documents for
18 subsequent license renewal provided means for
19 applicants to develop adequate programs and for the
20 staff to review subsequent license renewal
21 applications. Most of the relevant aging issues are
22 addressed by generic aging management programs as
23 we've discussed the last few slides. For a few
24 remaining issues the guidance documents identify
25 further evaluations for the applicants to identify and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 justify their plant-specific proposals to manage the
2 aging effects.

3 In all cases applicants have the
4 responsibility to ensure that they've identified the
5 relevant aging issues for their plants, appropriate
6 aging management activities and adequate justification
7 for their programs. With the completion and issuance
8 of these guidance documents NRC is prepared to review
9 subsequent license renewal applications.

10 Next slide. Now, this slide just provides
11 an overview of the remaining schedule for issuance of
12 the SLR guidance documents and the receipt of two
13 announced subsequent license renewal applications. As
14 indicated, in about two -- three weeks we have a
15 Commission meeting on subsequent license renewal.
16 Following that meeting we expect in July that we will
17 issue the final GALL-SLR report and the SRP-SLR. By
18 the end of this year we should issue NUREGs that
19 describe the technical bases and resolution of public
20 comments. And as listed there, 2018, we expect an
21 application from Peach Bottom. 2019 we expect to have
22 an application from Surry. Those are two announced
23 applications.

24 MEMBER SKILLMAN: Allen, let me ask you to
25 take a deep breath right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. HISER: Sure.

2 MEMBER SKILLMAN. Stand by. And I want to
3 communicate to my colleagues we're about to change
4 channels. What Allen presented are the technical
5 details regarding the documentation that will be used
6 for subsequent license renewal, specifically three
7 documents: the two volumes of GALL and the review
8 plan.

9 What we're going to talk about next are
10 program changes. And it's a somewhat different topic
11 because it has to do with process for a license
12 renewal for 60 years to 80 years.

13 So, colleagues, do you have any questions
14 on the documentation or the technical details that
15 Allen just presented, please?

16 MEMBER RICCARDELLA: Just out of
17 curiosity, is Surry one of those two plants, Plant A
18 or Plant B, that you presented?

19 DR. HISER: I don't know.

20 (Laughter.)

21 DR. HISER: A colleague put those two
22 slides together, and I'm not sure which plants she
23 selected for that.

24 MEMBER BALLINGER: Probably match the
25 dates.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. HISER: I guess one could do that. We
2 may have provided enough information there. Clearly
3 what we wanted to convey was one program that had
4 sufficient capsules and had withdrawals and tests.
5 The other is one that we just don't want them to push
6 that capsule out another 20 years.

7 So with that, I will turn it over to Billy
8 Rogers.

9 MEMBER SKILLMAN: Thank you.

10 Bill, go ahead.

11 MR. ROGERS: Thank you. This is just on
12 SLR optimization. My name is Bill Rogers. I'm a
13 staff member in the Division of License Renewal.

14 Pardon me. Pardon me. So this is a
15 presentation on SLR optimization. My name is Bill
16 Rogers. I'm a staff member in the Division of License
17 Renewal and today I will discuss the purpose of the
18 Subsequent License Renewal Optimization Working Group
19 and an overview of its activities, communications with
20 utilities and stakeholders and several of the staff's
21 recommendations.

22 Okay. Next slide, please. Thank you.
23 The Division of License Renewal established the
24 Subsequent License Renewal Optimization Working Group
25 to evaluate the subsequent license renewal application

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review process. The evaluation was performed in order
2 to develop recommendations as to how the review
3 process could be made more efficient and effective and
4 to optimize the staff's performance relative to
5 timeliness, application of staff resources and the
6 quality of products.

7 The working group evaluation consisted of
8 or considered both safety and environmental, project
9 management tools, audits and inspections, safety
10 evaluation reports and the subsequent license renewal
11 application, the SLRA, review time line. The working
12 group presented proposed staff position to industry
13 and stakeholders during several public meetings and
14 considered the comments received.

15 I'd like to discuss several of the
16 proposed recommendations that impact the staff,
17 utilities and would be of interest to stakeholders and
18 the Committee.

19 Slide, please. Okay. So concerning the
20 SLRA review time line, after completion of the
21 working group evaluation for both the safety and
22 environmental review the staff developed a subsequent
23 license renewal review timeline of 18 months, which
24 will begin at the completion of the staff's acceptance
25 review of the subsequent renewal application. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discontinuation of the routine use of a draft SER with
2 open items, which I'll discuss that momentarily, was
3 a primary contributor to the reduction of the staff
4 review timeline from 22 to 18 months.

5 So the staff intends to present a draft
6 final SER to the ACRS Subcommittee and a draft final
7 SER to the ACRS Full Committee, revised as necessary.

8 The staff concluded that the draft final
9 SER will provide a complete description of the
10 resolution of all technical issues to support the
11 staff's goal of increasing efficiency and
12 effectiveness when considering the time and resources
13 required to produce an interim SER with open items.

14 The staff is aware that the draft final
15 SER presented to the ACRS Subcommittee may require
16 subsequent revisions prior to presentation to the ACRS
17 Full Committee to incorporate any comments received.

18 MEMBER SKILLMAN: Bill, how much time did
19 you allow for that review and feedback by the
20 Subcommittee to inform the SER?

21 MR. ROGERS: So between the two Committee
22 meetings? Yes, we looked at that over a period of
23 time when we were doing the evaluation. It has flexed
24 a couple times and it's flexed between six weeks and
25 four weeks. And I think that the concept would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that depending on the nature of any comments we might
2 receive during the Subcommittee meeting that that
3 period could be adjusted to accommodate our response
4 to the comments.

5 MEMBER SKILLMAN: Is that process
6 acceptable under the current regulations? We speak --
7 the ACRS speaks as a Full Committee. We don't speak
8 as individual members in the Full Committee. The flip
9 side is when we're in the Subcommittee we're speaking
10 as individual members. So if you come into the
11 Subcommittee with a draft SER, call it final, we find
12 a handful of comments, those comments are really
13 comments by individuals, not from the Full Committee.

14 So my question is how has that important
15 feature of the ACRS business process been taken into
16 consideration by the staff? Remember, that we speak
17 as a Full Committee. In the Subcommittees we speak
18 only as individuals.

19 MR. ROGERS: Well, my impression is that
20 we would address the individual comments from the
21 Subcommittee to the extent necessary to prepare for
22 the Full Committee. But I think from past experience,
23 the amount of time to address those comments, it tends
24 to be on the quicker side and that we try to address
25 those immediately.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Yes, I would like to --

2 DR. HISER: Yes, I think the expectation
3 is that normally at the Subcommittee we have a list of
4 open items, so think that technically we're not quite
5 sure of the applicants -- that the applicant's
6 proposed aging management is sufficient, if you will.
7 And I think by coming to the Subcommittee with really
8 a completed package we will have been satisfied that
9 the applicant's proposals are acceptable and I think
10 we will then be able to present a more complete
11 message to the Subcommittee. Clearly any comments
12 from the Subcommittee that we need to go back and
13 reconsider, I mean, we will have to adjust our
14 timeline appropriately. I don't think we would -- we
15 would never try to rush the Full Committee meeting at
16 that point.

17 MEMBER SKILLMAN: Thank you. That's what
18 I was curious about. Thank you for answering that.

19 MR. ROGERS: So this relates to what you
20 just said. Considering that the draft final SER will
21 be presented at both the ACRS Subcommittee and Full
22 Committee, the staff would propose that the ACRS
23 Subcommittee and Full Committee be scheduled for
24 subsequent months, because during the conversation
25 that we just had I think we've addressed that there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 may be opportunities or occasions where that might not
2 occur.

3 MEMBER RICCARDELLA: I think the concern
4 though is more this -- allows some time after the Full
5 Committee meeting so that you can get our comments and
6 consider them before you have to get it finally
7 approved because the comments you get at Subcommittee
8 won't be official, so to speak.

9 MEMBER SKILLMAN: That's what I was just
10 trying to point to.

11 MEMBER RICCARDELLA: That's the point, I
12 understand.

13 MEMBER SKILLMAN: That's the point I'm
14 trying to make.

15 MEMBER RICCARDELLA: Which means you have
16 to have some time after Full Committee to address
17 comments.

18 MR. ROGERS: I don't think we've modified
19 that period of time in the timeline.

20 MEMBER RICCARDELLA: Steve, do you want to
21 weigh into this?

22 MR. BLOOM: Well, I just was going to
23 repeat -- I was actually going to say the same thing
24 Billy said, which is this was the time before the
25 Subcommittee to the Full Committee, but we did not do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anything to the timeline of waiting for the letter
2 from the Full Committee with or without any comments
3 from you, if we have to address those comments. We
4 did not touch that part of the schedule in any way.

5 So if there's a letter that's a very clean
6 letter, then that makes -- we'll just go forward. If
7 there are comments that come out of it, we'll have to
8 address those. And again, as Billy and Allen said,
9 that will adjust our schedule accordingly of how much
10 work we have to do to address those comments.

11 MEMBER RICCARDELLA: Okay. Fair enough.

12 MEMBER SKILLMAN: But this is all within
13 that 18-month window, though, right? So our meeting
14 better be like 16 months.

15 MR. ROGERS: If comments are sufficient
16 enough that we have to go back and do a lot more work,
17 then we will have to of course tell the applicant that
18 you are not -- we didn't have enough information based
19 on ACRS, and that will therefore make the schedule go
20 out longer than 18 months.

21 MEMBER SKILLMAN: Okay. Thank you.

22 DR. HISER: And I think one thing to
23 remember as well, the 18-month schedule assumes a very
24 high-quality application, a very responsive applicant,
25 a request for additional information, hopefully

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 minimal comments from ACRS on things that we need to
2 go back and reconsider or reevaluate. And so that 18
3 months is really best case scenario. Any other
4 elements that are not sufficient, the schedule will
5 have to move.

6 MEMBER SKILLMAN: Thank you. Let's
7 proceed.

8 MR. ROGERS: Okay. We'll move onto a
9 slide --

10 (Simultaneous speaking.)

11 CHAIRMAN BLEY: Billy, can I interrupt you
12 before you even get into this slide?

13 MR. ROGERS: Yes.

14 CHAIRMAN BLEY: I just want to raise a
15 couple points that maybe you can address as you go
16 forward. You don't need to answer them as I raise
17 them.

18 MR. ROGERS: Okay.

19 CHAIRMAN BLEY: At the Subcommittee
20 meeting we talked about some of the inspection areas
21 and a few of us got -- were a little surprised and
22 said we really counted on the results of the
23 inspection as we were doing the original license
24 renewal. You folks discussed some of the things that
25 might not make that the same, which is they have just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done inspection not long ago and then they're coming
2 with subsequent license renewal. There are lots of
3 other things.

4 But I went back and read those inspection
5 procedures a little bit and -- a couple points and
6 then I'll come up with a question for you to think
7 about later. If we go back to 71002, it has two areas
8 that were important in our thinking back then, and for
9 me may still be important. One is 71002 has a section
10 on material condition that must be consistent with the
11 claims of the application. Kind of makes sense to me.
12 And then it has a fairly extensive section on
13 operating experience and relating that to potential
14 extension.

15 71003 has no material condition
16 requirement for the inspections and it has -- the only
17 thing on operating experience is whether the licensee
18 updated the AMPs as a result of recent operating
19 experience.

20 Now at least to me it feels like when we
21 get out to the short period before -- and I guess
22 that's your Phase 1. Before we go into the subsequent
23 license renewal period of extended operation something
24 in 71003 ought to address the material condition being
25 consistent with the claims and the operating history

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the last time that was looked at up until that
2 point being an important part of that inspection. It
3 doesn't seem to me that those are. And from the way
4 you talked, I don't think it was intended to be there.
5 But it seems an important issue.

6 And when you -- if you've got a couple of
7 slides talking about these, you can wait until then to
8 talk about that, but right now I'm thinking I would
9 want to say something about those two areas: material
10 condition and operating experience.

11 MR. WILSON: No, and actually; this is
12 George Wilson, I'd like to address those. I used to
13 be a resident and a senior resident. So first let's
14 talk about the material condition.

15 The material condition of the plant is
16 evaluated every day that there's an NRC inspector on
17 the site. When I walk out into the plant, you're
18 looking at what is the material condition of the
19 plant? You're also -- that's part of the resident's
20 routine inspections, and when another inspector goes
21 out there.

22 Secondly, the resident inspectors read
23 every Corrective Action Program or document that goes
24 into the CAP program at a site and they evaluate that
25 and they bin it. So you get aging management insights

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 based on what's in those corrective action documents.

2 So the material condition, I want to
3 highlight, is looked at constantly. And I'm going
4 to --

5 CHAIRMAN BLEY: Before you pass that
6 one --

7 MR. WILSON: Go ahead. Sure.

8 CHAIRMAN BLEY: -- the requirement in
9 71002 -- and the same thing's true for operating
10 plants today, but before they came to 71002, it asked
11 that the material condition must be consistent with
12 the claims in the application. And that's where I was
13 coming from, that we ought to look -- it seems to me
14 that somewhere before you hit that second extended
15 period of operation, we ought to look back at what
16 those claims are. And from that point of view,
17 you've been looking at the material condition, but
18 does it really justify moving forward. And I'm not
19 sure how you pick that up --

20 MR. WILSON: Okay.

21 CHAIRMAN BLEY: -- if it's not included as
22 it was in 71002.

23 MR. WILSON: Right. So the second aspect
24 that I wanted to -- and I'm jumping a little bit ahead
25 on Billy, but to try to address your comments now, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 71003 inspections are broken down into four phases.
2 Something that's a little bit different in them than
3 just the 02 inspection also, as you read through them,
4 you would notice that there's actually a performance
5 portion of it, which actually is beneficial for us
6 because the NRC does a licensee's performance and then
7 based on the performance of the licensee we take
8 oversight actions or corrective actions. We can add
9 inspections or do more focused inspections in areas.

10 So let's run through the 71003 phases real
11 quick. Phase 1, which is done before the PEO period,
12 it's opportunistic, but it's always done. You
13 actually go look -- the refueling outage or two
14 refueling outages before a licensee goes in PEO -- and
15 I go into the inaccessible areas, the normally
16 inaccessible areas of the plant. You get a great
17 indication of the housekeeping of the material
18 condition that a licensee maintains when you go into
19 those normally inaccessible areas.

20 So the outcome of the Phase 1 inspection
21 done a refueling outage or two refueling outages,
22 along with the operating experience; and Billy will
23 get in here, and the aging management insights that we
24 actually garner from the different baseline inspection
25 procedures: equipment alignment, flood protection,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat sync; and Billy will go on them, we actually get
2 aging management insights through those that we take
3 that information along with the performance with the
4 licensee and the Phase 1, and there's a large, large
5 team inspection. The 02 -- the Phase 2 inspection
6 71003 is a very large team inspection.

7 Based on the overall performance of the
8 licensee in that inspection -- so let's say there was
9 a dual-unit site and the NRC was not satisfied with
10 Unit 1's overall evaluation of their aging management
11 programs. We would then talk with headquarters and
12 the regions would talk. And the Unit 2 would be
13 another very large team inspection to verify that
14 they've put corrective actions in place and corrected
15 and evaluated the concerns that we had brought up.

16 If we went to the first unit and we didn't
17 find anything, only maybe one little area, it only
18 might be one person instead of a team that would go
19 out on Unit 2 and focus that. The outcome also of the
20 Phase 2 inspection would lead into the Phase 3
21 inspection, which then if the licensee's performance
22 -- and these are actually programmatic reviews, so
23 they're actually looking at the AMPs and the program
24 as a whole -- we would then talk and potentially pull
25 that inspection up and do it earlier just to make sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the licensee was looking at that.

2 When those inspectors are going out and
3 doing those inspections, they're not only just looking
4 at the aging management programs. They're actually
5 looking at the material condition. The aging
6 management insights that we get -- and we've got some
7 examples, like containment liner degradation where the
8 concrete and the -- we picked up in some ISI
9 inspections. That's fed into that evaluation. Do we
10 need to go out and do that inspection early? Is the
11 material condition there? Let's -- and we've got some
12 examples at another site where the fire header just
13 zippered open. All right? So then we take that and
14 we feed that in the overall licensee's performance.
15 Then we take that action and tailor the programs for
16 that licensee.

17 One of the things Billy's also going to be
18 discussing is we're going to tailor the audits that
19 we're going to do that's going to address one of your
20 concerns based on when the plant got their original
21 license. Were they GALL, before GALL, GALL 1, GALL 2?
22 And also include the inspectors from the region and
23 the residents on those inspectors, use the insights.
24 There's always open constant communication between
25 headquarters and the residents and the inspectors that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do those sites. And during the yearly and semi-annual
2 evaluations with -- that the region has on the
3 licensee's performance that's evaluated.

4 So when you take the material condition
5 and you're looking at -- and I do understand your
6 point. I just wanted to show this is a lot more
7 robust. When it would come for like an SLR -- so like
8 for a license renewal, we would have looked at -- we'd
9 have did an AMP audit and the 02 inspection. By the
10 time we get an SLR submittal in from a licensee, I
11 would have did the 02 inspection, I would have did the
12 AMP audit for the license renewal, I would have did
13 the Phase 1 inspection of 03, I would have did the
14 Phase 2 inspection of 03. And then I would have --
15 that's before we'd get an SLR. Then I would be doing
16 a very robust audit including the inspectors. So five
17 looks would be done on the aging management programs
18 as a whole and specific AMPs for SLR.

19 So that is -- I'm just showing that the
20 robustness -- and they're looking at the material
21 condition, what it was supposed to be. How's it
22 degrading? Is it -- where it was. So that is
23 actually being addressed in the overall process and
24 how we're doing it. And we focus -- the performance
25 is the key in the 03 inspections because I'm focusing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it based on a licensee's performance. And you can --
2 and through those insights that I described you tailor
3 that.

4 So I understand your comment, but I think
5 it's being addressed more robustly over -- because
6 we're getting more run time on the overall look at
7 those programs and for the licensee.

8 CHAIRMAN BLEY: George, thanks.

9 MR. WILSON: I'm sorry to interrupt.

10 CHAIRMAN BLEY: That was a pretty thorough
11 explanation. I appreciate it. Thank you.

12 Billy?

13 MR. ROGERS: I'd like to just rephrase
14 that a little bit. In the Subcommittee meeting a
15 number of us were concerned that the inspection, the
16 final inspection, if you will, prior to subsequent
17 license renewal would take place during the license
18 renewal period quite a bit before the entrance to PEO,
19 say five years. Pick a number. And it looks like
20 slide 23 sort of addresses that.

21 So our concern was that the last serious
22 inspection might take place five years before the
23 period of extended operation, and a lot can happen in
24 five years. And so we made that comment during the
25 Subcommittee meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WILSON: Yes, George Wilson. The key
2 is actually; this is performance based, we'll move or
3 slide inspections back based on a licensee's
4 performance. Even the Phase 4 could get slid back if
5 we were very comfortable to do it closer to the SLR.

6 MEMBER SKILLMAN: I want to make the
7 comment that the inspection manual chapter you're
8 looking at and that I'm looking at are the same ones.
9 And you're accurate. There is a team inspection.
10 It's at Phase 2 and it is as you described. The text
11 is that Phase 2 of the inspection is intended to be a
12 one-time major team inspection per site. I've got
13 that. Three and four actually become optional in the
14 current procedure.

15 MR. WILSON: Well, right. And the reason
16 about that, that is based on the overall outcome of
17 the Phase 2, but --

18 MEMBER SKILLMAN: Okay. But that --
19 George --

20 MR. ROGERS: -- we have not --

21 MEMBER SKILLMAN: -- just a minute.

22 MR. WILSON: Okay. Go ahead.

23 MEMBER SKILLMAN: That's the information
24 we have.

25 MR. WILSON: Right, and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Simultaneous speaking.)

2 MEMBER SKILLMAN: -- Dennis' question, my
3 question, Ron's question.

4 MR. WILSON: So right now to -- and you're
5 exactly right, they're -- and they say they're
6 optional because it's based on performance, but right
7 now everyone will be getting that -- that we've had,
8 they've gotten to Phase 3 and we did that look. It's
9 also based on how comfortable we are in the overall
10 performance. That's why I was saying you pull -- you
11 take the insights from the individual licensee and
12 decide if you wanted to move that up.

13 So if the regional inspectors and the
14 headquarters staff was not comfortable with a plant
15 that was coming in for SLR and we would say, hey,
16 look, we want to pull that Phase 3 inspection up and
17 look at the overall outcome -- but like the plants
18 coming in for an SLR, they -- the first one actually
19 has already had the Phase 3 inspection; the other will
20 get it. But -- and me -- my discussions with the
21 regions, we do plan on doing -- even though they are
22 optional, right now we do plan on doing the Phase 3
23 and Phase 4 inspections at the facilities.

24 MEMBER SKILLMAN: Let me just add one more
25 comment that reinforces what both Ron and Dennis said.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If there is an 18-month or 24-month time period
2 between the actual walkdown team inspection and the
3 entrance into the PEO, that's a long time. And if you
4 had a plant that has a complacent staff, the plant
5 then enters the PEO for the first day of the 61st year
6 might not be the same plant that was on day one of the
7 58th year.

8 And so what you're experiencing here is
9 some caution by this Committee relative to knowing
10 that when that plant actually tumbles into day one or
11 the first day of the 60th year it really is ready to
12 run for 20 more in accordance with its design-basis,
13 and it's material condition reflects that.

14 MR. WILSON: Right, and I do -- this is
15 George Wilson. I do understand the point. I think
16 that I was -- that was the reason that I was
17 highlighting that these are performance-based
18 inspections.

19 MEMBER SKILLMAN: Yes, I got that.

20 MR. WILSON: It's not just that I'm taking
21 just the Phase 2 inspection of 03. I'm taking the
22 overall operating plant condition and monitoring that
23 we're doing in the ROP where I get additional insights
24 from the normal ROP baseline inspections. With those
25 insights and the material condition that the residents

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are walking around, the NRC then makes decisions.

2 So I'm not going to list the plant, but
3 there's a plant that's going to get a Phase 3
4 inspection -- actually going to get a robust -- it's
5 not a Phase 3 -- going to get another robust Phase 2
6 inspection because of that performance. We're seeing
7 some other things; and I'm not going to say what the
8 plant is, but one of the regions have already called
9 and they're actually going to go do another full-blown
10 team inspection on the opposite unit for Phase 2
11 because of some insights they've gotten from the ROP
12 and the plant's performance.

13 So I'm very comfortable of taking and
14 looking at the overall assessment we do for a reactor
15 during the ROP, taking those insights and then the
16 insights we're getting where we can go out and look at
17 the aging management program and the processes
18 themselves, and looking at that and deciding whether
19 or not we're going to pull up the inspections to
20 verify everything it has they told us.

21 MEMBER SKILLMAN: Well, I appreciate your
22 very strong commentary here because it's consistent
23 with what I would like to see in the letter that
24 communicates the importance of those physical
25 inspections. And whether they're conducted as a late-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 breaking 71002 or they're done in Phase 2 as a team
2 inspection to confirm that the facility is good to go,
3 it's up to you. The real issue for us is making sure
4 that the plant has a material condition that it's what
5 it needs to be. So as long as you're comfortable with
6 that, that's certainly where we are.

7 MR. WILSON: Right, I mean, right, I'm the
8 director and the license renewal, the SLR would not go
9 through me until I was comfortable with that.

10 MEMBER SKILLMAN: Good. Very good.

11 MR. WILSON: We would make sure we did
12 that inspection.

13 MEMBER SKILLMAN: Okay. Thank you.

14 MR. WILSON: All right. Thank you.

15 MEMBER SKILLMAN: Billy, go ahead.

16 CHAIRMAN BLEY: Sorry.

17 (Laughter.)

18 MEMBER SKILLMAN: I'm sorry, Dennis. I
19 might have terminated the conversation you wanted
20 to --

21 CHAIRMAN BLEY: Oh, no, I was just saying
22 sorry to Billy --

23 (Laughter.)

24 MEMBER SKILLMAN: Okay. Thank you, Bill.

25 CHAIRMAN BLEY: -- for diverting his --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Please go ahead, Bill.

2 CHAIRMAN BLEY: -- show here.

3 MR. ROGERS: This first slide is just the
4 agenda of the things that I'm going to speak about
5 over the next few slides. Okay?

6 Slide, please, Don. Okay. This slide
7 provides a generic timeline for the license renewal
8 activities and audits. You can see there that the
9 IP71002, which is a pre-implementation activity that
10 occurs prior to the issuance of the renewed operating
11 license. And following the issuance of the renewed
12 license the AMPs are implemented and subject to
13 verification in Phase 1 and Phase 2 of IP71003 just
14 prior to entering PEO. And Phases 3 and 4 of IP71003
15 occurred during the period of extended operation.

16 Next slide, Don. So this slide adds a
17 generic timeline for the subsequent renewal
18 activities, to illustrate when the activities will
19 occur following receipt of the SLR application. And
20 here we've highlighted where the additional PEO is on
21 the left and then in the subsequent PEO on the right
22 in red. Shows there's somewhat of an overlap of
23 certain activities.

24 CHAIRMAN BLEY: Let me try one other
25 question on you folks. Many of the arguments that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just heard make a lot of sense, but also seem they
2 would fit the first license renewal. But at the first
3 license renewal, for some reason, you wanted an 02
4 inspection as well. Now, I can invent some reasons
5 for that, but tell me why you wanted an 02 inspection
6 for the first one and you don't think you need it for
7 the second one?

8 MR. ROGERS: Okay. So I'm going to
9 address that --

10 CHAIRMAN BLEY: Okay.

11 MR. ROGERS: -- specifically.

12 CHAIRMAN BLEY: That's good. I'll wait.

13 MR. ROGERS: Okay. So, let's see, slide,
14 Don, please. So this describes the IP71002, the
15 license renewal inspection, which is a pre-
16 implementation inspection performed during the license
17 renewal application review. And this is performed
18 approximately 11 months after receipt of the
19 application. And that has moved around a bit in time
20 over the review periods. And again, it's prior to
21 issuance of the renewed license.

22 The regional inspector review includes
23 verification of the scoping and screening process,
24 assessments of the applicant's plans to implement,
25 aging management programs to review the documentation,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 past test analyses and plant walkdowns, and then
2 verification of the applicant's operating experience
3 review.

4 Okay. Slide, Don. So IP71003, the post-
5 approval --

6 MEMBER SKILLMAN: Bill, let's back up. So
7 just for timeline, 71002 on a plant that was licensed
8 in say 1980, the 71002 would probably have been
9 conducted around 2000 or 2005, 20-25 years later.

10 DR. HISER: It would depend on when the
11 application's --

12 MEMBER SKILLMAN: Bingo.

13 DR. HISER: Yes, it could be -- it could
14 have been year 2000, which would be about year 20.

15 MEMBER SKILLMAN: Yes.

16 DR. HISER: It could be as late as 2018
17 when the plant's 38 years old.

18 MEMBER SKILLMAN: Right. Okay. Fair
19 enough. So this is in the first -- within the first
20 40 years after the operating license was issued.

21 MR. ROGERS: So the 71002 would -- it
22 occurs within the 11 months of receipt of the
23 application.

24 MEMBER SKILLMAN: Yes. So if the
25 application came in after the plant was out say for 20

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or 25 or 30 years, it would have been 6 or 8 or 10
2 years prior to the 40-year clock?

3 MR. ROGERS: Yes.

4 MEMBER SKILLMAN: Good. Okay. So we're
5 talking about the first 40 years, and the 71003 is the
6 follow up to that inspection that was conducted --

7 MR. ROGERS: Yes.

8 MEMBER SKILLMAN: -- before the first 40
9 years timed out?

10 MR. ROGERS: For the PEO, yes.

11 MEMBER SKILLMAN: Good. That's the only
12 point I'm trying to make.

13 MR. ROGERS: Okay. So let's see.

14 DR. HISER: And actually I did misspeak.
15 For a plant that received their operating license in
16 1980, for timely renewal they would need to come in
17 before 2015 --

18 MEMBER SKILLMAN: Yes.

19 DR. HISER: -- five years ahead of the end
20 of the license.

21 MEMBER SKILLMAN: Yes.

22 DR. HISER: Sorry about that.

23 MEMBER SKILLMAN: Okay.

24 MR. ROGERS: So this discusses IP71003,
25 the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: We don't let it go that
2 -- we don't want to let go of that timely removal --
3 or timely renewal topic here. We want to touch on
4 that before this meeting ends.

5 MR. ROGERS: Okay. All right. So the
6 IP71003 is a post-approval site inspection for license
7 renewal. And George discussed, it's performed using
8 a four-phase approach following the issuance of the
9 renewed license. IP71003 Phases 1 and 2 are large
10 multi-team inspections performed to assess a
11 licensee's readiness to enter the PEO by verifying AMP
12 implementation and completion of inspections, tests
13 and analyses. And you'll note that if you've reviewed
14 the inspection procedure, large is roughly 11 to 2,000
15 person hours, depending on the site.

16 In addition, the team verifies that
17 license conditions have been met and changes to
18 commitments -- conditions in the UFSAR that have been
19 in accordance with the regulations.

20 Then the distinction between Phase 1 and
21 Phase 2 is that while the Phase 1 and Phase 2
22 activities are the same, that the Phase 1 is performed
23 during the second to last or the last refueling outage
24 prior to PEO to gain access to areas that wouldn't be
25 accessible during operations. So that's why they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 split into two pieces, Phase 1 and Phase 2. And the
2 remaining, anything that's not inspected in Phase 1 is
3 in the larger inspection in the Phase 2.

4 Phase 3, which is likely to occur one to
5 two years after the licensee enters PEO reviews the
6 implementation of license conditions, regulatory
7 commitments and AMPs and TLAAs with implementation
8 schedules that occur during the PEO. So some items
9 might not actually be implemented until they're
10 actually in the period of extended operation, and
11 Phase 3 would pick those up. And also a large
12 component of Phase 3 is to review corrective actions
13 for any issues identified during the earlier Phase 2
14 or Phase 1 inspections.

15 CHAIRMAN BLEY: Billy, I'm going to
16 interrupt you, and I'm either going to help you or
17 display my ignorance, or both.

18 What I thought you were going to tell us
19 is that the 02 inspection you need for the first one
20 because we'd have a plant operating for toward 40
21 years and they haven't had any aging management
22 programs or TLAAs, and that gets you ready to go into
23 this. Where when we come to the second period of
24 extended operation, they will have been implementing
25 these AMPs -- not all of the ones they'll need, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 many of them for 20 years, or on that order. And
2 therefore, you don't need to see that they're kind of
3 set up to be able to do them.

4 MR. ROGERS: Well, I'll jump ahead of
5 myself a little bit. We have a crosswalk slide which
6 you might have seen, but it goes through and compares
7 what we do in the different inspections. But I think
8 that the -- what you said is well worth considering is
9 71002, it's inspections, it's a pre-implementation
10 inspection. And when the inspectors go to the site,
11 in the same way that the auditors go to the site; and
12 I do an audit at the site, there are books, there are
13 documents to read, there's a lot of things to look at.
14 But what is not in place necessarily is an implemented
15 AMP.

16 And when AMPs are implemented, what that
17 means in practice is that they will have taken the
18 concepts that are in the AMP; and they're big basis
19 binders for the AMPs, and the utilities have to take
20 those concepts and roll them through their
21 implementing procedures. So there's inspecting
22 procedures in the plant, operational procedures. And
23 the AMPs get broken into procedures and put into these
24 procedures. And there's preparation of staff, there's
25 assignment of program managers, there's a whole lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different activities that go into the actual
2 implementation of the AMP.

3 So when we're in 71002 space, that has not
4 yet occurred. When we're in 71003 space, that has
5 occurred. So relative to what you said earlier, for
6 initial license renewal when we do the 71002, that has
7 not yet occurred, or not to any great extent. And we
8 look at that.

9 So when we're in subsequent license
10 renewal, all of that will have happened. All of that
11 will be implemented, with a few exceptions, and
12 generally operational. And that is the significant
13 difference between why you would do an 002 for license
14 renewal but you would not repeat that necessarily for
15 subsequent license renewal, because the subject of the
16 task is not in the same configuration.

17 CHAIRMAN BLEY: Sounds like a yes to what
18 I asked you.

19 MR. ROGERS: Okay. Well, I'll stop then.

20 (Laughter.)

21 MR. ROGERS: I'll take a yes.

22 MEMBER RICCARDELLA: As I read it, part of
23 the 002 inspection was verifying the scoping and that
24 aspect of it and selection of the components. And in
25 the 003 -- when you go in for subsequent license

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 renewal, I mean, there's no new components. The
2 scoping is pretty much done. I don't see that that
3 needs to be redone.

4 CHAIRMAN BLEY: Yes, absolutely.

5 MR. ROGERS: So I'll address the new phase
6 of IP71003, which is this Phase 4. That was added by
7 revision in 2016, just last year, and it's intended to
8 be performed 5 to 10 years in the period of extended
9 operation. The purpose of Phase 4 is to verify that
10 the licensee is managing the effects of aging in
11 accordance with the AMPs as described in the UFSAR and
12 also to review implementation of the AMP's elements
13 during PEO to ensure that the SSEs have maintained
14 their ability to perform their intended functions.
15 The NRC has not performed that inspection as of yet.

16 Next slide, Don, please. Okay. This
17 slide just addresses the timing of the phase. We
18 discussed this already. It just lays them out and
19 talks about them so you can compare those. But you
20 see it's -- I think we discussed that.

21 All right. Okay. Allen?

22 DR. HISER: Yes, I guess the other thing
23 just to reinforce, 71002 looks at plans for AMPs,
24 71003 looks at implementation of AMPs. So it's no
25 longer a notebook as Billy mentioned, but it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually things that the plant has done. Generally
2 there are inspection results that are available so you
3 can assess whether the plant -- the AMP is finding
4 things. That is I think fundamentally the difference.

5 With the -- you saw from the list of AMPs
6 at least compared to Rev. 2 there are not very many
7 new AMPs. Now some of the early plants are going to
8 be pre-GALL, so there may be more AMPs that are new
9 for the SLR application, but plants have been doing
10 aging management from actually before they constructed
11 the plant. So the -- it may be that for -- with
12 license renewal these are new AMPs from the way it's
13 -- they're laid out in 10 elements, but they've been
14 doing the procedures and many things since the plant
15 first opened. So there's nothing really unique.

16 I mean, now there's more emphasis.
17 There's maybe a definition of the AMPs within 10
18 elements, but they've been doing many of these things.
19 They're existing programs in most cases.

20 MR. ROGERS: Yes, I would add to that. I
21 think what the AMPs do and what occurs during the
22 development of the application, the performance of the
23 71002 inspection, the AMP audits and the technical
24 review is the utilities go through a thought process
25 which takes often existing programs and focuses them

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the effects of aging. It already existed, but it's
2 more of a mindset as they go into the period of
3 extended operation.

4 MEMBER STETKAR: Billy, and what you just
5 said resonates with me, okay, because everybody says,
6 well, everybody has been paying attention to all of
7 this throughout the life of the plant and the
8 inspectors have been doing all of the reactor
9 oversight process and everybody is in lockstep, but
10 when we've seen specific examples of plants that have
11 come in for their first license renewal, somebody
12 said, well, look at all of this experience in the
13 context of aging. And we've discovered stuff by
14 looking at it in that context. Because for some
15 reason people over the 20-25 years or so didn't think
16 of it that way.

17 It's not clear to me because these are
18 AMPs. They're not procedures. They're AMPs. I have
19 an aging management program and I say this aspect of
20 the aging management program for this system is in
21 this part of my normal maintenance or surveillance
22 program that I've implemented for the last 25 years.
23 Maybe I've had to tweak something a little bit. So
24 there's a danger that it gets redistributed, if you
25 will.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And where does it come back together
2 again? Where does that kind of focus of what have we
3 learned over; and I don't care what the period is for
4 right now, X period of time trigger that notion of,
5 hey, let's look at that again in the context of aging,
6 not in the context of have we been following all of
7 these distributed procedures and inspecting against
8 all of those distributed procedures?

9 MR. ROGERS: Yes, well, that's a good
10 question.

11 MEMBER STETKAR: That's kind of what I'm
12 looking for.

13 MR. ROGERS: So the way that that
14 typically occurs is the -- then there's a couple parts
15 of this, but the first way is that utilities have
16 program managers for aging management programs, so
17 there is typically a point of focus to keep
18 considering that as time goes on. And the second
19 piece to that is the utilities have a commitment to
20 consider the operating experience, which we issued an
21 ISG on that effect. It's part of the aging management
22 programs and it is -- in addition to the application
23 and the AMP documentation our review of operating
24 experience is the single most rich source of
25 information supporting our review of the aging

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 management programs.

2 MEMBER SKILLMAN: Bill, I would just join
3 John in raising that flag. It is a mindset, like you
4 said, but I've been involved in plants that had a
5 mindset to let the plant fall apart. And they did
6 have system engineers and they did have component
7 engineers, they did have maintenance rule, they did
8 have system health reports. And in spite of that the
9 plant literally dissolved around them, and it turned
10 out to be a money issue. How much money was
11 management going to put into maintaining the plant?

12 So these words are all well and good as
13 long as there is a discipline within that facility to
14 maintain the material condition of the plant.

15 To give a couple of examples, we've had
16 applicants come in here for license renewal, and I
17 think unless we pushed them they would have been happy
18 to start it up with two studs missing from the reactor
19 vessel head. We found applicants that literally
20 turned off their cathodic protection system 15 years
21 ago and let it languish.

22 So like John says, we've listened to an
23 awful lot of interesting things that would cause at
24 least this experienced engineer to say I'm not sure
25 someone's on watch and I'm not sure someone is really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anticipating wanting to take this plant from 60 to 80,
2 because if you're going to take it from 60 to 80,
3 you've got to protect it to 60. And hence, the
4 pushback you're getting here.

5 I understand your use of IP71003. 71002
6 gave us the thick magnifying glass inspection. I
7 think what we're searching for is assurance that
8 before we get into the PEO there has been another
9 really thick magnifying glass inspection with formerly
10 documented results that give us assurance that the
11 material condition is what it needs to be in spite of
12 all this.

13 DR. HISER: Yes, well, I think in part
14 that's what Phase 4 is intended to do. I mean, the
15 plant says they have AMPs. As George has described,
16 there are many elements of the ROP that try to verify
17 that the plant is doing the things that it needs to
18 maintain the plant safely.

19 MEMBER SKILLMAN: Okay. So the Phase 4
20 can be at plant age approximately 50, is that correct?

21 DR. HISER: Forty-five to fifty, that's
22 correct.

23 MEMBER SKILLMAN: Forty-five to fifty?
24 And if the physical inspection that comes out Phase 4
25 gives the same kind of inspector insights and material

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 condition results that we saw in IP002, I think we're
2 going to be good to go. But that's what's got to come
3 out of Phase 4.

4 MR. ROGERS: Well, I would add that the
5 Phase 2 inspection that occurs within the year of PEO,
6 that is a very deep scrub.

7 MEMBER SKILLMAN: But that could be 17
8 years ago, if I'm right on the cusp of 60.

9 MR. ROGERS: No. No, it's just prior to
10 PEO. It's 3 to 12 -- it's within 3 to 12 months.
11 It's just prior to PEO.

12 MEMBER SKILLMAN: So you're saying that is
13 at age 56 or 57?

14 MR. ROGERS: Yes. Yes, sir.

15 MR. WILSON: This is George Wilson again.
16 I'm going to -- I might have missed a point that I
17 said and I might not have said it clearly. So to try
18 to get at I think a point that you're making, one of
19 the things that we're going to do; and the regions
20 have already stated that they wanted to participate,
21 we're going to put the resident or one of the regional
22 inspectors that actually are aging management program
23 specialists that the region has -- they will actually
24 participate in the audit for SLR.

25 We also plan on making them available for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you to ask questions during the review on the material
2 conditions of the plants working with the regions. So
3 I think that will help address some of the material
4 conditions questions you have. So we do -- like I
5 said, we -- they -- in fact they -- the regions have
6 asked can they put more than one person on the audit?
7 And if we have to we will. But that question will be
8 thoroughly addressed before we would give the SLR on
9 material condition. And we will do what we -- we'll
10 make sure that we have an inspector available during
11 the review of the SLR for you guys to ask questions
12 and address some of your concerns.

13 MEMBER SKILLMAN: Okay. Thank you.

14 DR. HISER: Yes, and I think if we go back
15 to the 18-month schedule, we said high-level complete
16 application, very responsive to RAIs. And I think in
17 addition that schedule can adjust based on what we
18 find in the inspections, based on what we find in the
19 audit. If we find issues, then that clearly will
20 impact the schedule and our ability to complete our
21 review to find reasonable assurance.

22 MR. ROGERS: Yes, and I would add one more
23 thing to the list of the quality application would be
24 adequate resolution of all previously known technical
25 issues, because there's a lot in the SERs that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 demonstrate what an acceptable resolution of common
2 technical issues might be.

3 MEMBER SKILLMAN: Okay. Let's proceed.

4 MR. ROGERS: Okay. Slide, Don? So this
5 is the crosswalk. It provides a list of activities
6 that occur during the license renewal application
7 review process. And that's in the first column. The
8 second column is what occurred during the initial
9 license renewal. And the third column is what we
10 intend to accomplish during the subsequent license
11 renewal process.

12 So the first two rows there: walkdowns of
13 the plant, review of plant's material condition,
14 interviews of plant personnel. These were
15 accomplished during the IP71002 inspections. And also
16 the headquarter audits and the IP71003 inspections
17 during the first renewal.

18 Additionally walkdowns and interviews to
19 assess age-related degradation activities occurs
20 regularly by the resident and regional inspectors in
21 accordance with the baseline inspections performed
22 under the ROP. Many baseline inspection procedures
23 have been updated to incorporate aging management
24 inspection guidance. And I'll discuss those in a
25 moment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For SLR headquarters staff will continue
2 to conduct interviews with plant personnel as to
3 walkdown of relevant structures and components during
4 AMP audits. The IP71003 inspections for SLR and
5 baseline inspections under the ROP can also be
6 credited for the performance of walkdowns in
7 interviews. And again, I'm getting a little ahead of
8 myself, but the intent is, as George mentioned, to
9 have inspectors participate in the audit, onsite audit
10 process in lieu of the 71002 activities. And I have
11 some further -- I think some further basis for that.

12 The third row AMP evaluation. So during
13 the IP71002 inspection audits for the first renewals,
14 the inspectors and auditors reviewed the applicants'
15 plans to implement AMPs. During the IP71003
16 inspections for license renewal the inspectors
17 verified implementation of the AMPs and completion of
18 inspection tests and analyses. So for subsequent
19 license renewal there is a small subset of AMPs that
20 are new, the ones that Allen discussed, while the
21 other AMPs are existing AMPs that have implemented by
22 the applicants.

23 So the staff will continue to review the
24 pre-implementation information for the small subset of
25 new AMPs and the information related to the majority

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of AMPs which have been previously implemented during
2 AMP audits and the IP71003 inspections. So we do
3 intend to look at the pre-implementation information
4 for the -- I think the two AMPs that you listed, the
5 one that's broken into three and any plant-specific
6 AMPs that exist for an application.

7 The headquarters staff will work with the
8 regions to implement the tailored approach to the AMP
9 audits for SLR. The scope of the AMP audit will
10 depend on when the plant was originally licensed
11 against the pre-GALL report or GALL Rev. 0, 1 or 2,
12 accordingly.

13 The scoping and screening review, as was
14 alluded to earlier, during the IP71002 inspection
15 audits for the first renewal, the inspectors and
16 auditors reviewed the applicants' scoping and
17 screening methodology. The inspectors place a focus
18 on non-safety affecting safety. And the headquarter
19 auditors, which is myself and team, we do a complete
20 scrub on site of their methodology, identify the SSEs
21 and the scope. For SLR this activity will be
22 performed again during the AMP onsite audit.

23 I said add also that for that particular
24 subject, scoping and screening, the headquarters staff
25 and the region were -- during the review, following

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the review, that's a common -- we have common
2 communications on that, or often we have
3 communications on that subject. So there's a lot of
4 interaction. Probably in the first 40-50 percent of
5 the reviews there would often be a regional inspector
6 going on the scoping audit. In addition to doing the
7 inspection, they would go on the audit that I would
8 lead just to gain more information. And different
9 divisions in the agency also participate.

10 The operating experience review, which you
11 mentioned, Mr. Bley. During IP71002 inspection and
12 audits for first renewals the inspectors/auditors
13 assess the applicant's operating experience review.
14 For SLR this activity will be performed during the
15 aging management program audit.

16 Now, I just want to emphasize that this
17 operating experience review is really an extensive
18 activity for us. We have a set of practices we have
19 in place. We directly access their CAP program when
20 on site and do independent evaluations of corrective
21 action reports. So this is a big part of the review.
22 It routinely affects our evaluations and conclusions
23 in the SER. This will receive the same amount of
24 focus during the subsequent license renewal with an
25 additional component of how the AMP has dealt with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 age-related degradation. So it is actually more
2 complex for operating experience in the subsequent
3 renewal period.

4 So again, during the onsite AMP audit when
5 we look at operating experience or if we happen to do
6 that during another activity on site, the inspectors
7 would be -- hopefully be involved with that process.

8 MR. WILSON: And this is George Wilson
9 again. Actually one of the comments that you stated,
10 we'll make sure the AMP audit will be available to you
11 and we'll actually address the material condition of
12 the plant compared to what they AMP is and the
13 effectiveness of it. So that should address one of
14 the statements that you made. We'll make sure that we
15 add that and the AMP audit that we do is more robust
16 and actually addresses some of that concerns with the
17 inspectors.

18 MR. ROGERS: Okay. So the observations
19 identified documented reports. That's during the
20 initial license renewal review both the IP71002
21 inspection and headquarter audits resulted in similar
22 observations with similar documentation of the
23 outcomes. Since the IP71002 inspection is a pre-
24 implementation inspection, the items did not rise to
25 the level of findings or violations, but were instead

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 treated as observations and documented in the
2 inspection report and resulted ultimately in updates
3 to the license renewal application.

4 Similarly, issues and questions identified
5 during the headquarters onsite audit were documented
6 in audit reports and the safety evaluation report
7 promulgated through RAIs and also resulted in updates
8 to the license renewal application.

9 The IP71003 and the ROP baseline
10 inspections; the observations/findings can also become
11 violations, are identified and documented in the
12 inspection reports as appropriate. So for SLR the
13 headquarter auditors will continue to document the AMP
14 audit observations in the audit report, the safety
15 evaluation report and process the observations to
16 request for additional information and result -- have
17 the results -- have it result in updated SLR
18 applications.

19 In addition, similar to first renewals,
20 for IP71003 and ROP baseline inspections the
21 observations were made findings and violations if
22 appropriate and documented in the inspection reports.
23 The point that I am making there is that in the
24 IP71002 pre-implementation inspection it moved toward
25 documentation in the report and changes to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 application for both the audit and the inspection.

2 So there's two other areas I'd like to
3 address which actually are not on that slide, but I
4 think are relevant and some of which we've already
5 discussed. But I'd like us to go through these again.

6 During the initial license renewal process
7 inspectors performed the IP71002 inspection. The
8 71003 inspection would on occasion participate in
9 headquarters audits. Additionally, inspectors
10 routinely assess how the licensee addressed age-
11 related degradation during baseline inspections under
12 the ROP.

13 For subsequent license renewal inspectors
14 will continue to perform inspections of licensee's
15 performance in addressing age-related degradation as
16 part of the baseline inspection activities under the
17 ROP. It's also important to note that headquarters
18 and regional staff continually communicate during the
19 license renewal process and will continue to do so
20 during the subsequent license renewal process. Both
21 parties share information to -- on operating
22 experience, AMP evaluation and technical issues as
23 required to complete that review. And again, this is
24 an ongoing conversation. It's routine conversation.

25 As far as the ACRS meeting presentation we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consider the comments in the Subcommittee meeting on
2 the subject and we know that the first license renewal
3 inspectors presented on inspection observations and
4 the plant's material condition during the ACRS
5 meetings. So for subsequent renewal a regional or
6 resident inspector will be requested to present to the
7 ACRS on the material condition of the plant and
8 observations made during the first renewal's IP71003
9 inspections and any other observations that might have
10 been made -- that can be made based on participation
11 in the aging management program audits or other onsite
12 activities, including ROP baseline inspections. So
13 our intent is to have an inspector present at both
14 Committee meetings to address those concerns.

15 MEMBER STETKAR: Billy, can you help me?
16 I was trying to read and listen and think at the same
17 time. I was being ineffective at doing any of those
18 things. I hear you saying that your intention is to
19 have regional inspectors participate in the AMP audit
20 for subsequent license renewal. Is that an intention
21 or do you actually have some sort of written firm
22 commitment that that shall be?

23 MR. ROGERS: Well, I'll address that and
24 then there may be another comment in the room.

25 MEMBER STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ROGERS: But, so the concept of the
2 inspections in SLR, we have been discussing this with
3 the region for at least a year. We have routine phone
4 calls and we went through the process and discussed
5 how they fit into the SLR process. When it became
6 apparent that we were heading in the direction of not
7 having the IP71002 repeated for the reasons that we've
8 already discussed, then the concept of having the
9 inspectors' perspective and knowledge of the plant --
10 how does that get fused back in to our process?

11 Well, we're going to do an onsite audit.
12 And so we floated that idea to the inspectors. And
13 this is staff and management-level branch chiefs. And
14 we asked would you be supportive of participating in
15 the onsite audit? And they said yes, and may we send
16 multiple inspectors to support? And that's an
17 informal request.

18 MEMBER STETKAR: Okay. So far that's
19 informal, but --

20 MR. ROGERS: Okay.

21 MEMBER STETKAR: -- if I'm an inspector,
22 I'm --

23 (Simultaneous speaking.)

24 MR. ROGERS: However, recently there's
25 been additional conversations at the management level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 between DLR and the regions.

2 And maybe, George, would you like to
3 address that?

4 MR. WILSON: Yes, this is George Wilson.
5 I just had conversations. There is an intention that
6 each one of the regions will participate in the audits
7 for the SLR. In fact, I mean, I just had that with
8 the division-level management and that is the
9 intention. And I will make sure that through my
10 conversations they do participate.

11 MEMBER STETKAR: The intention and oral
12 things are -- sound good in meetings like this. What
13 I'm looking for is is there a commitment that when I
14 constitute an AMP audit team in headquarters, there
15 shall be -- in writing there shall be participation by
16 at least one regional inspector, or one of the
17 resident inspectors from that plant --

18 MR. WILSON: No, but --

19 MEMBER STETKAR: -- in terms of an office
20 instruction or something like that, however this is
21 implemented?

22 MR. WILSON: Well, there is no office
23 instruction that does that.

24 MEMBER STETKAR: Okay.

25 MR. WILSON: That conversation will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 held between me and the other director in the region
2 associated with the aging management, which in each
3 one of the regions is a DRS director.

4 MEMBER STETKAR: Okay.

5 MR. WILSON: So I also -- I mean, I
6 understand what you're saying, but we also give them
7 FTE for the inspectors to go out and do that. And
8 that will be provided, so they will provide support
9 back to cover the FTE that we're giving to them.

10 MEMBER BALLINGER: But with all due
11 respect, you probably will be here forever, but maybe
12 not. And so the person who replaces you might not
13 have the same intention or might not have the same
14 idea.

15 MEMBER STETKAR: Or budget.

16 MEMBER BALLINGER: Or budget.

17 MR. WILSON: I understand the comment. So
18 right now there is no formal agreement. I'll have to
19 work in the DRS meeting that we have biweekly and see
20 if I can get a -- I don't know if I'm going to get a
21 formal agreement, but I understand what you want. But
22 right now that is the intention and that's what I was
23 told they would. So, but there is no formal
24 agreement. I'll see what we can do to go about do
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Thank you, George. Yes,
2 let's proceed.

3 MR. ROGERS: Next slide, please? Okay.
4 This is a list of the ROP procedures that have been
5 updated to incorporate Aging Management Inspection
6 Guidance. And you can see it's a -- there is some
7 equipment alignment, flood protection measures, heat
8 sync, in-service inspections, maintenance
9 effectiveness, component design-basis inspection and
10 PI&R inspections.

11 The inspection procedures that are listed,
12 they can provide useful information during the review
13 of the SLR application and insights on aging
14 management to be utilized during the IP71003
15 inspection and also the SLR aging management program
16 audits.

17 Okay. Slide, Don? Okay. In closing we'd
18 like to reiterate that the license renewal functions
19 will continue to be performed for subsequent license
20 renewal. The activities that support the review of
21 the SLR applications such as the AMP audit for SLR in
22 the first renewal IP71003 inspections may need to be
23 tailored on a plant-specific basis to ensure the
24 review is adequate and timely. The staff has
25 confidence that reasonable assurance of the adequacy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the applicant's implementation of AMPs and aging
2 management activities for subsequent license renewal
3 will be obtained based on the staff reviews and
4 inspection activities.

5 We appreciate the present on the SLR staff
6 guidance documents and the SLR Optimization Working
7 Group results. Thank you.

8 MEMBER SKILLMAN: Okay. Question: Before
9 we lose momentum here, or interest, I would like to
10 talk for a few minutes about timely renewal. So I'm
11 a plant manager and I'm an executive of a plant out in
12 the middle of *Dances With Wolves* and I haven't done
13 squat for my plant. My plant is just -- I'm hanging
14 on. I listen to what George says. George says I've
15 got the ROP. All I'm interested in is performance
16 indicators and I've got half a dozen systems that are
17 in system health red. I'm hanging on by a thread with
18 the maintenance rule and I'm at 54 years, 11 months
19 and 28 days. And I just tell my administrative people
20 put in the application because I'm going to be timely
21 renewal for life beyond 60, because I'm obeying the
22 rules, I'm obeying the law.

23 What is going to prevent this miserable
24 facility from being permitted to go into the first day
25 of its 61st year when it's collapsing?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ROGERS: Well, I would -- I think that
2 I would not start with that hypothesis.

3 MEMBER SKILLMAN: I would.

4 MR. ROGERS: Okay.

5 MEMBER SKILLMAN: I can give you stories,
6 because I spent a lot of years out there after I left
7 running engineering in a nuke, and I will tell you
8 there are people who do not take care of their
9 machine. They let them fall apart and they only get
10 religion when they are on the cusp of 95003 or 0350.
11 That wakes them up real fast. But it normally takes
12 that to get their attention.

13 So I'm kind of -- I'm being a contrarian
14 on purpose. I would like to spark this conversation
15 because at least I envision the potential for a
16 licensee to make a timely application under what, Part
17 2109 or 12103? And now here we are with a plant that
18 really is into the first day of its 60th year and --
19 or 61st year and it really has not done any
20 preparation. What prevents that?

21 MR. BLOOM: I think the answer is
22 something that George said before. Since we're always
23 watching the material condition of a plant, if they
24 are in such a bad condition as you are describing, I
25 don't believe the NRC is going to allow them to get to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 60 years regardless of whether they have an
2 application in. There will be numerous inspections
3 and 350. I mean, we are just going to do a lot of
4 other stuff that would almost shut the plant down
5 before then.

6 MR. WILSON: This is George Wilson to add
7 onto what you're saying. So one of the key components
8 of the revised oversight process is the Corrective
9 Action Program being very dynamic and very proactive.

10 MEMBER SKILLMAN: And effective.

11 MR. WILSON: And effective. That is the
12 key. So what would happen during the performance
13 evaluation of a licensee, we would identify several
14 issues if the condition of the plant was that way.
15 They should be put into the Corrective Action Program.
16 Then the Corrective Action Program would be evaluated
17 during the problem identification resolution
18 associated with each one of the inspections.

19 If a licensee would then no longer -- they
20 weren't implementing the corrective actions, they
21 would get crosscutting issues in the corrective
22 actions where it could lead to -- one of the basic
23 statements in the revised oversight process is that a
24 licensee, as you stated, has to have a very proactive
25 effective Corrective Action Program. If they do not,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you have to evaluate whether or not they can stayed in
2 a revised oversight process. And so that would be
3 something that would be done by the regions on the --
4 you would have to evaluate that if they were not
5 taking corrective actions the way they were supposed
6 to be.

7 MEMBER SKILLMAN: This is a yes or no
8 question: If a plant is in that situation, and I
9 would say it's probably a 95003 --

10 (Simultaneous speaking.)

11 MR. WILSON: Well, it could be worse in a
12 95003. We don't -- so if you would get --

13 MEMBER SKILLMAN: Well, George, let me
14 finish my question. The reason I used 95003 is that
15 can still be operating at power and being in 95003.
16 0350 they fall -- they've lost their keys.

17 MR. WILSON: That's correct.

18 MEMBER SKILLMAN: So they still have --
19 they're still operating in 95003. There are real
20 problems, whether administrative or material condition
21 problems. And in that condition can they successfully
22 apply for timely license renewal, or can they get
23 permission to proceed with their application if they
24 are in that situation? It's a yes or no.

25 (No audible response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: I'd like to have an
2 answer to that question.

3 MR. WILSON: Right. I mean, I'd have to
4 look at the conditions and what the -- I mean, legally
5 we're bound by regulations. I have to see how the
6 regulations lie. And I'm -- also have a performance
7 part. So you're asking a question that has a legality
8 portion of it, not --

9 MEMBER SKILLMAN: It does.

10 MR. WILSON: -- just an operations.

11 MEMBER SKILLMAN: It does.

12 MR. ROGERS: So for the legality portion
13 I have to go back and look and talk to OGC. For the
14 performance-based I couldn't see how the quality of
15 the submittal that they would submit to my staff in
16 the Division of License Renewal would be acceptable
17 based on the performance of the plant and the
18 condition. Then we would deny it. We would not
19 accept that license renewal submittal based on the
20 conditions that you just gave me, as me acting as the
21 director of DLR.

22 MEMBER SKILLMAN: Okay. I kind of had a
23 hunch that that would be the answer, but that tells me
24 that if you chose to not accept that application
25 because it is not acceptable, then they may not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 proceed to that step.

2 MR. WILSON: They would probably
3 potentially shut down when that -- they would have to
4 shut down when that license come in. That would be a
5 decision that would be evaluated at very high levels,
6 but that would be based on what you -- my call would
7 be I wouldn't accept this. You're going to have to do
8 this. And we'd brief up.

9 MEMBER SKILLMAN: Okay. And please
10 understand that the basis of my question is not to be
11 punitive. It's to have organized thought about, if
12 you will, inadvertent entry into the PEO for
13 subsequent license renewal without having sufficient
14 overview.

15 MR. WILSON: Right, and that was one of
16 the keys where I said it's all performance-based. In
17 the performance you're giving me, that licensee
18 doesn't have it for me to --

19 MEMBER SKILLMAN: Yes.

20 MR. WILSON: -- have the reasonable
21 assurance.

22 MEMBER SKILLMAN: Thank you. Billy, back
23 to you.

24 MR. ROGERS: Thank you. I've completed my
25 portion of the presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay. Thank you.

2 Everybody just freeze. Colleagues, do you
3 have any further questions for the members from the
4 staff?

5 MEMBER KIRCHNER: I have a comment.

6 MEMBER SKILLMAN: Please, Walt.

7 MEMBER KIRCHNER: Bill, on your slides
8 that show the timeline, I'm in the middle of the
9 second PEO of myself and you're showing accelerated
10 aging there. So could I ask you in the future to
11 extend that? It's not -- you see what you're timeline
12 is doing? It's compressing. And I'm looking at time
13 dilation.

14 (Laughter.)

15 DR. HISER: Yes, thank you. We were just
16 putting everything on the slide. That's a good point
17 though. We were just trying to put it on the slide.

18 MEMBER SKILLMAN: Thank you, Walt.

19 Any other questions from the ACRS members,
20 please?

21 (No audible response.)

22 MEMBER SKILLMAN: If none, are there any
23 comments from anybody in the room, please? If so,
24 please come to the microphone and identify yourself
25 and raise your comment or question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (No audible response.)

2 MEMBER SKILLMAN: Seeing none, good
3 afternoon on the phone line. This is the ACRS. The
4 topic is subsequent license renewal. If anybody is
5 out there, would you just simply acknowledge that you
6 are there?

7 CHAIRMAN BLEY: Just go ahead, Dick. It's
8 open.

9 MEMBER SKILLMAN: Is anybody there,
10 please?

11 MS. CLARK: Yes, this is Phyllis Clark.

12 CHAIRMAN BLEY: You can just ask for
13 comments at this point.

14 MS. CLARK: Yes, this is Phyllis Clark,
15 CLR.

16 MR. XIU: And Bob Xiu, CLR.

17

18 MEMBER SKILLMAN: Thank you. For those of
19 you that --

20 (Simultaneous speaking.)

21 CHAIRMAN BLEY: You don't all need to
22 check in. Thank you.

23 MEMBER SKILLMAN: Thank you. For those of
24 you who are out there, does anybody wish to make a
25 comment, please?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (No audible response.)

2 MEMBER SKILLMAN: Hearing none, thank you.

3 We'll close the phone line.

4 Dennis, back to you, sir.

5 CHAIRMAN BLEY: Thank you very much, Dick.

6 We are at this point off the record.

7 (Whereupon, the above-entitled matter went

8 off the record at 5:04 p.m.)

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



United States Nuclear Regulatory Commission

Protecting People and the Environment

Design of the Highly Integrated Protection System Platform

**Presentation to the ACRS
Full Committee**

April 6, 2017
(Open Session)

Agenda

- Background
- High-Level Description of the HIPS Platform
- Safety Evaluation Scope
- Regulatory Conformance

Background - Timeline

Date	Activity
December 2015	Topical Report (TR) 1015-18653-P submitted for review
February 2016	NRC Accepted TR for Review
June 2016	NRC Sent RAIs
July 2016	First Audit at NuScale's Rockville Office
August 2016	NuScale Sent Response to RAIs
November 2016	Revision 1 of TR docketed
January 2017	Draft Safety Evaluation Issued
January 2017	Second Audit at Ultra Electronics (Wimborne, UK)
February 2017	ACRS Subcommittee Meeting
March 2017	Issuance of Final Safety Evaluation
April 2017	ACRS Full Committee Meeting

HIPS Platform

- The HIPS platform is composed of logic implemented using discrete logic and field programmable gate array (FPGA) technology
- The HIPS platform consists of the HIPS chassis and a system of modules
 - Safety Function Module (SFM)
 - Communications Module (CM)
 - Equipment Interface Module (EIM)
 - Hardwired Module (EIM)

SE Review Scope

- The scope of the review was focused on:
 - Fundamental I&C design principles
 - Independence
 - Redundancy
 - Predictability and Repeatability
 - Diversity and Defense in Depth
 - Calibration, testing, and diagnostics capabilities of the HIPS Platform



Regulatory Conformance

- The HIPS platform design supports meeting the applicable regulatory requirements associated with the fundamental I&C design principles.
- 65 ASAs have been established to identify criteria that should be addressed by applicants or licensees referencing this SE.
 - Quality Assurance
 - Equipment Qualification
 - Secure Development Process
 - MWS and PS Gateway
 - Human-Machine Interface
 - Displays

Questions



- ACRS: Advisory Committee on Reactor Safeguards
- ASAI: application-specific action item
- CM: Communication Module
- EIM: equipment interface module
- ESFAS: engineering safety features actuation system
- FPGA: field programmable gate array
- HIPS: highly integrated protection system
- HWM: Hard-Wired Module
- I&C: instrumentation and control
- ISM: Input Sub-Module
- MIB: Monitoring and Indication Bus
- MWS: maintenance workstation
- NRC: U.S. Nuclear Regulatory Commission
- RAI: request for additional information
- RTS: reactor trip system
- SDB: Safety Data Bus
- SBM: scheduling and bypass module
- SFM: safety function module
- SE: safety evaluation
- SVM: scheduling and voting module
- TR: topical report

Acronyms




Backup Slides

Populated HIPS chassis with the trip/bypass plate



High Level Representative Architecture Safety Data Paths

- Safety Data Paths (1, 2, 3)
- Safety Data Path 1
- Safety Data Path 2
- Safety Data Path 3
- Monitoring and Indication Path



Independence

- Physical Independence
- Electrical Independence
- Communications Independence
- Functional Independence

The staff finds that the TR provides information sufficient to support conformance with the independence requirements in RG 1.75, RG 1.152, RG 1.53, and DI&C-ISG-04, or establishes ASAs as necessary to fully comply with the regulatory requirements for an applicant or licensee referencing this SE.


Redundancy

- Power Supply Redundancy
- Safety Module Redundancy
- Communication Redundancy
- Equipment Interface Redundancy
- Platform Redundancy

The staff finds that the TR provides information sufficient to support conformance with the regulatory requirements on the single failure criterion in RG 1.53, or establishes ASAs as necessary to fully comply with the regulatory requirements for an applicant or licensee referencing this SE.

Diversity

FPGA Equipment Diversity Allocation in a Representative Architecture




Diversity

Effects of Digital CCF for HIPS Diversity Strategy

Event	Module	A	C	B	D
Transient or accident (no CCF)	SFM	✓	✓	✓	✓
	CM	✓	✓	✓	✓
	EIM	✓	✓	✓	✓
Transient or accident with CCF (Case 1 – equipment (FPGA) and module functional diversity)	SFM	✗	✗	✓	✓
	CM	✓	✓	✓	✓
	EIM	✓	✓	✓	✓
Transient or accident with CCF (Case 2 - equipment (FPGA) diversity)	SFM	✗	✗	✓	✓
	CM	✗	✗	✓	✓
	EIM	✗	✗	✓	✓

Predictability and Repeatability

Typical plant signal data flow path in HIPS platform



Calibration, Testing, and Diagnostics Capabilities

- Section 8, “Calibration, Testing, and Diagnostics,” of the TR describes the diagnostics and maintenance features provided by HIPS platform and directly addresses IEEE Std 603-1991 Clause 5.7.
- These features include the use of BIST, CRC checks, periodic surveillance testing, and other tests in each type of module as appropriate to verify normal operation.

Subsequent License Renewal (SLR) Guidance Documents and Optimization of the SLR Safety Review Process

**Advisory Committee on Reactor Safeguards (ACRS)
Full Committee Meeting
April 6, 2017
Division of License Renewal
Office of Nuclear Reactor Regulation**

Agenda

- Background
- SLR Guidance Documents
 - Overview of changes to GALL-SLR Report and SRP-SLR
 - Status
- Optimization of SLR Review Process
 - Safety Review
 - Implementation of Activities for SLR

Background

- Part 54 to Title 10 of the *Code of Federal Regulations*, License Renewal Rule
- Staff proposed options for changes to Part 54 for SLR (60-80 years) in SECY 14-0016
- Commission did not approve staff's recommendation to initiate rulemaking in SRM to SECY 14-0016
- In December 2015, draft guidance documents issued for public comment – comment period ended February 29, 2016
- In 2016, staff held numerous public meetings and addressed public comments
- Staff has prepared final guidance documents for issuance

Staff Interactions with ACRS

- Subcommittee meeting – April 8, 2014
- Full committee meeting – May 8, 2014
- ACRS Letter to Commission – May 22, 2014
- Subcommittee meeting (SLR research on technical issues) – November 17, 2015
- Subcommittee meeting – February 17, 2016
- Subcommittee meeting – March 23, 2017
- Full committee meeting – today

SLR Significant Technical Issues

- Neutron embrittlement of the reactor pressure vessel at high fluence
- Stress corrosion cracking of reactor internals and primary system components
- Concrete and containment performance after long-term irradiation and high temperature exposure
- Environmental qualification, performance, and inservice testing of cables

Safety Continues to be Maintained Beyond 60 Years

- License renewal principles are effective to ensure safety
 - Regulatory process ensures that the current licensing basis provides and maintains an acceptable level of safety
 - Each plant's licensing basis must be maintained
 - Additional focus on management of aging effects of in-scope passive, long-lived structures and components

Regulations and Processes Ensure Safe Operation for SLR

- License renewal regulations ensure passive, long-lived structures and components perform intended functions during the subsequent period of extended operation (PEO)
- Subsequent license renewal application (SLRA) review includes environmental and safety reviews, and audits
- Continuous verification of plant safety through reviews and the Reactor Oversight Process (ROP)

SLR Guidance

- Generic Aging Lessons Learned for Subsequent License Renewal (GALL-SLR) Report (NUREG-2191)
 - Provides generic evaluation of aging effects to be managed and appropriate aging management programs (AMPs)
 - Identifies acceptable method to manage aging effects
 - Plant-specific alternatives may be proposed and reviewed
- Standard Review Plan for Review of Subsequent License Renewal Applications for Nuclear Power Plants (SRP-SLR) (NUREG-2192)
 - Provides guidance to NRC staff reviewers to perform safety reviews of the SLRA

Development of SLR Guidance Involved Rigorous Staff Review


- Technical sources used for SLR guidance
 - Expanded Materials Degradation Assessment
 - AMP effectiveness audits
 - Relevant domestic and international operating experience
 - External stakeholder, staff comments

Refinements to Guidance Support 80 Years of Operation


- New GALL-SLR Report AMPs
 - Fluence Monitoring
 - High Voltage Insulators
- Modified approach to aging management for reactor vessel internals for pressurized water reactors (PWRs)
- Modifications to Reactor Vessel Materials Surveillance AMP

Changes include Revisions to Reactor Vessel Material Surveillance AMP

PLANT A
 (1 untested capsule)



PLANT B
 (4 untested capsules)



Changes Include Revisions to Electrical and Structural AMPs

- Expanded Electrical Insulation of Cables AMP from one AMP to three AMPs to address aging of submerged cables at different voltages
- Aging management of concrete
 - Updated for alkali-silica reaction (ASR)
 - Added further evaluation for irradiation of concrete

Overview of Changes to SRP-SLR

- Eliminated some plant-specific further evaluations by pointing to a generic AMP
- Added aging management review (AMR) line items for new material, environment, aging effect and AMP combinations
- Broadened Section 4.3, Metal Fatigue, to provide guidance for all cyclical loading analyses
- Added table of potential plant-specific time-limited aging analyses (TLAAs) (Section 4.7)

Overview of Changes to SRP-SLR

- New Chapter 5 on Technical Specification changes and additions that may be required for aging management
- Added new appendix on review of operating experience for AMPs
- Added detailed Final Safety Analysis Report Supplement summary descriptions in GALL-SLR Report and SRP-SLR

Readiness to Review SLRAs

- GALL-SLR Report AMPs address technical issues
- For a few technical issues, no generic approach to address aging, and will require plant-specific further evaluations
- Applicant's responsibility to evaluate technical issues, develop adequate aging management methods
- NRC is prepared to review SLRAs

SLR Guidance Schedule

Timeframe	Description
April 26, 2017	<ul style="list-style-type: none"> • Commission Meeting on SLR
July 2017	<ul style="list-style-type: none"> • Issuance of final GALL-SLR Report and SRP-SLR NUREGs
December 2017	<ul style="list-style-type: none"> • Issuance of Technical Bases and Public Comments NUREGs
2018	<ul style="list-style-type: none"> • SLRA – Peach Bottom
2019	<ul style="list-style-type: none"> • SLRA – Surry

SLR Optimization

SLR Optimization Presentation Topics

- Subsequent License Renewal Optimization Working Group (SLRO-WG) Purpose, Areas Evaluated and Communications
- SLRO-WG Results for SLRA Safety Evaluation Reports (SER), ACRS Meetings and Review Timeline
- Implementation of Activities for SLR

SLRO-WG Purpose, Areas Evaluated, and Communications

- SLRO-WG Purpose
 - SLRO-WG was established to evaluate the SLRA review process to identify areas where the process could be made more efficient and effective and to optimize the staff's performance relative to timeliness, application of staff resources and quality of products.
- Areas Evaluated and Stakeholder Communications
 - SLRO-WG evaluation included both safety and environmental project management tools, audits and inspections, the SERs and the SLRA review timeline.
 - SLRO-WG presented proposed staff positions to industry and stakeholders during several public meetings and considered comments.

SLRO-WG Recommendations

Safety Review and ACRS Meetings

- SLRA Review Timeline
 - SLRA review timeline goal, for both safety (SER) and environmental (EIS) reviews, will be eighteen months (without a hearing), which will begin at the completion of the acceptance review.
- Draft Safety Evaluation Report
 - Staff intends to present a draft Final SER to the ACRS Subcommittee and a draft Final SER to the ACRS Full Committee (revised as necessary).
- ACRS Subcommittee and Full Committee Scheduling Request
 - Staff will request scheduling of the ACRS Subcommittee meeting and ACRS Full Committee meeting to occur in consecutive months.

Implementation of Activities for SLR – Agenda

- Inspection/Audit Timeline for License Renewal and SLR
- Purpose of IPs 71002, 71003
- Crosswalk of Activities for SLR
- Assurance of Implementation of Activities for SLR

LR Inspection/Audit Timeline

AMP Audit

- 3-5 months after LRA received
- 30 auditors to review most AMPs and verify consistency with GALL

1st IP 71002

- 9-11 months after LRA received
- 5-6 inspectors to review most AMPs to assess applicant's plans to implement AMPs, and evaluate effectiveness of implementation activities

1st IP 71003, Phase 1

- After renewed license approved
- During the last outage prior to PEO to review aging management activities in inaccessible areas

1st IP 71003, Phase 2


- After renewed license approved
- 3-6 months prior to PEO to verify AMPs implemented and inspection/testing activities completed

1st IP 71003, Phase 3

- After renewed license approved
- 1 year into PEO to review aging management activities, follow up on issues

1st IP 71003, Phase 4

- After renewed license approved
- 5-10 years into PEO to verify AMP effectiveness, and completion of inspection/testing activities



SLR Inspection/Audit Timeline

AMP Audit

- 3-5 months after LRA received
- 30 auditors to review most AMPs and verify consistency with GALL

1st IP 71002

- 9-11 months after LRA received
- 5-6 inspectors to review most AMPs to assess applicant's plans to implement AMPs, and evaluate effectiveness of implementation activities

1st IP 71003, Phase 1

- After renewed license approved
- During the last outage prior to PEO to review aging management activities in inaccessible areas

1st IP 71003, Phase 2

- After renewed license approved
- 3-6 months prior to PEO to verify AMPs implemented and inspection/testing activities completed

1st IP 71003, Phase 3

- After renewed license approved
- 1 year into PEO to review aging management activities, follow up on issues

1st IP 71003, Phase 4

- After renewed license approved
- 5-10 years into PEO to verify AMP effectiveness, and completion of inspection/testing activities

AMP audit

- 3-5 months after SLRA received
- 5-6 auditors (1 inspector invited to participate in audit)
- Verify AMPs consistent with GALL
- Review sample of AMPs and activities that are new or not previously reviewed
- Assess plans to implement AMPs, and evaluate effectiveness of activities
- Walkdowns and interviews with plant personnel

2nd IP 71003, Phase 1

- After renewed license approved
- During the last outage prior to PEO to review NEW inspections/testing activities in inaccessible areas

2nd IP 71003, Phase 2


- After renewed license approved
- 3-6 months prior to PEO to verify implementation of NEW AMPs and completion of inspection/testing activities

2nd IP 71003, Phase 3

- After renewed license approved
- 1 year into subsequent PEO to review inspections/testing activities and follow up on issues

2nd IP 71003, Phase 4

- After renewed license approved
- 5-10 years into subsequent PEO to verify ongoing implementation of AMPs and completion of activities



Purpose of IP 71002

- Performed during license renewal application review, approximately 11 months after receipt of a license renewal application (license not yet renewed)
- Pre-renewal inspection
- Verify processes for Scoping and Screening
- Assesses applicant's plans to implement AMPs
 - Walkdowns to observe aging effects
 - Review past tests and inspections
- Verify applicant's Operating Experience review

Purpose of IP 71003

- Post-Approval Site Inspection for License Renewal
- Verify implementation of AMPs
- Verify completion of activities such as, inspections, tests, and analyses
- Verify license conditions met
- Verify changes to commitments, conditions, and UFSAR in accordance with regulations
- Verify readiness to enter PEO

Phases of IP 71003

- Performed after approval of renewed license
 - Phase 1: Last outage prior to PEO, review inspections and tests in inaccessible areas
 - Phase 2: 3-12 months prior to PEO, verify AMP implementation, completion of activities
 - Phase 3: 1-2 years into PEO, follow up issues identified during Phase 2, activities completed
 - Phase 4 (New): 5-10 years into PEO, verify licensee managing aging effects in accordance with AMPs, ensure SSCs maintain ability to perform their intended function(s)

Crosswalk of Activities Assure Functions Accomplished for SLR

Functions of the License Renewal Application Review	Accomplished during License Renewal by	To Be Accomplished during SLR by
Plant walkdowns and review of material condition of plant	IP 71002, AMP Audit, IP 71003, ROP Baseline inspections	AMP Audit, IP 71003, ROP Baseline inspections
Interviews with plant personnel	IP 71002, AMP Audit, IP 71003, ROP baseline inspections	AMP Audit, IP 71003, ROP baseline inspections
AMP evaluation	IP 71002, AMP Audit, IP 71003	AMP Audit, IP 71003
Scoping and Screening Review	IP 71002, Scoping and Screening Audit	AMP Audit
Operating Experience Review	IP 71002, Scoping and Screening Audit	AMP Audit
Observations identified and documented in reports	IP 71002, AMP Audit, safety evaluation report, IP 71003, ROP baseline inspections	AMP Audit, safety evaluation report, IP 71003, ROP baseline inspections

ROP Updated to Include Aging Management Inspection Guidance

- Baseline inspection procedures in the ROP updated to incorporate aging management inspection guidance include:
 - IP 71111.04 Equipment Alignment
 - IP 71111.06 Flood Protection Measures
 - IP 71111.07 Heat Sink Performance
 - IP 71111.11 Inservice Inspection Activities
 - IP 71111.12 Maintenance Effectiveness
 - IP 71111.21 Component Design Bases Inspection
 - IP 71152 Problem Identification and Resolution

Summary of SLR Optimization

- We are developing a more efficient process for reviewing all aspects of an SLRA and conducting audits and inspections to assure the applicant's ability and readiness to implement AMPs
- License renewal functions sufficiently assessed for SLR
- HQ and Regions will work together to ensure audits and inspections are tailored to plant-specific needs
- Audits and inspections will provide reasonable assurance of continued safe plant operation for 80 years