

NOV 07 1974

Docket Nos. 50-237
and 50-249

Commonwealth Edison Company
ATTN: Mr. J. S. Abel
Nuclear Licensing Administrator -
Boiling Water Reactors
P. O. Box 767
Chicago, Illinois 60690

DISTRIBUTION:

AEC PDR
Local PDR
Docket
ORB #2 Reading
Attorney, OGC
RO (3)
TJCarter
DLZiemann
RSilver
RMDiggs
JRBuchanan, ORNL
TBAbernathy, DTIE
SVarga
ACRS (16)

Gentlemen:

Your letter of June 27, 1974 requested three changes to the Technical Specifications of License Nos. DPR-19 and DPR-25 for Dresdens 2 and 3. The requested changes are concerned with requirements on liquid control system testing, containment atmospheric dilution system and reporting. No safety analysis was included in your letter to support the first two requested changes. Therefore, we conclude that the requests have not been adequately justified and your application is denied. The third request, pertaining to reporting requirements, is discussed in a separate letter to you dated October 29, 1974.

Sincerely,
Original signed by:
Karl R. Goller

Karl R. Goller, Assistant Director
for Operating Reactors
Directorate of Licensing

cc: See next page

OFFICE >	L:ORB-2	L:ORB-2	L:OR	KRG		
SURNAME >	RSilver/tc	DLZiemann	KRGoller			Appl Amend
DATE >	10/31/74	10/4/74	10/6/74			

John W. Rowe, Esquire
Isham, Lincoln & Beale
One First National Plaza
Chicago, Illinois 60670

Chairman, Board of Supervisors
of Grundy County
Morris, Illinois 60451

Anthony Z. Roisman, Esquire
Berlin, Roisman and Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Morris Public Library
604 Liberty Street
Morris, Illinois 60451

OFFICE >						
SURNAME >						
DATE >						