


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT  
0.05 ft<sup>2</sup> BREAK AT 102-PERCENT POWER 30-min.  
OPERATOR ACTION TEMPERATURE VS TIME

FIGURE 3J-1



REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.2 ft<sup>2</sup>  
BREAK AT 70-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-2






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.2 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-3




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.4 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-4




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.6 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-5




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.8 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-6




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 1.2 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-7




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 1.1 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-8




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 4.6 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
TEMPERATURE VS TIME

FIGURE 3J-9



REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT  
COMBINED TEMPERATURE PROFILE

FIGURE 3J-10






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.05 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
PRESSURE VS TIME

FIGURE 3J-11




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 0.2 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
PRESSURE VS TIME

FIGURE 3J-12




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 1.1 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
PRESSURE VS TIME

FIGURE 3J-13




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT 4.6 ft<sup>2</sup>  
BREAK AT 102-PERCENT POWER  
PRESSURE VS TIME

FIGURE 3J-14




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT  
COMBINED PRESSURE PROFILE

FIGURE 3J-15



<b>ENVELOPE</b>	<b>CASE 2</b>	<b>CASE 4</b>
<b>CASE 1</b>	<b>CASE 3</b>	<b>CASE 5</b>


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT COMBINED  
TEMPERATURE PROFILE FOR  
MODEL 54F CASES AT 102% POWER

FIGURE 3J-16



REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

HELB OUTSIDE CONTAINMENT COMBINED  
TEMPERATURE PROFILE FOR  
MODEL 54F CASES AT 70% POWER

FIGURE 3J-17

**3K HIGH-ENERGY LINE PIPE BREAK (OUTSIDE CONTAINMENT)**

**TABLE OF CONTENTS**

	<u>Page</u>
3K.1.0 INTRODUCTION.....	3K-1
3K.2.0 REPORT CRITERIA.....	3K-1
3K.2.1 Analysis Criteria (General).....	3K-1
3K.2.1.1 Analysis Criteria for Systems Whose Operating Temperature and Pressure at Power Exceed 200°F and 275 psig .....	3K-2
3K.2.1.2 Analysis Criteria for Systems Whose Operating Temperature or Pressure at Power Exceed 200°F or 275 psig .....	3K-3
3K.2.2 Single Active Failure Criteria.....	3K-3
3K.3.0 EQUIPMENT NECESSARY FOR COLD SHUTDOWN OF THE REACTOR.....	3K-4
3K.4.0 PIPE RUPTURE ANALYSIS .....	3K-4
3K.4.1 Piping Systems with Temperatures Higher Than 200°F and Pressures Higher Than 275 psig .....	3K-5
3K.4.1.1 Main Steam Line Rupture .....	3K-5
3K.4.1.2 Feedwater and Auxiliary Feedwater Line Rupture.....	3K-10
3K.4.1.3 Condensate or Extraction Line Rupture.....	3K-15
3K.4.1.4 Auxiliary Steam System Rupture (Auxiliary Feedwater Pump Turbine-Driven Steam Supply).....	3K-15
3K.4.1.5 Steam Generator Blowdown Line Rupture .....	3K-19
3K.4.1.6 Chemical and Volume Control System (CVCS) Letdown Line Rupture.....	3K-19
3K.4.1.7 Boron Thermal Regenerative System (BTRS) Line Rupture .....	3K-22
3K.4.1.8 Steam Generator Blowdown Processing System (SGBD) Line Rupture .....	3K-25



**TABLE OF CONTENTS**

	<u>Page</u>
3K.4.2	Piping Systems With Power Operation Temperatures Higher Than 200°F or Pressures Higher Than 275 psig ..... 3K-26
3K.4.2.1	CVCS Charging Line Rupture..... 3K-26
3K.4.2.2	Auxiliary Feedwater System Rupture..... 3K-28
3K.4.2.3	Auxiliary Steam and Condensate Recovery System Line Rupture ..... 3K-31
3K.4.2.4	Plant Heating System Line Rupture..... 3K-32
3K.5.0	EMERGENCY SHUTDOWN PROCEDURE ..... 3K-33

**LIST OF ATTACHMENTS**

Attachment A	General Information Required for Consideration of Effects of a Piping System Break Outside Containment
Attachment B	Pipe Whip Restraint Design
Attachment C	Methods Used To Calculate Blowdown Rates for High-Energy Fluid Line Ruptures
Attachment D	Compartment Pressure Temperature Analysis Computer Program Description
Attachment E	Calculation Methods for Compartment Pressurization
Attachment F	Methods Used To Calculate Pipe Whip Thrust Loads and Jet Impingement Forces
Attachment G	Main Steam Room and Pipe Chase Structural Stress Analysis

**LIST OF TABLES**

3K.2-1	Criteria for Identification of High-Energy Lines and Effects Considered
3K.3-1	Equipment Required Following a High-Energy Line Break - Unit 1 (Outside Containment)

## APPENDIX 3K

### HIGH-ENERGY LINE PIPE BREAK (OUTSIDE CONTAINMENT)

#### 3K.1.0 INTRODUCTION

This appendix was prepared in response to the NRC letter from A. Giambusso, Deputy Director for Reactor Project - Directorate of Licensing, to the Alabama Power Company, dated December 12, 1972. The Farley Nuclear Plant complies with the criteria set forth in attachment A, parts 1 and II.

It describes the analyses performed to determine the effects of a high-energy line break outside containment upon the Farley Nuclear Plant. The appendix applies to Units 1 and 2. Since the Unit 2 main steam room arrangement is similar to the Unit 1 main steam room arrangement, the results and conclusions of these analyses are applicable to both units.

On December 7, 1984, the NRC issued Information Notice 84-90, "Main Steam Line Break Effect on Environmental Qualification of Equipment." This notice raised the concern that a large main steam line break may not be the most limiting with respect to peak compartment and equipment temperature. In response to this notice, a new analysis was performed to determine the main steam valve room temperature and pressure response to a spectrum of postulated break sizes. This analysis supersedes the analysis included in this appendix with regard to compartment environmental conditions for the postulated main steam line break inside the main steam valve room. Details of the analysis are presented in appendix 3J. The main steam line break analysis presented in this appendix remains in the FSAR for completeness and to retain the original structural design basis for the main steam valve room.

#### 3K.2.0 REPORT CRITERIA

This section describes the criteria considered in assessing the effects of a full area pipe rupture or pipe crack in a high-energy line outside the containment. These criteria were developed from the December 1972 NRC document entitled "General Information Required for Consideration of the Effects of a Piping System Break Outside Containment," the Branch Technical Positions APCS 3-1 and MEB 3-1 as attached to Standard Review Plans 3.6.1 and 3.6.2, and subsequent discussions with the NRC. These criteria are included as attachment A, parts I and II.

#### 3K.2.1 ANALYSIS CRITERIA (GENERAL)

The systems analyzed were those piping systems whose operating temperature exceeds 200°F or whose operating pressure exceeds 275 psig. The effects of pipe whip were considered only for those piping systems whose operating pressure and temperature exceed 275 psig and 200°F, respectively. For piping systems whose pressure exceeds 275 psig, but whose temperature does not exceed 200°F, or whose temperature exceeds 200°F, but whose pressure does not exceed 275 psig, the effects of a critical crack only were considered. Piping systems

## FNP-FSAR-3K

whose temperatures were less than 200°F and whose pressures were less than 275 psig were not considered.

As discussed in attachment A, double ended breaks were not assumed for pipe sizes equal to or less than 1 in., longitudinal breaks were not assumed for pipe sizes less than 4 in., and critical cracks were not assumed for pipe sizes equal to or less than 1 in.

Plant conditions prior to rupture were assumed to be power operation or hot shutdown. (Power operation and hot shutdown conditions are described in chapter 15.0.)

No other accident was assumed to occur concurrently with the pipe failure.

Pipe whip forces and jet impingement loads were derived using the methods outlined in attachment F.

The worst case effects of jet impingement from a break or critical crack, as defined in later sections, were analyzed as to their consequences on mechanical or electrical equipment that must be available to bring the plant to hot shutdown and eventually to a cold shutdown condition.

Concurrent loss of both preferred offsite power and auxiliary power from the generator was assumed for those accidents that cause a turbine trip.

### **3K.2.1.1 Analysis Criteria for Systems Whose Operating Temperature and Pressure at Power Exceed 200° F and 275 psig**

The following systems were analyzed for the effects listed in table 3K.2-1:

<b><u>System</u></b>	<b><u>Break Type and Effects Considered</u></b>
Main steam	B
Main feedwater	B
Auxiliary feedwater (from junction with main feedwater line to first isolation valve)	B
Auxiliary steam (To steam driven auxiliary feedwater pump)	B
Steam generator blowdown	B

<u>System</u>	<u>Break Type and Effects Considered</u>
CVCS (letdown line from containment penetration to pressure control valve)	B
BTRS (supply and return lines for the tube side of the letdown reheat heat exchanger)	B

In Seismic Category I piping systems, or Seismic Category II piping systems which were seismically analyzed, the pipe breaks are assumed to occur at the terminal ends and at high stress locations as described in attachment A. The magnitudes of the circumferential and longitudinal stresses were used to define either a double ended or a longitudinal break at each break location. Both break types were not postulated to occur at a single location.

**3K.2.1.2 Analysis Criteria for Systems Whose Operating Temperature or Pressure at Power Exceed 200°F or 275 psig**

The following systems were analyzed for effects listed in table 3K.2-1:

<u>System</u>	<u>Break Type and Effects Considered</u>
CVCS charging line (including reactor coolant pump seal water)	A
Auxiliary feedwater (from the three auxiliary feedwater pumps to last isolation valve connecting with main feedwater line)	A
Auxiliary Steam and Condensate Recovery System (inside the Auxiliary Building)	C and note 1 of table 3K.2-1
Plant Heating System (PHS) (inside the Auxiliary Building)	C and note 1 of table 3K.2-1

Critical crack breaks were assumed to occur in these systems at any location. They were located to maximize the consequences on required safe shutdown equipment or on structures. The crack length used was one-half the pipe diameter and the width used was one-half the wall thickness of the failed pipe.

**3K.2.2 SINGLE ACTIVE FAILURE CRITERIA**

An occurrence which results in the loss of capability of an active component to perform its intended function is an active failure. Multiple failures resulting from a single occurrence are considered to be a single failure. Fluid and electric systems are considered to be designed to accommodate an assumed single active failure if such a failure does not result in the loss of the capability of the system to perform its safety function.

## FNP-FSAR-3K

The analysis in this appendix considers a single active failure within the combined systems required to effect the cold-shutdown condition. The following fluid systems were designed to perform their required functions to bring the plant to a cold shutdown assuming a single failure concurrent with a high-energy line break outside containment:

- A. Reactor coolant system (RCS).
- B. Low-head/high-head safety injection system.
- C. Residual heat removal system (RHRS).
- D. Auxiliary feedwater system (AFS).
- E. Service water system (SWS).
- F. Component cooling water system (CCWS).
- G. Chemical and volume control system (CVCS).
- H. Diesel fuel oil system.
- I. Main steam system (MSS) from steam generators to and including main steam line isolation valves.
- J. Main feedwater system (MFS) from steam generators to and including feedwater isolation valves.

### **3K.3.0 EQUIPMENT NECESSARY FOR COLD SHUTDOWN OF THE REACTOR**

Table 3K.3-1 lists the equipment required to mitigate the consequences of a high-energy line rupture outside the containment and obtain a cold shutdown condition. This equipment, as well as any equipment necessary to mitigate the consequences of a high-energy line break, is protected so as not to be adversely affected by the effects of a high-energy line break outside containment.

### **3K.4.0 PIPE RUPTURE ANALYSIS**

This section describes, on a system-by-system basis, how Farley Nuclear Plant safety considerations will be implemented. Attachment A, Parts I and II, provides the information required for consideration of a piping system break outside containment.

High-energy piping systems within the plant, as described in table 3K.2-1, are classified into two groups for this purpose. Group 1 (subsection 3K.4.1) contains those systems whose operating temperature and pressure will exceed 200°F and 275 psig during power operation or while at hot standby; they are outlined in subsection 3K.4.1. The analysis criteria for all Group 1 piping systems are given in paragraph 3K.2.1.1. Group 2 (subsection 3K.4.2) consists of those systems whose temperature or pressure exceeds either 200°F or 275 psig; they are outlined in

subsection 3K.4.2. The analysis criteria for Group 2 piping systems are given in paragraph 3K.2.1.2.

Stress analysis results utilized in the criteria for determining pipe break locations are documented in the applicable piping stress calculation for each piping system. Whip restraint locations based on postulated pipe break locations are shown on applicable civil design drawings.

### **3K.4.1 PIPING SYSTEMS WITH TEMPERATURES HIGHER THAN 200°F AND PRESSURES HIGHER THAN 275 psig**

#### **3K.4.1.1 Main Steam Line Rupture**

The three main steam lines carry saturated steam at 547°F and 1005 psig for no-load hot standby and 516°F and 775 psig for 100-percent load operation. Since the main steam piping is greater than 4-in. nominal pipe size, both longitudinal and/or double-ended ruptures were considered at the break locations. Critical cracks were also considered.

Additional information regarding a balance of plant accident analysis of the consequences of a rupture in the main steam lines is given in subsection 3K.5.0.

#### **3K.4.1.1.1 Main Steam System (MSS) Design**

The portion of the MSS located in the auxiliary building is designed to carry steam from the three steam generators to the turbine-generator and associated equipment located in the turbine building and to the TDAFWP located in the auxiliary building.

Drawings D-175033, sheet 1; D-175033, sheet 2; D-170114, sheet 1; D-170114, sheet 2; D-205033, sheet 1; D-205033, sheet 2; and D-200007 show the schematic arrangement of the MSS piping in the auxiliary building. The main steam piping from the steam generators, up to and including the second isolation valve in each main steam line, and the main steam supply to the TDAFWP have safety-related functions. Those portions of the system are classified as Safety Class 2A and are designed as Seismic Category I. Main steam piping downstream of the main steam line isolation valves is designed in accordance with ANSI B31.1.0 and is Seismic Category II. The design pressure rating of the MSS piping is based on the maximum pressure and temperature that occur at no-load conditions.

Saturated steam is generated in the three steam generators and flows out through the containment wall in three 32-in. main steam lines to the main steam isolation valves. Downstream from the main steam isolation valves, the three main steam lines form a common header from which two 36-in. lines conduct steam to the turbine-generator. A flow restrictor, integral with each steam generator, is provided inside the containment to limit steam generator blowdown in the event of a steam line break.

The main steam line from each steam generator is provided with five spring loaded safety valves and one power-operated atmospheric relief valve. These valves, which are Safety



Class 2A and Seismic Category I, are located between the containment penetration and the first main steam isolation valve on a section of main steam line which has a 34.55-in. outside diameter.

The safety valves are direct spring loaded. Each valve is set at a different incremental opening pressure between 1075 psig and 1129 psig. Umbrella-type vent stacks route safety valve discharge through penetrations in the auxiliary building roof.

The power-operated atmospheric relief valves are air-operated diaphragm type; they are set to discharge before the first spring loaded safety valve opens. Discharge from the power-operated atmospheric relief valves is piped to the atmosphere through penetrations in the auxiliary building roof. The discharge piping has been analyzed for thermal, seismic, and normal operating loadings.

Two pneumatic cylinder operated, swing disc trip, main steam line isolation valves are installed in series in each main steam line outside the containment and downstream from the safety valves. Each pair of isolation valves is bypassed by a 3-in. warming and pressure equalizing line which contains two air-operated isolation valves. The main steam line isolation valves and bypass valves are of a fail close design, are classified as Safety Class 2A, and are designed to meet Seismic Category I requirements.

On two of the three main steam lines outside the containment and downstream from the safety valves, and upstream of the main steam line isolation valves, there is a 3-in. takeoff that supplies steam to the TDAFWP.

The main steam piping outside the auxiliary building is routed from the auxiliary building across an open area, into the turbine building, and on to the turbine stop and control valves.

#### **3K.4.1.1.2 Main Steam System Piping**

The MSS piping outside containment was analyzed in accordance with the criteria described in subsection 3K.2.0 and the methods outlined in attachment F.

The Seismic Category II portions of the main steam line were analyzed seismically to determine the high stress points and postulated break locations.

#### **3K.4.1.1.3 Areas Affected by a Steam Line Rupture**

The main steam system piping penetrates the containment wall just above the 127-ft floor level, runs through the main steam room to a pipe chase, runs up the chase, and exits the auxiliary building at el 179 ft 8 in. From the auxiliary building, the two main steam headers proceed across the yard to the turbine building. Each of the three main steam lines between the containment penetrations and the main steam header inside the auxiliary building is separated by a jet impingement wall. Jet impingement barriers are provided where necessary to preclude damage to feedwater control valves and outboard stop-check valves from high-energy line breaks at postulated breakpoints in the main steam and feedwater valve room.

The main steam system inside the turbine building is not located near any safety-related equipment whose safety function would be impaired by a line rupture. Jet and pipe whip forces resulting from a ruptured main steam line cannot cause the loss of the turbine building.

#### **3K.4.1.1.4 Pipe Whip**

The methods outlined in attachment F were used to analyze full area pipe breaks for pipe whip.

Because of the large resultant jet thrust forces, pipe whip restraints are located at various places along the piping system to prevent any whipping of the pipe due to a rupture at the postulated break locations. A description of pipe restraint design is given in attachment B. The forces that the pipe would exert in the event of a full area rupture are given in attachment F. The forces are assumed to be instantaneous.

#### **3K.4.1.1.5 Jet Impingement**

The jet impingement force, caused by the momentum change of fluid striking a target, is a function of the upstream fluid condition, fluid enthalpy, source pressure, break dimensions, distance from the target, and jet geometry. The jet forces were calculated using the methods outlined in attachment 3-F. The jet forces caused by the escaping fluid are assumed to develop instantaneously (with zero rise time).

The following were analyzed for the effects of jet impingement from a longitudinal or circumferential break and critical crack inside the auxiliary building.

- Main steam room structure.
- Adjacent containment wall.
- Pipe chase structure.
- Equipment contained in the main steam room listed in table 3K.3-1.

The results of the analysis are as follows:

Each of the above-referenced structural elements was analyzed for a force corresponding to the jet force dispersed over the impingement area. Each structure is sufficient to withstand the jet forces as described in attachment G.

All piping systems and their components listed in paragraph 3K.4.1.1.3 are so supported or protected by barriers as to withstand the effects of all jet impingement forces from all postulated break locations and from critical cracks. Safety-related instrumentation that would have been adversely affected by jet impingement has been removed from the main steam room to a nonaffected area.

For safety and design conservatism, cable trays have been eliminated from the main steam room. The cables have been routed in conduits far removed from the pipe break locations so as to ensure no damage to the conduit or its supports, except for cables serving the main steam isolation valves. Of necessity, these cables serving the main steam isolation valves are in close proximity to the main steam lines. In this case, a pipe break damaging both redundant valve circuits in the broken line would be equivalent to a rupture in the main steam line upstream of the isolation valves, as analyzed in section 3K.5.0 and paragraph 3K.4.1.1.9. In view of the separation wall between steam lines, a pipe break on a steam line will not affect the redundant isolation valves and associated circuits on the other steam lines.

#### **3K.4.1.1.6    Compartment Pressurization**

The postulated main steam line ruptures in the main steam room and adjacent pipe chase structure were analyzed to determine the effects of the resulting compartment pressurization. Because of the similarity of the steam and feedwater piping, which runs through the main steam room and pipe chase, the various postulated breaks in these two piping runs were analyzed to determine the worst case break in the main steam room and the worst case break in the pipe chase structure. The methods outlined in attachment C were used to calculate steam and feedwater mass and energy blowdown rates for full area pipe ruptures.

The analysis outlined in attachment E was used to predict the compartment pressure in the main steam room and pipe chase structure. A description of the program used is given in attachment D. The compartmentation used for the worst case line rupture in the main steam room is given in figure E-3 (in attachment E). The compartmentation used to evaluate the worst break in the pipe chase is shown in figures E-6 and E-6A. The worst case pressures of 5.8 psig and 28.8 psig were used along with the maximum pressures of the other compartments for the structural analysis of the main steam room and the pipe chase, respectively, after the structural modifications described below. See figures E-1, E-1A, E-2, and E-2A for time pressure/temperature curves.

The criteria used to evaluate the pressurization analysis were that the effects of a steam line rupture would not propagate to areas other than those where the rupture occurred and that the walls separating the three main steam lines must remain intact. Using the peak pressures given in attachment E and the analytical methods outlined in attachment G, the main steam room and the pipe chase were analyzed for structural adequacy during and after a main steam line rupture.

Initial results indicated that the configuration of the main steam room and the exterior pipe chase as originally envisioned was not viable. Compartment pressures were higher than could be tolerated and structural walls and slabs were overloaded. This situation was corrected by deleting intermediate floors and walls to provide increased free volume and to provide additional vent paths to atmosphere for any steam discharging from a break. In the pipe chase the intermediate wall was removed and replaced by horizontal structural steel props; also, the pipe chase roof was raised from el 161 ft 8 in. to el 175 ft. Protection from external missiles was provided in the form of heavy steel grating, and structural integrity was preserved by the addition of structural steel.

In the main steam room the main steam room roof was raised from el 155 to el 205 to form a penthouse structure. This new roof is supported on structural steel. The north, south, and west faces of the penthouse are open to allow venting to the atmosphere. A grating for protection against tornado missiles has been installed. Flame retardant polyethylene or a similar flame-retardant plastic sheeting may be applied to the outside of the exterior grating of the MSVR in winter to prevent freeze damage to critical instruments. This sheeting will be applied such that, in the event of a pipe break accident, the sheeting will tear away so that the pressure in the MSVR will not exceed its design pressure.

Structural integrity of these Category I structures has been retained throughout the revised structures by keeping stresses below the allowable working stresses permitted in Codes ACI 318-69 and AISC, 1969 edition. In addition, an analysis using finite element methods was performed to verify the manual calculations. The details and results of this analysis are described in attachment G.

#### **3K.4.1.1.7 Flooding from a Steam Line Break**

The most critical flooding condition for the main steam room and the pipe chase structure is from a break in the main feedwater lines, as discussed in paragraph 3K.4.1.2.7.

#### **3K.4.1.1.8 Environmental Effects**

The environmental effects considered as a result of a high-energy fluid line break were as follows:

- Pressure (its effect on equipment).
- Temperature.
- Humidity.

There is no safety-related equipment in the main steam room or the pipe chase structure that will be affected by the pressures described in paragraph 3K.4.1.1.6.

The peak temperatures and pressures (predicted by the computer code, reference paragraph 3K.4.1.1.6) for the worst case steam or feedwater line rupture in the main steam room at break Location 57 are 308°F and 5.8 psig, respectively. The pressure and temperature/time curves for break Location 57 are given in figures E1 and E2, respectively. As a result of the high temperatures predicted, the safety-related sensing instrumentation that could have been affected in the main steam room has been removed to a nonaffected area.

In response to IE Information Notice 84-90, a new MSLB analysis was performed for the main steam valve room. The results of this analysis supersede the appendix 3K analysis with regard to main steam valve room pressure and temperature conditions. The details of the new analysis and the corresponding pressure and temperature curves are presented in appendix 3J.

In that the post-LOCA environment is more severe than that of the main steam valve room, these units will be able to perform their design function in the event of a steam line break in this room.

#### **3K.4.1.1.9 Emergency Shutdown With a Main Steam Line Rupture**

The equipment necessary for cold shutdown of the reactor is given in table 3K.3-1. The effect of a main steam line break upstream of the isolation valves on plant shutdown is the loss of one steam generator for reactor decay heat removal immediately after reactor trip.

For a large steam line break downstream of the isolation valves the redundant main steam isolation valves will ensure isolation of the steam generators from the break. Following this break all steam generators will be available for decay heat removal.

For large steam line breaks the equipment that must be available to accomplish a cold shutdown is listed in table 3K.3-1.

#### **3K.4.1.2 Feedwater and Auxiliary Feedwater Line Rupture**

The three 14-in. feedwater lines carry water at 437°F and 923 psig at 100-percent load. Feedwater temperatures and pressures do not exceed 440°F and 1055 psig under any load conditions. The pipe break criteria as described in paragraph 3K.2.1.1 were used for the analysis. Since the main feedwater piping is greater than 4-in. nominal pipe size, longitudinal and/or double-ended circumferential ruptures were considered at the break locations. Critical cracks were also considered. Additional information regarding a balance-of-plant accident analysis of the consequences of a rupture in the main feedwater line is given in subsection 3K.5.0.

The auxiliary feedwater piping considered in this section of the appendix was that portion of piping from its junction with each main feedwater line back to the first auxiliary feedwater isolation valve. The remaining portion of the auxiliary feedwater piping is discussed in paragraph 3K.4.2.2. The effects of a pipe rupture in that portion of the auxiliary feedwater piping described above were analyzed using the same criteria and system temperatures and pressures as that used for the main feedwater system.

##### **3K.4.1.2.1 Feedwater and Auxiliary Feedwater System Design**

The portion of the feedwater system located in the auxiliary building is designed to carry feedwater from the turbine building into the containment to the three steam generators.

Drawings D-170117, sheet 1; D-170117, sheet 2; D-170117, sheet 3; D-170117, sheet 4; D-175073; D-200011, sheet 1; D-200011, sheet 2; D-200011, sheet 3; and D-205073 show the schematic arrangement of the main feedwater piping in the auxiliary building and yard area. The main feedwater piping from the three steam generators up to and including the feedwater isolation valve located outside containment are classified as Safety Class 2A and are designed

as Seismic Category I. Main feedwater piping upstream from the feedwater isolation valves is designed in accordance with ANSI B31.1.0.

Feedwater flow enters the auxiliary building through three 14-in. lines. Inside the auxiliary building each line contains an air-operated feedwater flow control valve that, for maintenance purposes, has a manually-operated gate valve installed on either side. The feedwater flow in each line passes through a containment penetration and continues to the corresponding steam generator. Between the feedwater isolation valve and the containment penetration, each feedwater line has a 4-in. connection for flow from the auxiliary feedwater system and a 1-in. connection for flow from the chemical injection system.

The auxiliary feedwater system is designed to supply feedwater to the steam generators during plant startup, cooldown, and emergency conditions when the normal feedwater supply is not available. The system contains two motor-driven pumps, one turbine-driven pump, associated piping, valves, and instrumentation. Each of the motor-driven pumps or the turbine-driven pump is designed to supply the steam generators with the required flow for a normal safe shutdown of the reactor coolant system, as described in subsection 6.5.1. The steam supply piping to the turbine-driven pump is discussed in paragraph 3K.4.1.4.1.

The auxiliary feedwater system is an engineered safety feature (ESF) and is designed to meet Seismic Category I requirements. The pumps are normally aligned to take suction from the condensate storage tank. One 8-in. suction header supplies condensate to the two motor-driven pumps and a separate 8-in. suction line supplies condensate to the turbine-driven pump. Each pump's individual suction line contains a locked open isolation valve and a nonreturn valve.

A backup source of water for the pumps is provided from the safety-related portion of the service water system. The service water is isolated from the normal suction piping by two normally closed motor-operated gate valves. Each of the three pumps can be supplied with water from either of the two redundant service water headers.

Each of the two motor-driven pumps discharges through a nonreturn valve and an isolation valve into a common header. From this header, individual lines feed each steam generator through a control valve station, consisting of an air-operated control valve, locked-open manual block valves, and a nonreturn valve.

The turbine-driven pump discharges through a nonreturn valve and branches into three lines, each containing a control valve station. Downstream of the control valve station, each of these three lines joins with the corresponding line from the motor-driven pumps. A single supply line then connects to each of the three main feedwater lines downstream of the main feedwater stop valve. The single auxiliary feedwater line for each steam generator contains a remote manual stop-check valve. This normally open valve can be used to isolate auxiliary feedwater flow to a faulty steam generator. The swing check valve normally functions to prevent backflow of main feedwater into the auxiliary feedwater system. In addition, normally open motor-operated isolation valves are provided in the pump discharge header and supply piping. These valves can be operated from the control room to isolate failures in the steam and feedwater systems.

Each pump has a minimum flow recirculation line with a pressure reducing orifice or a locked manually operated anticavitation pressure reducing flow control valve, a nonreturn valve, and a

locked open manual block valve. In addition to the minimum flow recirculation line, each pump has a manual locked closed recirculation system and a breakdown orifice for testing of the pump at the design point. The minimum flow recirculation line and the test line for the three pumps are joined together and routed to the condensate storage tank.

#### **3K.4.1.2.2 Feedwater and Auxiliary Feedwater System Piping**

The main feedwater piping outside containment and inside the auxiliary building and that portion of the auxiliary feedwater piping inside the auxiliary building described in paragraph 3K.4.1.2 were analyzed in accordance with the criteria described in section 3K.2.0.

Main feedwater and auxiliary feedwater lines, including the Seismic Category II piping, were seismically analyzed to obtain seismic loading in order to determine the high stress locations. Using this analysis, the pipe break locations were postulated.

#### **3K.4.1.2.3 Areas Affected by a Feedwater or Auxiliary Feedwater Line Rupture**

The three main feedwater lines penetrate the containment at el 141 ft 6 in. and follow approximately the same path as the main steam lines, as described in paragraph 3K.4.1.1.3.

The areas in the auxiliary building affected by a rupture in the main feedwater system and the auxiliary feedwater system will be the same as the main steam system; therefore, the environmental consequences will be limited to the main steam room and the pipe chase, as outlined in paragraph 3K.4.1.1.3.

The areas inside the turbine building that would be affected by a feedwater line rupture contain no safety-related equipment whose safety function would be impaired by a line rupture. The forces and flooding resulting from a feedwater line rupture cannot cause the loss of the building.

Safety-related equipment and available equipment necessary for a cold shutdown located in the main steam room and the pipe chase are listed in table 3K.3-1.

#### **3K.4.1.2.4 Pipe Whip**

The methods outlined in attachment F were used to analyze full area pipe breaks for pipe whip and the resultant jet thrust forces. The forces experienced in the event of a full area break are given in attachment F.

Because of the large resultant jet thrust forces, pipe whip restraints are located at various places along the pipe system to prevent whipping of the pipe due to rupture at the postulated break locations. A description of pipe restraint design is given in attachment B.

#### **3K.4.1.2.5 Jet Impingement**

The jet impingement force, caused by the momentum change of fluid striking a target, is a function of the upstream fluid conditions, fluid enthalpy, source pressure, break dimensions, distance from the target and jet geometry; for conservatism, pipe friction effects from the pressure source to any break in the line were neglected. The jet forces were calculated using the method outlined in attachment F. The jet forces caused by the escaping fluid are assumed to develop instantaneously (with zero rise time).

The effects of jet impingement on the structures and equipment listed in paragraph 3K.4.1.1.5 were analyzed. The results were the same as those outlined in that section.

The closest line-of-sight distance from postulated breakpoints to valve actuation elements in the main steam room is 11 ft 8 in. Impingement pressure from the break falls to < 1.3 psig at a distance of 5 ft; therefore, no damage will be done to the actuation element.

#### **3K.4.1.2.6 Compartment Pressurization**

Because of the lower energy release rate associated with a feedwater line break, the compartment pressurization would be less than already presented in the main steam pressure analysis for the main steam room and the pipe chase structure as discussed in paragraph 3K.4.1.1.6.

#### **3K.4.1.2.7 Flooding**

The main steam room and the pipe chase structure contain equipment available for hot standby and eventual cooldown. Postulated flooding due to a main feedwater line rupture in the main steam room and pipe chase structure was conservatively analyzed using the following assumptions:

- A. A full circumferential break was assumed in the No. 3 main feedwater line.
- B. Main feedwater pumps are initially operating, with a portion of the flow flashing to steam upon exiting the break. The net flow of water to the floor of the main steam room is 24,100 gal/min, based on system resistances between the pump discharges and the break location.
- C. All three of the auxiliary feedwater pumps are assumed to be operating at the time of the break. The net flow of water to the floor of the main steam room is initially a total of 900 gal/min, the flow being based on system resistances between the pump discharges and the break location.
- D. The main feedwater pumps and auxiliary feedwater pumps contribute a total initial combined flow of 25,000 gal/min to the floor. Six redundant level sensors, set to activate at a level not to exceed 6 in. off the 127-ft floor elevation, initiate signals to trip the feedwater pumps and close the feedwater isolation valves. During the 30-s interval required for these isolation valves to



## FNP-FSAR-3K

close, the combined pumps are conservatively assumed to continue to contribute at their maximum net rate of 25,000 gal/min. The two motor-driven auxiliary feedwater pumps (MDAFWPs) are assumed to contribute through the break for a total of 10 min after the main feedwater isolation signals are initiated, at which time the break is remote manually isolated using the motor-operated valves provided. The turbine-driven pump continues to contribute through the break at a flow rate of 348 gal/min until isolated from the break using manual valves which are located below the main steam room and isolated from the effects of a feedwater or steam line break.

- E. The affected steam generator is assumed to be at maximum water level, and blows down its entire inventory of water to the main steam room with a portion of the water flashing to steam as it exits the break. Total net contribution of water to the main steam room from this source is 2800 ft<sup>3</sup>.
- F. All feedwater lines and heaters between the feedwater pumps and the break are assumed to drain their entire 1200 ft<sup>3</sup> inventory to the main steam room. The net free volume of the pipe chase and main steam room up to the elevation of the lowest safety-related equipment (the solenoid valves associated with MDAFW and TDAFW discharge valves HV-3227A, B, and C and HV-3228A, B, and C located at el 131 ft. 0 in.) is 15,710 ft<sup>3</sup>. The maximum calculated water level, using the assumptions above and including auxiliary feedwater flow through the break until the MDAFWPs are isolated at 10 min, is 2 ft. 10 in. above the 127-ft elevation. Plant personnel have approximately 2-1/2 additional h to isolate the turbine-driven pump discharge from the break before water levels in the main steam room would approach the bottom of the solenoid valves on the AFW pump discharge valves. Additional time would be available before water levels would approach the critical portions of the valve operators, located on top of the valve.

### **3K.4.1.2.8 Environmental Effects**

Environmental effects from a feedwater pipe break in the main steam room and pipe chase structure are included in the analysis in paragraph 3K.4.1.1.8.

### **3K.4.1.2.9 Emergency Shutdown with a Feedwater or Auxiliary Feedwater Rupture**

A feedwater rupture between the containment and the feedwater check valve is considered to be the worst case feedwater rupture because of the complete blowdown of one steam generator, in addition to almost unrestricted flow out of the break from the feedwater pumps.

The equipment necessary for cold shutdown of the reactor is given in table 3K.3-1. For this rupture the following must be available to accomplish their respective safety functions:

- A. Safety injection to inject borated water into the core and thereby limit the core power transient following the break.

- B. For a large feedline break, there will be considerable water carryover from the affected steam generator. The water loss out of the steam generator lessens the plant's ability to dissipate decay heat. The auxiliary feedwater pumps will automatically start and deliver flow through the auxiliary feedwater flow restriction orifices. The orifices limit flow to the faulted steam generator and establish flow to the intact steam generators. After 10 min, operator action is taken to decrease flow to the faulted steam generator and increase flow to the intact steam generators.
- C. Closure of main steam isolation valves.

In order to cool the plant down to the residual heat removal system (RHRS) operating temperature and pressure, auxiliary feedwater from at least one auxiliary feedwater pump must be available and the steam generator power-operated relief valves must be accessible for manual local operation.

For a large break between the main feedwater pump and the main feedwater check valve, the feedline check valve will prevent water or steam release from any of the steam generators through the break. A large break at this point is, thus, essentially a loss of normal feedwater. In this case, the equipment that must be available to accomplish the safety shutdown is given in table 3K.3-1. Safety injection is not required. This case covers all lesser feedwater and condensate system high-energy line breaks.

#### **3K.4.1.3 Condensate or Extraction Line Rupture**

The condensate and extraction lines are located in the turbine building. There is no safety-related equipment located in the vicinity of these lines whose safety function would be impaired by a line rupture, and the flooding or forces created by the rupture of these lines are incapable of compromising the integrity of the turbine building.

#### **3K.4.1.4 Auxiliary Steam System Rupture (Auxiliary Feedwater Pump Turbine-Driven Steam Supply)**

The auxiliary steam system supplies steam to the auxiliary feedwater pump turbine driver from the No. 2 and No. 3 steam headers upstream of the main steam isolation valves at main steam pressures and temperatures given in paragraph 3K.4.1.1.

Where the piping is < 4-in. nominal pipe size, only full area circumferential breaks were considered at the break locations. The analysis criteria used are outlined in paragraph 3K.2.1.1.

#### **3K.4.1.4.1 Auxiliary Steam System Design**

The steam turbine which drives one of the three auxiliary feedwater pumps is a single stage noncondensing turbine that operates on steam extracted from the main steam system (MSS). Drawing D-175033, sheet 2 shows the schematic arrangement of the supply piping.

Three-inch connections for the steam supply to the auxiliary feedwater turbine driver are provided on two of the three main steam lines between the containment penetrations and the main steam isolation valves. Each line is provided with a normally open manual gate valve, a normally closed air-operated isolation valve, and a normally open manual gate valve installed in series. Between the two normally open gate valves, there is a 1-in. normally open bypass line that keeps the supply piping at main steam temperature. The 3-in. lines penetrate the 127 ft elevation floor, increase to 4-in., and then combine to form a single 4-in. line that runs to a control station and trip and throttle valve located at the turbine inlet. Each 3-in. line contains a check valve below el 127 ft.

The system piping is Seismic Category I from the main steam line to the turbine.

#### **3K.4.1.4.2 Auxiliary Steam System Piping**

The auxiliary steam system piping from the No. 2 and No. 3 MSS headers to the auxiliary feedwater pump turbine was analyzed in accordance with the criteria described in paragraph 3K.2.1.1. Each 3-in. auxiliary steam branch line from the main steam line header is increased to a 4-in. line downstream from the air-operated isolation valves. These 4-in. lines then join into a common 4-in. header to the auxiliary feedwater pump turbine driver.

#### **3K.4.1.4.3 Areas Affected by an Auxiliary Steam System Line Rupture**

The auxiliary steam system provides steam from the No. 2 and No. 3 main steam headers in the main steam room through the floor level at el 127 to the equipment room area at el 100 directly below the main steam room. From the point at which the two lines join in the equipment room, a single 4-in. header proceeds through the ceiling of the steam driven auxiliary feedwater pump room to the turbine driver. The only other room that would be affected at el 100 besides the turbine pump room and equipment room would be the chemical storage room adjacent to motor pump room 1. The areas affected by an auxiliary steam line rupture above el 127 are outlined in paragraph 3K.4.1.1.3.

In order to prevent the adverse environmental consequences (i.e., temperature and pressure) of a rupture in the auxiliary steam line at the el 100-ft level from propagating to other areas of the auxiliary building containing available shutdown equipment, and at the same time allowing the adverse environmental effects to vent to the atmosphere, the following structural design changes were initiated: the rollup door to the equipment access shaft on the south wall of the auxiliary building was removed (this allowed discharging steam to vent up the shaft to the atmosphere); and the area containing the TDAFWP was isolated from safety-related equipment by the addition of walls and watertight doors to protect nearby equipment from flooding.

#### **3K.4.1.4.4 Pipe Whip**

The methods and analyses used for full area pipe breaks for pipe whip are the same as those outlined in paragraph 3K.4.1.1.4.

Pipe whip restraints have been so located at the postulated break locations as to prevent whipping of the pipe due to a full area break at those locations. The thrust forces that the pipe would exert in the event of a full area break are given in attachment F.

#### **3K.4.1.4.5 Jet Impingement**

The methods and analysis used in considering the effects of jet impingement caused by a rupture in the auxiliary steam system are the same as those outlined in paragraph 3K.4.1.1.5.

The effects of jet impingement forces on the following structures and equipment were analyzed:

- A. Main steam room.
- B. The structural areas at el 100 described in paragraph 3K.4.1.4.3.
- C. Electrical cables servicing safety-related equipment at el 100.
- D. Auxiliary feedwater lines
- E. Service water lines at el 100.
- F. Safety-related instrumentations at el 100.

The results are as follows:

The auxiliary feedwater lines and service water lines are supported or protected by appropriate barriers so as to withstand the effects of all jet impingement forces from all postulated break locations and from critical cracks.

Each of the above referenced structural elements was investigated for a force corresponding to the jet force dispersed over the impingement area. The capacity of the structures has been shown to be sufficient to safely withstand the jet forces in combination with the static pressure loadings associated with a high-energy line break.

Cable trays have been relocated away from break locations so as to reduce jet impingement loads to acceptable levels.

Safety-related instrumentation that could be adversely affected by jet impingement has been removed from the areas at el 100 to a nonaffected area.

#### **3K.4.1.4.6 Compartment Pressurization**

Overpressurization of the compartments outlined in paragraph 3K.4.1.4.3 due to a full area rupture in the auxiliary steam line was considered using the methods and analyses of paragraph 3K.4.1.1.6.

A rupture in the main steam line at el 127 is the worst case break for the main steam room, and is discussed in paragraph 3K.4.1.1.6.

After making the structural modifications for the areas at el 100 described in paragraph 3K.4.1.4.3, the peak pressure at el 100 in the TDAFWP area was found to be 15.25 psia as shown on figure E-7; this amounts to a differential pressure across walls and slabs of approximately 0.55 psi, which is well within the design strength of the structure.

The computer model flow diagram for the above pressure analysis is given on figure E-8, in attachment E, along with the blowdown table E-1.

#### **3K.4.1.4.7 Flooding**

Flooding accompanying a break in the line carrying auxiliary steam to the TDAFWP at el 100 will affect the steam-driven auxiliary, feedwater pump room, adjacent corridors, equipment room, and chemical storage room. The combined net floor area is calculated to be 1,615 ft<sup>2</sup>. (For conservatism, for calculating a flood height the floor area for the chemical storage room was neglected.) Flooding is calculated assuming the entire inventory (3,250 ft<sup>3</sup> water, 2508 ft<sup>3</sup> steam) of one steam generator to empty into the area. The flooding level is calculated at 2 ft above the 100 ft floor elevation throughout the affected areas.

The two MDAFWPs will be unaffected since their respective rooms are equipped with watertight doors. Auxiliary feedwater crossconnect valving is located outside the affected space, and required auxiliary feedwater flow can be maintained with the two motor-driven pumps. Indication of flooding would be provided by the equipment room sump high-level alarm. No safety-related equipment is adversely affected, and safe shutdown capability is unimpaired.

A rupture in an auxiliary steam line in the main steam room at el 127 ft leads to a less severe case of flooding than does a rupture in the main feedwater system, as outlined in paragraph 3K.4.1.2.7.

#### **3K.4.1.4.8 Environmental Effects**

Pressure and temperature due to a rupture in the auxiliary steam system at el 100 ft (turbine-driven pump room) are given in figures E-7 and E-7A, respectively. No safety-related equipment in these areas will be affected by the pressures shown in figure E-7. The temperatures shown in figure E-7A approach an asymptotic value of 300°F. The electric cable to safety-related equipment in this area has the same characteristics as that discussed in paragraph 3K.4.1.1.8 and will not be adversely affected by these temperatures. The operators will terminate the transient by closing the appropriate isolation valves located at el 127 ft within 10 min.

Environmental effects at el 127 are less than those discussed for the main steam system. See paragraph 3K.4.1.1.8.

#### **3K.4.1.4.9 Emergency Shutdown with an Auxiliary Steam System Rupture**

A rupture of the auxiliary feedwater pump steam supply line between the main steam line and the normally closed air-operated valve is considered a less severe main steam line rupture. The necessary emergency shutdown equipment is discussed in paragraph 3K.4.1.1.9. The MDAFWPs remain operable in this condition.

In case of a high-energy line break downstream of the normally closed air-operated stop check valves, the TDAFWP will be lost. Considering a single failure in the electrical train which would render one of the two MDAFWPs inoperable, safe shutdown can be accomplished by one MDAFWP providing at least 285 gal/min to two steam generators.

#### **3K.4.1.5 Steam Generator Blowdown Line Rupture**

Steam generator blowdown piping is field installed. The analysis of this system is provided in paragraph 3K.4.1.8.

#### **3K.4.1.6 Chemical and Volume Control System (CVCS) Letdown Line Rupture**

The 3-in. letdown line carries water at a maximum temperature and pressure of 380°F and 550 psig from the containment penetration through the letdown heat exchanger to a control valve where the temperature and pressure are reduced to 115°F and 75 psig. The pipe break criteria described in paragraph 3K.2.1.1 were used for the analysis of the piping from containment penetration to the letdown heat exchanger. The criteria described in paragraph 3K.2.1.2 were used for the analysis of the piping from the heat exchanger to the flow control valve, where the temperature and pressure are 115°F and 500 psig, respectively.

#### **3K.4.1.6.1 CVCS Letdown and Charging System Design**

During normal power operation, a continuous stream of letdown water is bled from the reactor coolant loop No. 1 upstream from the reactor coolant pump. The high temperature water flows through the shell side of the regenerative heat exchanger where it heats the charging flow in the tubes being returned to the reactor coolant system. The letdown water then flows through the letdown orifices where the pressure is reduced. The water continues through a temperature control valve before passing through the tubes of the letdown heat exchanger, where it gives up its heat to the component cooling water in the shell. Further pressure reduction takes place in a low pressure letdown valve before passing through one of the mixed-bed demineralizers, where ionic impurities are removed. The water then flows either through the thermal regeneration resins, or directly through the reactor coolant filter, and into the volume control tank through a spray nozzle.

Normal charging flow to the reactor coolant system is handled by one or more of the three charging pumps. The charging pumps take suction from the volume control tank and pump the makeup water through the tubes of the regenerative heat exchanger, where its temperature is increased by the hot letdown fluid in the shell. The flow is then injected into the reactor coolant system via the cold leg of reactor coolant loop No. 2.

#### **3K.4.1.6.2 CVCS Letdown Piping**

The 3-in. CVCS piping was analyzed for the effects of a full area circumferential break at the postulated break locations and for critical cracks anywhere along the line. The entire letdown line system piping is B31.7 class 2, ASME III Seismic Category I. The letdown line has been equipped with two fail-closed air-operated valves in series (QV565A and B) as shown in drawings D-175039 and D-205039. These valves limit the adverse environmental effects due to a rupture in the letdown line.

These isolation valves are actuated by pressure sensors which monitor all areas affected by a rupture in the CVCS letdown piping. The sensors detect pressure buildups caused by a line break, and initiate signals to close the air-operated valves provided. A more detailed description of their function is given in paragraph 3K.4.1.6.6.

#### **3K.4.1.6.3 Areas Affected by a CVCS Letdown Line Rupture**

The CVCS piping penetrates the containment at el 108 ft 6 in. into the airtight penetration room at el 100. From the penetration room the letdown line goes through a wall seal into a sealed piping tunnel, then to the seal water heat exchanger room and the letdown heat exchanger room at el 100.

In addition to the rooms that contain the CVCS letdown line piping, the el 100-ft corridor is also affected by a letdown line rupture in the piping tunnel or the heat exchanger rooms. The door between the letdown heat exchanger room and this corridor will open due to elevated pressure in the letdown heat exchanger room following a letdown line rupture. The open doorway provides a flow path for steam to enter the corridor. In Unit 1 the equipment hatch acts as an open flow path and connects this corridor to other elevations (el 121, 139, and 155 ft). In Unit 2 there is no equipment hatch, however, a 6-ft<sup>2</sup> open flow path (a pipe chase) exists between the el 100-ft and 121-ft corridors. Therefore, the el 100-ft and 121-ft corridors are affected by the line rupture.

#### **3K.4.1.6.4 Pipe Whip**

The analysis criteria and methods used for consideration of full area pipe breaks for pipe whip are in accordance with the descriptions outlined in attachments A and F, respectively.

Pipe whip restraints have been so located at the postulated break locations as to prevent whipping of the pipe due to a full area break at those locations.

The forces that the pipe would experience in the event of a full area rupture are given in attachment F.

#### **3K.4.1.6.5 Jet Impingement**

No safety-related equipment, cables, or equipment necessary to bring the plant to a hot standby and eventual cold shutdown are located in letdown line areas that would be affected by jet impingement forces.

#### **3K.4.1.6.6 Compartment Pressurization**

As described in paragraph 3K.4.1.6.2, the CVCS letdown line has been equipped with two air-operated valves which are actuated to the closed position by pressure sensors located in the areas affected by a CVCS letdown line rupture. The sensors are calibrated to actuate the air-operated valves at a pressure of 0.28 psig within the compartments affected. The operating time of the air-operated valves is 5 s to the closed position. However, to account for instrument response time, the valve is assumed to remain fully open for 2 s after the room pressure reaches the high-pressure setpoint. Therefore, the total response time of the valve is assumed to be 7 s.

The pressure sensors and associated circuitry that actuate isolation valves in the CVCS letdown line are seismically qualified. The pressure sensors are not mounted in the rooms whose pressure they are to sense. They are connected to these rooms by stainless steel tubing through wall penetrations.

The blowdown rates for double-ended full-area circumferential breaks in the penetration room (el 100 ft), the letdown heat exchanger room, and the seal water heat exchanger room and for a critical crack in the piping tunnel are given in tables E-2 through E-6. Critical cracks were not postulated in the other rooms because the blowdown from a circumferential break is more severe. The blowdown decreases linearly when the air-operated valves start to close and stops when the valves are fully closed. The blowdown is based on the letdown reheat heat exchanger outlet valve (TCV-381A) being open; this valve is open when the boron thermal regeneration system is in the boron-release mode of operation. Therefore, since the valve is open, the branch piping for the alternate letdown path contains high-temperature water and, thus, it contributes to the compartment pressurization.

The analytical methods used for the pressure response analyses are in accordance with reference 2 of attachment E.

As discussed in paragraph 3K.4.1.6.3, the el 100-ft corridor outside of the letdown heat exchanger room for both Units 1 and 2 is affected by a letdown line rupture. Additionally, the Unit 1 corridors on el 121, 139, and 155 ft are also affected. Due to the increased volume from the upper elevations in Unit 1, the pressure increase of the piping tunnel, the seal water heat exchanger room, and the letdown heat exchanger room is lower for Unit 1 than for Unit 2. The Unit 2 pressures provide an upper bound for Unit 1. The temperatures for both units are about the same.

The pressure and temperature histories for CVCS letdown line breaks in the penetration room, the CVCS letdown heat exchanger room, and the seal water heat exchanger room and the piping tunnel are given in figures E-9 through E-18. As shown in these figures and in table E-7, the letdown line is isolated before the pressure reaches 3 psig (the design peak differential for



Seismic Category I structures) in any of these rooms. In table E-7, the reported peak temperatures and pressures apply to both units since these temperatures and pressures provide an upper bound for both units. In addition, only the peak pressure of a break or crack area is reported; for the affected areas other than the break or crack areas, only peak temperatures are reported.

The flow diagrams used in this analysis are given in figures E-19 and E-20.

#### **3K.4.1.6.7 Flooding**

Due to the small mass of blowdown (equal to about 45 ft<sup>3</sup> of water) from a CVCS letdown line rupture, no flooding damage to safety-related equipment or equipment necessary for a cold shutdown will occur.

#### **3K.4.1.6.8 Environmental Effects**

Due to the short duration of blowdown from the CVCS letdown, as described in paragraph 3K.4.1.6.6, environmental effects will be minimal. The peak temperatures and pressures shown in table E-7 will not adversely affect equipment required for shutdown.

#### **3K.4.1.6.9 Emergency Shutdown with a CVCS Letdown Line Rupture**

For a break in the letdown line between the containment and the letdown heat exchanger, the following must be available:

- A. Boration capability via the safety injection system.
- B. Letdown line containment isolation valves.
- C. Auxiliary feedwater.
- D. Steam generator power-operated relief valves (local manual operation).
- E. RHRS, to bring the plant to cold-shutdown conditions.

#### **3K.4.1.7 Boron Thermal Regenerative System (BTRS) Line Rupture**

The 3-in. boron thermal regenerative system (BTRS) lines considered in this report carry water at 380°F and 510 psig from the CVCS letdown line described in paragraph 3K.4.1.6 to the BTRS letdown reheat heat exchanger, and from the BTRS letdown reheat heat exchanger back to the CVCS letdown line at 247°F and 500 psig. The alternate letdown line and its return line connect with the main letdown line upstream of the letdown heat exchanger. A double-ended, full-area circumferential break is considered assuming the boron thermal regenerative system is in operation at the time of the break. The pipe break criteria described in paragraph 3K.2.1.1 were used for the analysis.

#### **3K.4.1.7.1 BTRS System Design**

The BTRS contains high-energy lines only when boron concentration in the reactor coolant is being increased (the boron-release mode--see paragraph 9.3.4.2.2.). In this mode, high temperature letdown fluid is extracted from the letdown line between the letdown orifices and the letdown heat exchanger. The fluid flows through the tubes of the letdown reheat heat exchanger, where it gives up its heat, to the low temperature letdown fluid in the shell that has had the ionic impurities removed in the mixed-bed demineralizers.

The high-temperature letdown fluid in the tubes is then returned to the letdown line upstream from the letdown heat exchanger.

During all other modes of normal plant operation, the letdown reheat heat exchanger is valved off and the lines leading to and from the letdown heat exchanger cease to be high-energy lines.

Since the worst postulated line break occurs when the BTRS is in the boron-release mode, the BTRS line is assumed to contain high-energy water.

#### **3K.4.1.7.2 BTRS Piping**

The 3-in. BTRS piping considered in this appendix was analyzed for the effects of a full area circumferential break at the postulated break locations and for critical cracks anywhere along the line. The BTRS piping considered in this appendix is Seismic Category I.

#### **3K.4.1.7.3 Areas Affected by a BTRS Line Rupture**

The 3-in. BTRS lines join with the CVCS letdown line in the CVCS letdown heat exchanger room. Lines going in and returning from the BTRS letdown reheat heat exchanger exit the CVCS letdown heat exchanger room, enter the piping tunnel, and go on to the recycle holdup tank compartment immediately adjacent to the tunnel. From the recycle holdup tank compartment, both lines traverse two other recycle holdup tank compartments and into the compartment containing the BTRS letdown reheat heat exchanger. Since the CVCS line break analysis was performed for a postulated break in the CVCS heat exchanger rooms and a crack in the piping tunnel (paragraph 3K.4.1.6), it is not necessary to postulate a break in those locations.

In addition to the rooms that contain the BTRS alternate letdown line piping, the el 121-ft corridor is also affected by an alternate letdown line rupture in the three recycle holdup tank compartments and the heat exchanger/valve room. There is an open doorway between the heat exchanger/valve room and this corridor that provides a flow path for steam to enter the corridor. In Unit 1, the equipment hatch acts as an open flow path and connects this corridor to other elevations (el 100, 139, and 155 ft). For Unit 2, the same description as in 3K.4.1.6.3 applies.

#### **3K.4.1.7.4 Pipe Whip**

The analysis criteria and methods used for consideration of full area pipe breaks for pipe whip are in accordance with the description outlined in attachments A and F, respectively.

Pipe whip restraints have been located at the postulated break location so as to prevent whipping of the pipe due to a full area break at those locations.

The forces that the pipe would experience in the event of a full area rupture are given in attachment F.

#### **3K.4.1.7.5 Jet Impingement**

No safety-related equipment or equipment necessary to bring the plant to a hot standby and eventual cold shutdown that would be damaged by jet impingement forces are located in BTRS line areas.

#### **3K.4.1.7.6 Compartment Pressurization**

All the compartments affected by a rupture in the BTRS line have been equipped with pressure sensors that will isolate the CVCS letdown line in the event of a rupture in the compartment affected. The sensors are calibrated to actuate at a compartment pressure of 0.28 psig. (See paragraph 3K.4.1.6.6.) As the BTRS is an integral part of the CVCS letdown line during operation, the isolation of the air-operated valves in the CVCS letdown line will also isolate the BTRS alternate letdown line.

As discussed in paragraph 3K.4.1.7.3, the el 121-ft corridor outside of the heat exchanger/valve room for both Units 1 and 2 is affected by an alternate letdown line rupture. Additionally, the Unit 1 corridors on el 100, 139, and 155 ft are also affected. Due to the increased volume from the upper elevations in Unit 1, the pressure increase of the recycle holdup tank rooms and the heat exchanger/valve room is lower for Unit 1 than for Unit 2.

The blowdown rates for double-ended full-area circumferential breaks in two of the recycle holdup tank rooms (numbers 156 and 157) are given in tables E-8 and E-9. Although these tables are based on Unit 2, the compartment pressurization results are valid for both units. The blowdown rates for the break in the heat exchanger room/valve room are given in table E-10 for Unit 1 and in table E-11 for Unit 2. Since the pressure of the Unit 1 compartments increases slower than the Unit 2 compartments, both the detection of the piping rupture and the closure of the air-operated valve occur later. Therefore, the blowdown for Unit 1 terminates later than that of Unit 2. A critical crack in the heat exchanger/valve room in Unit 1 is postulated to see a long-term temperature response in all the elevations. Its corresponding blowdown rates are given in table E-12. A critical crack in the heat exchanger/valve room in Unit 2 was not postulated since the blowdown from a circumferential break is more severe.

The analytical methods used for the pressure response analyses are in accordance with reference 2 of Appendix E.

The pressure and temperature histories of BTRS alternate letdown line breaks in recycle holdup tank rooms 156 and 157 are given in figures E-21 through E-24. Only the Unit 2 results are presented here because they provide an upper bound for Unit 1 pressures. The temperatures for both units are approximately the same. The pressure and temperature histories for the break in the heat exchanger/valve room for Units 1 and 2 are given in figures E-25 through E-28. For the critical crack case, the resulting temperature and pressure histories are shown in figures E-29 and E-30. As shown in these figures and in table E-13, the alternate letdown line is isolated before the pressure reaches 3 psig in any of these rooms. The peak temperatures and pressures in table E-13 apply to both units since these temperatures and pressures provide an upper bound for both units. In addition, only the peak pressure of a break or crack area is reported; for the affected areas other than the break or crack areas, only peak temperatures are reported.

The flow diagrams used in this analysis are given in figures E-31 through E-33.

#### **3K.4.1.7.7 Flooding**

Due to the small mass of blowdown (equal to about 61 ft<sup>3</sup> of water) from a BTRS alternate letdown line rupture, no flooding damage to safety-related equipment or equipment necessary for a cold shutdown will occur.

#### **3K.4.1.7.8 Environmental Effects**

Because of the short duration of the blowdown, as described in paragraph 3K.4.1.6.7, environmental effects will be minimal. The peak temperatures and pressure shown in the curves in attachment E will not adversely affect equipment required for shutdown.

#### **3K.4.1.7.9 Emergency Shutdown Procedure with a BTRS Line Rupture**

Shutdown following a rupture in that portion of BTRS piping considered in this appendix would be the same as that following a rupture in the CVCS letdown line. The emergency shutdown procedure following a CVCS letdown line rupture is discussed in paragraph 3K.4.1.6.9.

#### **3K.4.1.8 Steam Generator Blowdown Processing System (SGBD) Line Rupture**

Three 2-in. steam generator blowdown processing system (SGBD) lines carry steam generator effluent to the steam generator blowdown processing system, which maintains the plant effluent from the steam generators at a chemical and radiological specification which meets plant discharge regulations. Treated blowdown is suitable for recycle into the main condenser. A complete system description is contained in subsection 10.4.8.

#### **3K.4.1.8.1 SGBD Piping**

The 2-in. SGBD lines considered were analyzed for the effects of a full area circumferential break at the postulated break locations and for critical cracks anywhere along the line.

#### **3K.4.1.8.2 Deleted**

#### **3K.4.1.8.3 Jet Impingement**

The steam generator blowdown lines were analyzed for jet impingement effects, using the methods outlined in attachment F. No safety-related equipment or equipment necessary to bring the plant to a hot standby and eventual cold shutdown that would be damaged by jet impingement forces is affected by the postulated breaks in the SGBD line break.

#### **3K.4.1.8.4 Pipe Whip**

The analysis criteria and methods of full area pipe breaks are in accordance with the description outlined in attachments A and F.

Pipe whip restraints have been so located at the postulated break locations as to prevent whipping of the pipe because of a full area break at those locations. Thrust loads for the line are shown in table F.1.

#### **3K.4.1.8.5 Compartment Pressurization**

Not all compartments affected by a rupture in the SGBD line have been equipped with pressure sensors that will isolate the SGBD line in the event of a rupture in the compartment affected. However, due to the location and separation of pressure sensors in adjacent compartments, a rupture in any affected compartment will be sensed and the SGBD line will be isolated. The sensors are calibrated to actuate at a compartment pressure of 7.76-in. WG.

### **3K.4.2 PIPING SYSTEMS WITH POWER OPERATION TEMPERATURES HIGHER THAN 200°F OR PRESSURES HIGHER THAN 275 psig**

#### **3K.4.2.1 CVCS Charging Line Rupture**

The 3-in. CVCS charging line carries water at a temperature of 120°F and a pressure of 2485 psig from the charging pumps to the containment penetration. The CVCS charging line was analyzed in accordance with the criteria in subsection 3K.2.0 and specifically as per paragraph 3K.2.1.2. The CVCS charging system is described in paragraph 3K.4.1.6.1.

#### **3K.4.2.1.1 CVCS System Makeup Piping**

The 3-in. discharge lines from the three respective pumps run to a 4-in. header. From a 4 x 3 reducer the 3-in. charging line proceeds to the containment penetration. The entire CVCS charging line is Seismic Category I.

#### **3K.4.2.1.2 Areas Affected by a CVCS Charging Line Rupture**

Each charging pump is located in its individual watertight compartment. The common 3-in. header from the boron injection tank area passes through the containment storage area to the penetration room at el 100 ft and into the containment.

#### **3K.4.2.1.3 Jet Impingement**

The CVCS makeup line and the areas affected were analyzed for critical cracks using the methods outlined in attachment F.

Due to the short effectual distance of the jet spray from the pipe, no adverse effects will occur.

#### **3K.4.2.1.4 Flooding Due to a CVCS Charging Line Break**

Flooding because of a CVCS charging line rupture is limited to the charging/high-head safety injection watertight pump rooms, interconnecting corridors, and piping penetration room at el 100 ft.

A line rupture in watertight pump room IA was analyzed for flooding by assuming flow out of a critical crack for 10 min without operator action. The 1100 ft<sup>3</sup> of water exiting through the crack is estimated to cover the 220 ft<sup>2</sup> of floor area, submerge the pump, and attain a level of 4 ft 6 in. above the floor elevation of 100 ft. Valving necessary to isolate the affected pump from the rest of the system is located above the calculated flood level. Thus, safe shutdown capability can be maintained by the two remaining unaffected pumps.

Indication of flooding in pump room IA is a sump high level alarm in the control room.

Flooding due to a CVCS charging line rupture in charging/high-head safety injection watertight pump room IB is estimated to reach a level of 5 ft 9 in. This is based on the previous assumptions (1100 ft<sup>3</sup> of water in 10 min exiting the crack without operator action) and a net floor area of 178 ft<sup>2</sup>. All valves necessary to isolate the affected pump are located above the calculated flood level. The floor drain in this space is piped to an otherwise sealed sump in the corridor. This floor drain is the only source of water to the sump. Activation of a sump high level alarm in the control room will provide indication of flooding in pump room IB.

Flooding analysis of charging/high-head safety injection pump room IC was identical to those of the other two pump rooms, with an estimated flooding level of 5 ft 6 in. Safe shutdown capability is maintained, as flooding is localized to pump room IC by the watertight door.

## FNP-FSAR-3K

Valving necessary to isolate the affected pump is located well above the flood level. Indication of flooding is activation of a high sump level alarm in the control room.

Since the pump rooms are each equipped with watertight doors, flooding of any one will not impair the operability of either of the other two. Therefore, safe shutdown capability is not impaired.

Flooding in the corridors in the area of the charging/high-head safety injection pump rooms is estimated to reach a level of 1 ft 6 in. above el 100 ft, assuming no drainage.

No safety-related equipment is located at or below el 101 ft 9 in.

Indication of flooding in the corridor adjacent to the charging/high-head safety injection pump rooms (where no sump is available) is a floor drain tank high level alarm accompanied by a charging line low flow alarm.

The effects of water backup from a full floor drain tank were analyzed by allowing 10 min of flow (1100 ft<sup>3</sup>) from a critical crack to back up through the floor drain system into each affected space connected to the floor drain tank. In all spaces considered, no equipment required for safe shutdown is adversely affected.

Flooding in the piping penetration room at el 100 would result in an estimated flooding depth of 8 in. No safety-related equipment is adversely affected, and safe shutdown capability is intact.

### **3K.4.2.1.5 Emergency Procedure with a CVCS Charging Line Critical Crack**

For a critical crack in the charging line between the containment and the charging pumps, the following must be available:

- A. Boration capability via the safety injection system.
- B. Auxiliary feedwater.
- C. Steam generator power-operated relief valves (local manual operation).
- D. RHRS, to bring the plant to cold shutdown conditions.

### **3K.4.2.2 Auxiliary Feedwater System Rupture**

The auxiliary feedwater system carries water from three auxiliary feedwater pumps to the three main feedwater lines. The temperature and pressure from the motor driven auxiliary feedwater pumps are 110°F and 1231 psig, respectively. The temperature and pressure from the turbine driven auxiliary feedwater pump is 110°F and 1227 psig, respectively.

A design description of the auxiliary feedwater system is given in paragraph 3K.4.1.2.1. The system was analyzed in accordance with the criteria in subsection 3K.2.0 and specifically as per paragraph 3K.2.1.2.

#### **3K.4.2.2.1 Auxiliary Feedwater System Piping**

The 6-in. discharge from the steam-driven auxiliary feedwater pump runs to a 4-in. discharge line from the two motor-driven auxiliary pumps. The 4-in. motor-driven pump discharge lines then run to a common 4-in. header where they join the three main feedwater lines on the steam generator side of the first isolation valve on each main feedwater line.

#### **3K.4.2.2.2 Areas Affected by an Auxiliary Feedwater Line Rupture**

Each MDAFWP is contained in its individual watertight room at el 100. The areas that would be affected by a rupture in any one of the discharge lines from all three pumps would be:

- A. The areas for a rupture in the auxiliary steam supply to the steam-driven auxiliary feedwater pump discussed in paragraphs 3K.4.1.4.3 and 3K.4.1.4.7.
- B. Each watertight MDAFWP pump room.
- C. The chemical storage room adjacent to the MDAFWP room 1.
- D. The main steam room.

#### **3K.4.2.2.3 Jet Impingement**

The auxiliary feedwater lines and the areas affected were analyzed for jet impingement from critical cracks using the methods outlined in attachment F.

The results of that analysis are as follows:

- A. Due to the short effective distance of the jet spray from the pipe, structural integrity of the separation walls and floors at el 100 and el 127 will not be affected.
- B. Any adverse spray effects in close proximity to one auxiliary feedwater pump will not damage either of the other two.

Jet impingement effects at el 127 is the same as those discussed in paragraph 3K.4.1.1.5.

#### **3K.4.2.2.4 Flooding**


Flooding because of an auxiliary feedwater line rupture at el 100 will affect the individual auxiliary feedwater pump rooms, corridors, the adjacent equipment room, and the chemical tank and pump area.

In the case of MDAFWP room No. 1, the flooding level is calculated assuming 10 min of flow at 125 percent of rated turbine-driven pump capacity (1170 ft<sup>3</sup>) through a critical crack without operator action. The level attained over the estimated 240 ft<sup>2</sup> of floor area above el 100 is



**TABLE 3K.2-1**

**CRITERIA FOR IDENTIFICATION OF HIGH-ENERGY  
LINES AND EFFECTS CONSIDERED**



<u>Criteria</u>	<u>Break Types and Effects Considered</u>
A	Critical crack, jet impingement, flooding
B	Circumferential or longitudinal breaks, critical cracks, pipe whip, jet impingement, flooding, pressure and temperature effects on structural integrity of compartments, environmental effects
C	Same as A
D	Piping systems with temperatures and pressures less than 200° F and 275 psig not considered in this appendix.

Note: 1. Also includes temperature and steam/moisture effects. See section 3K.2.1.2.

FNP-FSAR-3K

TABLE 3K.3-1 (SHEET 1 OF 2)

**EQUIPMENT REQUIRED FOLLOWING A HIGH-ENERGY LINE BREAK - UNIT 1<sup>(a)(b)</sup>  
(OUTSIDE CONTAINMENT)**

Short-Term (<10 Min)	Long-Term (Hot Standby)	Required for Cooldown
Reactor trip and safeguards actuation channels including sensors, circuitry, and processing equipment (the protection circuits used to trip the reactor on undervoltage, underfrequency, and turbine trip may be excluded)	Auxiliary feedwater system including pumps, water supply, and system valves and piping (this system must be placed in service to supply water to operable steam generators within one minute after initiating signal)	Steam generator power operated relief valves (can be manually operated locally)
Safety injection system, including pumps, the refueling water storage tank, and system valves and piping	Reactor containment ventilation cooling units	Controls for defeating automatic safety injection actuation during a cooldown and depressurization.
Diesel generators and emergency power distribution equipment		Residual heat removal system including pumps, heat exchanger and system valves and piping necessary to cool and maintain the reactor coolant system in a cold shutdown condition
Essential service water system including pumps and system valves and piping	Capability for obtaining a reactor coolant system sample	
Essential component cooling water system including pumps, heat exchanger, and component cooling water surge tank		
Main feedwater control valves(trip closed feature) <sup>(c)</sup>		
Circuits and/or equipment required to trip the main feedwater pumps <sup>(c)</sup>		
Main feedwater isolation valves (trip closed feature) <sup>(c)</sup>		
Main steam line stop valves (trip closed feature) <sup>(d)</sup>		
Main steam line stop valve bypass valves (trip closed feature) <sup>(d)</sup>		
Steam generator blowdown isolation valves (automatic closure feature)		
Batteries		
Control room ventilation		

# FNP-FSAR-3K

## TABLE 3K.3-1 (SHEET 2 OF 2)

Short-Term  
(<10 Min)

Long-Term  
(Hot Standby)

Required for  
Cooldown

Control room equipment must not be damaged to the extent that any equipment will be spuriously actuated or any of the equipment contained elsewhere in this list cannot be operated

Emergency lighting

In addition to the instrumentation required to operate the equipment on this list, indication of the following plant parameters should be available to the operator:

Wide range  $T_{hot}$  or  $T_{cold}$   
(preferably  $T_{hot}$ ) for each  
reactor coolant loop

Pressurizer water level

Wide range reactor coolant  
system pressure

Steam line pressure for each  
steam generator

Wide range and narrow range  
steam generator level  
for each steam generator

Containment pressure

- a. Instrumentation, interlocks, and power supplies required to operate the above equipment must be available.
- b. Support systems for the above equipment such as long-term diesel fuel storage, battery chargers, and a long-term water supply for the auxiliary feedwater system must be available.
- c. Required for steam line and steam generator blowdown line break only.
- d. Required for steam line, feed line, and steam generator blowdown line break only.

FNP-FSAR-3K

**ATTACHMENT A**

**GENERAL INFORMATION REQUIRED FOR CONSIDERATION OF EFFECTS OF A PIPING  
SYSTEM BREAK OUTSIDE CONTAINMENT**

**ATTACHMENT A**

**PART I**

**GENERAL INFORMATION REQUIRED FOR CONSIDERATION OF THE EFFECTS OF A  
PIPING SYSTEM BREAK OUTSIDE CONTAINMENT**

The following is a general list of information required for NRC review of the effects of a piping system break outside containment, including the double-ended rupture of the largest pipe in the main steam and feedwater systems, and for NRC review of any proposed design changes that may be found necessary. Since piping layouts are substantially different from plant to plant, applicants and licensees should determine on an individual plant basis the applicability of each of the following items for inclusion in their submittals.

- A. The systems (or portions of systems) for which protection against pipe whip is required should be identified. Protection from pipe whip need not be provided if any of the following conditions exist:
  - 1. Both of the following piping system conditions are met:
    - a. The service temperature is less than 200°F.
    - b. The design pressure is 275 psig or less.
  - 2. The piping is physically separated (or isolated) from structures, systems, or components important to safety by protective barriers, or restrained from whipping by plant design features, such as concrete encasement.
  - 3. Following a single break, the unrestrained pipe movement of either end of the ruptured pipe in any possible direction about a plastic hinge formed at the nearest pipe-whip restraint cannot impact any structure, system, or component important to safety.

## FNP-FSAR-3K

4. The internal energy level<sup>(a)</sup> associated with the whipping pipe can be demonstrated to be insufficient to impair the safety function of any structure, system, or component to an unacceptable level.
- B. Design basis break locations should be selected in accordance with the following pipe whip protection criteria; however, where pipes carrying high-energy fluid are routed in the vicinity of structures and systems necessary for safe shutdown of the nuclear plant, supplemental protection of those structures and systems shall be provided to cope with the environmental effects (including the effects of jet impingement) of a single postulated open crack at the most adverse location(s) with regard to those essential structures and systems; the length of the crack size is taken to be one-half the pipe diameter in length and one-half the wall thickness in width.

The criteria used to determine the design basis piping break locations in the piping systems should be equivalent to the following:

1. ASME Section III Code Class I piping<sup>(b)</sup> breaks should be postulated to occur at the following locations in each piping run<sup>(c)</sup> or branch run:
  - a. The terminal ends.

---

a. The internal fluid energy level associated with the pipe- break reaction may take into account any line restrictions (e.g., flow limiter) between the pressure source and break location, and the effects of either single-ended or double- ended flow conditions, as applicable. The energy level in a whipping pipe may be considered as insufficient to rupture an impacted pipe of equal or greater nominal pipe size and equal or heavier wall thickness.

b. Piping is a pressure-retaining component consisting of straight or curved pipe and pipe fittings (e.g., elbows, tees, and reducers).

c. A piping run interconnects components, such as pressure vessels, pumps, and rigidly fixed valves, that may act to restrain pipe movement beyond that required for design thermal displacement. A branch run differs from a piping run only in that it originates at a piping intersection as a branch of the main pipe run.

FNP-FSAR-3K

- b. Any intermediate locations between terminal ends where the primary plus secondary stress intensities  $S_n$  (circumferential or longitudinal) derived on an elastically calculated basis under the loadings associated with 1/2 safe shutdown earthquake and operational plant conditions<sup>(a)</sup> exceed  $2.0 S_m^{(b)}$  for ferritic steel and  $2.4 S_m$  for austenitic steel.
  - c. Any intermediate locations between terminal ends where the cumulative usage factor  $(U)^{(c)}$  derived from the piping fatigue analysis and based on all normal, upset, and testing plant conditions exceeds 0.1.
2. ASME Section III Code Class 2 and 3 piping breaks should be postulated to occur at the following locations in each piping run or branch run:
- a. The terminal ends.
  - b. Any intermediate locations between terminal ends where either the circumferential or longitudinal stresses derived on an elastically calculated basis under the loadings associated with seismic events and operational plant conditions exceed 0.8.

---

a. Operational plant conditions include normal reactor operation, upset conditions (e.g., anticipated operational occurrences) and testing conditions.

b.  $S_m$  is the design stress intensity as specified in Section III of the ASME Boiler and Pressure Vessel Code, "Nuclear Plant Components."

c.  $U$  is the cumulative usage factor as specified in Section III of the ASME Boiler and Pressure Vessel Code, "Nuclear Power Plant Components."

## FNP-FSAR-3K

$(S_h + S_A)^{(a)}$  or the expansion stresses exceed  $0.8 S_A$ .

The requirement to postulate arbitrary intermediate breaks has been eliminated from the structural design basis (including resultant dynamic and environmental effects) as allowed by NRC Generic Letter 87-11, "Relaxation in Arbitrary Intermediate Pipe Rupture Requirement".

- C. The criteria used to determine the pipe break orientation at the break locations as specified under (b) above should be equivalent to the following:
1. Longitudinal<sup>(b)</sup> breaks in piping runs and branch runs, 4-inches nominal pipe size and larger.
  2. Circumferential<sup>(c)</sup> breaks in piping runs and branch runs exceeding 1-inch nominal pipe size.
- D. A summary should be provided of the dynamic analyses applicable to the design of Category I piping and associated supports which determine the resulting loadings as a result of a postulated pipe break including:

---

a.  $S_h$  is the stress calculated by the rules of NC-3600 and ND-3600 for Class 2 and 3 components, respectively, of the ASME Code Section III Winter 1972 Addenda.

$S_A$  is the allowable stress range for expansion stress calculated by the rules of NC-3600 of the ASME Code, Section III, or the USA Standard Code for Pressure Piping, ANSI B31.1.0-1967.

b. Longitudinal breaks are parallel to the pipe axis and oriented at any point around the pipe circumference. The break area is equal to the effective cross-sectional flow area upstream of the break location. Dynamic forces resulting from such breaks are assumed to cause lateral pipe movements in the direction normal to the pipe axis.

c. Circumferential breaks are perpendicular to the pipe axis, and the break area is equivalent to the internal cross-sectional area of the ruptured pipe. Dynamic forces resulting from such breaks are assumed to separate the piping axially and cause whipping in any direction normal to the pipe axis.



## FNP-FSAR-3K

1. The locations and number of design basis breaks on which the dynamic analyses are based.
  2. The postulated rupture orientation, such as a circumferential and/or longitudinal break(s), for each postulated design basis break location.
  3. A description of the forcing functions used for the pipe-whip dynamic analyses, including the direction, rise time, magnitude, duration, and initial conditions that adequately represent the jet-stream dynamics and the system-pressure difference.
  4. Diagrams of mathematical models used for the dynamic analysis.
  5. A summary of the analyses which demonstrates that unrestrained motion of ruptured lines will not damage, to an unacceptable degree, structures, systems, or components important to safety, such as the control room.
- E. A description should be provided of the measures, as applicable, to protect against pipe whip, blowdown jet, and reactive forces, including:
1. Pipe restraint design to prevent pipe whip impact.
  2. Protective provisions for structures, systems, and components required for safety against pipe whip, blowdown jet, and reactive forces.
  3. Separation of redundant features.
  4. Provisions to separate physically piping and other components of redundant features.
  5. A description of the typical pipe-whip restraints and a summary of number and location of all restraints in each system.
- F. The procedures that will be used to evaluate the structural adequacy of Category I structures and to design new seismic Category I structures should be provided, including:
1. The method of evaluating stresses, e.g., the working stress method and/or the ultimate strength method that will be used.
  2. The allowable design stresses and/or strains.
  3. The load factors and the load combinations.
- G. The structural design loads should be provided. They include the pressure and temperature transients; the dead, live, and equipment loads; and the pipe and equipment static, thermal, and dynamic reactions.

## FNP-FSAR-3K

- H. Seismic Category I structural elements, such as floors, interior and exterior walls, building penetrations, and the buildings as a whole, should be analyzed for eventual reversal of loads due to the postulated accident.
- I. If new openings are to be provided in existing structures, the capabilities of the modified structures to carry the design loads should be demonstrated.
- J. Verification that failure of any structure, including nonseismic Category I structures, caused by the accident, will not cause failure of any other structure in a manner to adversely affect:
  - 1. Mitigation of the consequences of the accidents.
  - 2. Capability to bring the unit(s) to a cold shutdown condition.
- K. Verification that rupture of a pipe carrying high-energy fluid will not directly or indirectly result in:
  - 1. Loss of required redundancy in any portion of the protection system (as defined in IEEE-279), Class IE electric system (as defined in IEEE-308), engineered safety feature equipment, cable penetrations, or their interconnecting cables required to mitigate the consequences of that accident and place the reactor(s) in a cold-shutdown condition.
  - 2. Environmentally induced failures caused by a leak or rupture of the pipe, which would not of itself result in protective action but does disable protection functions. In this regard, a loss of redundancy is permitted but a loss of function is not permitted. For such situations plant shutdown is required.
- L. Assurance should be provided that the control room will be habitable and its equipment functional after a steam-line or feedwater-line break or that the capability for shutdown and cooldown of the unit(s) will be available in another habitable area.
- M. Environmental qualification should be demonstrated by test for that electrical equipment required to function in the steam-air environment resulting from a high-energy-fluid-line break. The information required for our review should include the following:
  - 1. Identification of all electrical equipment necessary to meet requirements of K above. The time after the accident in which they are required to operate should be given.
  - 2. The test conditions and the results of test data showing that the systems will perform their intended function in the environment resulting from the postulated accident and time interval of the accident. Environmental conditions used for the tests should be selected from a conservative evaluation of accident conditions.

## FNP-FSAR-3K

3. The results of a study of steam systems identifying locations at which barriers will be required to prevent steam jet impingement from disabling a protection system. The design criteria for the barriers should be stated and the capability of the equipment to survive within the protected environment should be described.
  4. An evaluation of the capability for safety-related electrical equipment in the control room to function in the environment that may exist following a pipe-break accident. Environmental conditions used for the evaluation should be selected from conservative calculations of accident conditions.
  5. An evaluation to ensure that the onsite power distribution system and onsite sources (diesels and batteries) will remain operable throughout the event.
- N. Design diagrams and drawings of the steam and feedwater lines, including branch lines, showing the routing from containment to the turbine building should be provided. The drawings should show elevations and include the location relative to the piping runs of safety-related equipment, including ventilation equipment, intakes, and ducts.
- O. A discussion should be provided of the potential for flooding of safety-related equipment in the event of failure of a feedwater line or any other line carrying high-energy fluid.
- P. A description should be provided of the quality control and inspection programs that will be required or have been utilized for piping systems outside containment.
- Q. If leak-detection equipment is to be used in the proposed modifications, a discussion of its capabilities should be provided.
- R. A summary should be provided of the emergency procedures that would be followed after a pipe-break accident, including the automatic and manual operations required to place the reactor unit(s) in a cold-shutdown condition. The estimated times following the accident for all equipment and personnel operational actions should be included in the procedure summary.
- S. A description should be provided of the seismic and quality classification of the high-energy-fluid piping systems, including the steam and feedwater piping that runs near structures, systems, or components important to safety.
- T. A description should be provided of the assumptions, methods, and results of analyses, including steam- generator blowdown, used to calculate the pressure and temperature transients in compartments, pipe tunnels, intermediate buildings, and the turbine building following a pipe rupture in these areas. The equipment assumed to function in the analyses should be identified, and the capability of systems required to function to meet a single active component failure should be described.

FNP-FSAR-3K

- U. A description should be provided of the methods or analyses performed to demonstrate that there will be no adverse effects on the primary and/or secondary containment structures due to a pipe rupture outside these structures.

**PART II**

**POSTULATED BREAK AND LEAKAGE LOCATIONS IN THE MAIN STEAM LINE**

High-Energy Fluid System Piping

A. Fluid Systems Separated from Essential Systems and Components

For the purpose of satisfying the separation provisions of plant arrangement as specified in B.1.a of the Branch Technical Position APCS 3-1, a review of the piping layout and plant arrangement drawings should clearly show that the effects of postulated piping breaks at any location are isolated or physically remote from essential systems and components. At the designer's option, break locations as determined from B.1.c and B.1.d of Branch Technical Position MEB 3-1 may be assumed for this purpose.

B. Fluid System Piping in Containment Penetration Area

Breaks need not be postulated in those portions of piping identified in B.2.c of the Regulatory Position APCS 3-1, provided they meet the requirements of the ASME Code, Section III, Subarticle NE-1120, and the following additional design requirements:

1. The following design stress and fatigue limits should not be exceeded:

For ASME Code, Section III, Class 2 Piping

- a. The maximum stress ranges as calculated by equation 9 and 10 in Paragraph NC-3652, ASME Code Section III, considering upset plant conditions (i.e., sustained loads, occasional loads, and thermal expansion) and an OBE event should not exceed  $0.8 (S_h + S_A)$ .
  - b. The maximum stress as calculated by equation 9 in Paragraph NC-3652, under the loadings resulting from a postulated piping failure of fluid system piping beyond these portions of piping, should not exceed  $1.8 S_h$ . The deflection-limited stresses are included in equation 9.
2. Welded attachments, for pipe supports or other purposes, to these portions of piping should be avoided except where detailed stress analyses, or tests, are performed to demonstrate compliance with the limits of B.1.b(1) of MEB 3-1.
  3. The number of circumferential and longitudinal piping welds and branch connections should be minimized.
  4. The length of these portions of piping should be reduced to the minimum length practical.

## FNP-FSAR-3K

5. The design of pipe anchors or restraints (e.g., connections to containment penetrations and pipe whip restraints) should not require welding directly to the outer surface of the piping (e.g., flued, integrally forged pipe fittings may be used) except where such welds are 100-percent volumetrically examinable in service and a detailed stress analysis is performed to demonstrate compliance with the limits of B.1.b(1) of MEB 3-1.1.

### C. Fluid Systems Enclosed Within Protective Structures

1. With the exception of those portions of piping identified Part B above, breaks in Class 2 and 3 piping (ASME Code, Section III) should be postulated at the following locations in those portions of each piping and branch run within a protective structure or compartment designed to satisfy the plant arrangement provision of B.1.b or B.1.c of Branch Technical Position APCS B 3-1:
  - a. At terminal ends of the run if located within the protective structure. Terminal ends include those locations identified in APCS B 3-1, paragraph B.2.c(3).
  - b. At intermediate locations selected by one of the following criteria:
    - i. At each pipe fitting (e.g., elbow, tee, cross, flange, and nonstandard fitting), welded attachment, and valve.

Where piping contains no fittings, welded attachments, or valves, at one location at each extreme of the piping within the protective structure. (A terminal end, as determined by B.1.c(1)(a) of MEB 3-1, may be considered as one of these extremes.)

- ii. At each location where the stresses exceed  $0.8 (S_h + S_A)$ .

---

#### NOTES:

1. Tees and junctions having comparable sizes and fixtures need not be considered as terminal ends for purposes of break locations when so justified in the stress analysis.
2. Stresses under normal and upset plant conditions, and an OBE event as calculated by equations 9 and 10, Paragraph NC-3652 of the ASME Code, Section III.
3. Select two locations with at least 10-percent difference in stress or, if stresses differ by less than 10 percent, two locations separated by a change of direction of the pipe run.

## FNP-FSAR-3K

The requirement to postulate arbitrary intermediate breaks at locations where the stresses do not exceed  $0.8 (S_n + S_A)$  has been eliminated from the structural design basis (including resultant dynamic and environmental effects) as allowed by NRC Generic Letter 87-11, "Relaxation in Arbitrary Intermediate Pipe Rupture Requirements".

2. The main steam piping downstream of the MSIVs was designed, fabricated, and constructed to the requirements of ANSI B31.1.0-1967 through 1971 addenda, including Code Cases 74 and 95. The main steam piping upstream of the MSIVs was designed, fabricated, and constructed to the requirements of ASME Section III, Class 2, through Summer 1971 addenda. The stress analyses performed on both portions of piping were carried out using identical methods of analysis. Breaks, and the use of no break criteria, in the ANSI B31.1 portions of this piping were postulated using the same criteria that were applied to the ASME Section III portions. The following discussion provides justification for using this approach.

- c. A comparison of materials, quality assurance, welding heat treatment, and nondestructive examination for piping and fittings for the main steam system was made between the ASME Section III, Class 2, portion of the system as installed and the ANSI B31.1.0 portion of the system as installed. The results are as summarized below.

The materials including weld filler metal for both portions have the same physical and chemical properties. The same quality assurance provisions for welding apply throughout both portions. The design material specifications require 100-percent radiography of all longitudinal and circumferential butt welds in both portions of the system. All welding is post-weld heat treated in both portions; i.e., stress relief at 1100-1200°F.

- d. The only differences between the as-fabricated piping systems are as follows:
      - i. ASME Section III portion requires Code Data Forms; ANSI portion does not.
      - ii. ASME Section III portion requires third party inspection; ANSI portion does not.
      - iii. All piping and associated welding filler metal that is part of the containment penetration is Charpy impact tested. Impact testing is required by ASME Section III and may be advisable for cold hydrostatic testing, but is not needed for system operation as brittle fracture would not occur at main steam operating temperature.

## FNP-FSAR-3K

In summary the ANSI portion of the main steam piping is equivalent to the ASME Section III portion. However, the "N" stamp cannot be applied to ANSI piping because of items i and ii above. This difference does not affect the quality of material or workmanship.

### D. Augmented Inservice Inspection

Inservice examination and related design provisions in the containment penetration area and throughout the no break region should be in accordance with the following:

1. The protective measures, structures, and guard pipes should not prevent the access required to conduct the inservice examinations specified in the ASME Boiler and Pressure Vessel Code, Section XI, Division 1, "Rules for Inspection and Testing of Components in Light-Water Cooled Plants."
2. For those portions of fluid system piping identified in B.2.c of APCS 3-1, the extent of inservice examinations completed during each inspection interval (IWA-2400, ASME Code, 1974 Edition with Addenda through Summer 1975, Section XI) should provide 100-percent volumetric examination of circumferential and longitudinal pipe welds within the boundary of these portions of piping to the extent practical.
3. The areas subject to examination should be defined in accordance with Examination Categories C-F and C-G for Class 2 piping welds in Table IWC-2520.



FNP-FSAR-3K

**ATTACHMENT B**  
**PIPE WHIP RESTRAINT DESIGN**

**ATTACHMENT B**

**PIPE WHIP RESTRAINT DESIGN**

**APPROACH**

A pipe whip restraint is designed to absorb the energy of a pipe whipping due to a slot or guillotine break. The gap between the pipe and its restraint is kept to a minimum, commensurate with allowing no contact under hot and cold conditions. In the case of a slot break, the direction which has the greatest gap is used to determine kinetic energy. The restraints are designed to deform plastically within a ductility range of 3 to 26. The lower value is chosen to ensure that the impact between pipe and restraint is plastic, with no significant rebound. The upper limit is chosen to be well below ultimate strain and to preclude bending instability. The restraint is comprised of a ring with two or four parallel legs connecting it to a support as shown in this attachment. Two load conditions are considered:

A. Parallel to legs.

The plastic hinge occurs in the ring at the point of load application.

B. Perpendicular to legs.

The plastic hinges form at the base of the legs.

The analytical procedure involves an energy-balance approach from which time is removed as a parameter by assuming that the thrust force is constant. The resistance-displacement diagrams for the pipe and restraint are constructed and the equilibrium position of the system is computed. If the ductility is outside the accepted limits, the restraint is redesigned until the ductility criterion is satisfied. When the final restraint configuration is established, all other components such as bolts, welds, etc., are designed statically and elastically to be at least as strong as the restraint.

**PROCEDURE**

I. Find parameters. Assign known values.

II. Determine resistance-displacement diagram for pipe (slot or guillotine).

III. Check to determine whether restraint is required.

FNP-FSAR-3K

- IV. Design restraint. Determine resistance-displacement diagrams for two load conditions.
- V. Find restraint distortion.
- VI. Find restraint ductility. If ductility is not between 3 and 26, return to Step IV.
- VII. Design elastic components statically, using the resistance of the restraint as the load.

# FNP-FSAR-3K

## I YIELD STRESS FOR PIPE AND RESTRAINT - INPUT PARAMETERS

$$\sigma_y^P = \text{nominal yield stress for pipe} \times \text{TC}$$

$$\sigma_y^R = \text{nominal yield stress for restraint} \times \text{TC} \times \text{DIF}$$

where

TC = temperature coefficient (reduction)

DIF = Dynamic Increase Factor (to account for strain rate effect)

$$= 1.10$$

### Example

For main steam line pipes (SA-155) and restraints (SA-516)

Fluid temp. = Pipe temp. = 547°F  
Restraint temp. = 400°F

From Table 1 - 2.1 of Section III of the ASME Code, the following data can be determined:

Pipe:

$$S_y = 30.7 - 0.47 (30.7 - 28.1) = 29.4 \text{ ksi}$$

$$\text{TC} = 29.4/38.0 = 0.772$$

$$\sigma_y^P = 38 \times 0.772 = 29.4 \text{ ksi}$$

Restraint:

$$S_y = 32.6 \text{ ksi}$$

$$\text{TC} = 32.6/38.0 = 0.86$$

$$\sigma_y^R = 38 \times 0.86 \times 1.10 = 35.9 \text{ ksi}$$

F = constant jet thrust force



$y_g$  = maximum possible gap between pipe wall and restraint

II RESISTANCE-DISPLACEMENT RELATIONSHIP FOR PIPE

$E$  = modulus of elasticity

$I$  = moment of inertia

$S$  = elastic section modulus



FNP-FSAR-3K

The pipe stiffness is determined by taking the reciprocal of the deflection under the load with  $F = 1$ .

From the Manual of Steel Construction, seventh edition, AISC:


Page 2-205, No. 22

$$\text{CASE I} \quad K_P = \frac{6 EI}{2L_F^3 - 3L_F^2(L_F - L_P) + (L_F - L_P)^3}$$

Page 2-203, No. 17

$$\text{CASE II} \quad K_P = \frac{L_T^3}{L_P^2} \cdot \frac{6 EI}{(L_T - L_P)^2 [3L_F L_T - 3L_F L_P - (L_T - L_P) L_P]}$$

The resistance-displacement diagram for a member in bending is:



If the plastic section modulus is used, then the resistance is calculated as  $R'_p$  and the plastic displacement as  $y'_p$ . If the elastic section modulus is used, these values are  $R_p$  and  $y_p$ . Since the energy absorbed by the pipe equals the area under the resistance-displacement diagram, it is conservative to use the elastic section modulus and unconservative to use the plastic section modulus. In the former case, the cross-hatched area is neglected, while, in the latter, the dotted area is included. The conservative approach is employed here.

FNP-FSAR-3K

$\sigma_Y^P$  = design yield stress for pipe

$$\text{Yield moment} = \sigma_Y^P S = R_P \beta L_F$$

$$\beta = 1 \quad \text{Case I}$$

$$\beta = \frac{(L_T - L_F)^2}{L_T^2} \quad \text{Case II} \quad L_F < L_T/2$$

$$\beta = \frac{L_F(L_T - L_F)}{L_T^2} \quad \text{Case II} \quad L_F > L_T/2$$

$\beta$  = dimensionless function of support conditions

Solving for  $R_P$ :

$$R_P = \frac{\sigma_Y^P S}{\beta L_F}$$

$$R_P = K_P y_P$$

$$y_P = \frac{R_P}{K_P}$$

## FNP-FSAR-3K

### III CHECK TO SEE WHETHER RESTRAINT IS REQUIRED

Before a pipe whip restraint is designed, it must be determined whether the pipe reaches equilibrium before the restraint is contacted. This condition is given by:

$$y < y_g$$

The equation for the maximum displacement ( $y$ ) of the pipe in this condition for the case when the pipe remains elastic is

$$1. \quad y = \frac{2F}{K_p} \quad ; \quad y < y_p < y_g$$

For the case when the maximum displacement ( $y$ ) exceeds yield, the equation is

$$2. \quad y = \frac{1}{2} \frac{R_p y_p}{R_p - F} \quad ; \quad y_p < y < y_g$$


If  $y < y_g$ , no restraint is required.

Note: Relationships 1 and 2 are valid if  $R_p > F$



FNP-FSAR-3K

IV RESISTANCE-DISPLACEMENT RELATIONSHIP FOR RESTRAINTS




Reference: Roark, Formulas for Stress and Strain, 4th Edition,  
 P. 172, Case 1  
 P. 173, Case 5

FNP-FSAR-3K

CASE 1

Treat problem as system with one degree of indeterminacy.



From Case 5, Roark for primary structure:

$$\Delta_1 = \frac{PL_R^3}{2E_R I_R} \left[ 0.1488 - 0.0554 \right] = \frac{0.0934 PL_R^3}{2E_R I_R}$$

From Case 1, Roark for redundant structure:

$$\Delta_2 = - \frac{0.137 HL_R^3}{2E_R I_R}$$

Compatibility requires that  $\Delta = \Delta_1 + \Delta_2$

$$\Delta = \frac{L_R^3}{2E_R I_R} \left[ 0.0934 P - 0.137 H \right] \quad (1)$$

To find H, consider deflections in the direction of H.

FNP-FSAR-3K

From Case 5, Roark for primary structure:

$$\Delta_1 = \frac{0.1366 P L_R^3}{2 \times 2 \times E_R \times I_R}$$

From Case 1, Roark for redundant structure:

$$\Delta_2 = - \frac{0.149 H L_R^3}{2 \times E_R \times I_R}$$

Compatibility requires that the force in the column equal the redundant force H.

$$F_{\text{column}} = H; \Delta = \Delta_1 + \Delta_2 = \frac{H L_c^3}{3E_c I_c}$$

$$\frac{L_c^3}{3E_c I_c} H = \frac{0.03415 P L_R^3}{E_R I_R} - \frac{0.0745 H L_R^3}{E_R I_R}$$

Solving for H

$$H \left[ \frac{L_c^3}{3E_c I_c} + \frac{0.0745 L_R^3}{E_R I_R} \right] = \frac{0.03415 L_R^3 P}{E_R I_R}$$

$$H = \frac{0.10245 E_c I_c L_c^3 P}{E_R I_R L_c^3 + 0.2235 E_c I_c L_R^3} \quad (2)$$

Substituting (2) into (1),

$$\Delta = \frac{L_R^3 P}{2E_R I_R} \left[ 0.0934 - \frac{0.014 E_c I_c L_R^3}{E_R I_R L_c^3 + 0.2235 E_c I_c L_R^3} \right] \quad (3)$$

Determination of Maximum Moment,  $M_{\text{max}}$

The maximum moment for the primary structure occurs under the load. From Case 5, Roark:

$$M_{\text{max}_1} = \frac{P L_R}{4}$$

FNP-FSAR-3K

The redundant moment under the real load is given by Case 1, Roark:

$$M_{\max_2} = - 0.1817 HL_R$$

$$M_{\max} = \frac{PL_R}{4} - 0.1817 HL_R$$

$$= PL_R \left[ 0.25 - \frac{0.0186 E_C I_C L_R^3}{E_R I_R L_C^3 + 0.2235 E_C I_C L_R^3} \right] \quad (4)$$

For plastic conditions:

$$M_{\max} = \sigma_Y Z_R \quad (5)$$

For the condition  $P = R_R$

Substituting (5) into (4) and solving:

$$R_R = P = \frac{\sigma_Y Z_R [E_R I_R L_C^3 + 0.2235 E_C I_C L_R^3]}{L_R [0.25 E_R I_R L_C^3 + 0.0373 E_C I_C L_R^3]} \quad (6)$$

Substituting (6) into (3) and adding the extension of the columns:


$$\Delta = \bar{y}_r = \frac{L_C R_R}{2A_C E_C} + \frac{L_R^3 R_R}{2E_R I_R} \left[ 0.0934 - \frac{0.014 E_C I_C L_R^3}{E_R I_R L_C^3 + 0.2235 E_C I_C L_R^3} \right]$$

$$\bar{y}_r = \frac{\sigma_Y Z_R}{2 L_R} \left[ \left( \frac{E_R I_R L_C^3 + 0.2235 E_C I_C L_R^3}{0.25 E_R I_R L_C^3 + 0.0373 E_C I_C L_R^3} \right) \left( \frac{L_C}{A_C E_C} + \frac{L_R^3}{E_R I_R} \right) \right. \\ \left. \times \left\{ \frac{0.00687 E_C I_C L_R^3 + 0.0934 E_R I_R L_C^3}{E_R I_R L_C^3 + 0.2235 E_C I_C L_R^3} \right\} \right] \quad (7)$$

FNP-FSAR-3K

CASE 2

Treat problem as system with one degree of indeterminacy.



From Case 1, Roark:

$$\Delta_1 = \frac{0.149 P L_R^3}{E_R I_R} + \frac{P L_C^3}{3 E_C I_C}$$

$$\Delta_2 = -\frac{0.149 H L_R^3}{E_R I_R} - \frac{H L_C^3}{3 E_C I_C}$$

$$\Delta = \Delta_1 + \Delta_2$$

Also

$$H = \frac{3 E_C I_C}{L_C^3} \Delta \quad \text{or} \quad \Delta = \frac{L_C^3}{3 E_C I_C} H$$

So

$$\frac{H L_C^3}{3 E_C I_C} = \frac{0.149 (P - H) L_R^3}{E_R I_R} + \frac{L_C^3 (P - H)}{3 E_C I_C} = \Delta \quad (8)$$

FNP-FSAR-3K

Solving for H

$$H = \frac{\left[ 0.447 E_C I_C L_R^3 + E_R I_R L_C^3 \right] P}{\left[ 0.447 E_C I_C L_R^3 + 2 E_R I_R L_C^3 \right]} \quad (9)$$

Substituting (9) into (8),

$$\Delta = \left[ \frac{0.149 L_R^3}{E_R I_R} \left( 1 - \frac{0.447 E_C I_C L_R^3 + E_R I_R L_C^3}{0.447 E_C I_C L_R^3 + 2 E_R I_R L_C^3} \right) + \frac{L_C^3}{3 E_C I_C} \left( 1 - \frac{0.447 E_C I_C L_R^3 + E_R I_R L_C^3}{0.447 E_C I_C L_R^3 + 2 E_R I_R L_C^3} \right) \right] P \quad (10)$$

The maximum column moment occurs at the base.

$$M_{\text{column}} = \sigma_Y Z_C = H L_C \quad (11)$$

$$\frac{\sigma_Y Z_C}{L_C} = H = P \left[ \frac{0.447 E_C I_C L_R^3 + E_R I_R L_C^3}{0.447 E_C I_C L_R^3 + 2 E_R I_R L_C^3} \right]$$

For this case,  $P = R_R$ .

So

$$R_R = \frac{\sigma_Y Z_C}{L_C} \left[ \frac{0.447 E_C I_C L_R^3 + 2 E_R I_R L_C^3}{0.447 E_C I_C L_R^3 + E_R I_R L_C^3} \right] \quad (12)$$

Substituting (11) into (8) yields

$$\bar{y}_T = \frac{\sigma_Y Z_C L_C^2}{3 E_C I_C} \quad (13)$$

FNP-FSAR-3K

$$\text{Let } C_1 \equiv I_R L_C^3 ; C_2 \equiv I_C L_R^3 ; E = E_R = E_C$$

Then:

Load Case 1

$$R_R = \frac{\sigma_Y Z_R}{I_R} \cdot \frac{C_1 + 0.2235 C_2}{0.25 C_1 + 0.0373 C_2}$$

$$\bar{y}_r = \frac{R_R}{2E} \left[ \frac{L_C}{A_C} + \frac{L_R^3}{I_R} \times \frac{0.0934 C_1 + 0.00687 C_2}{C_1 + 0.2235 C_2} \right]$$

Load Case 2

$$R_R = \frac{\sigma_Y Z_C}{L_C} \left[ \frac{2 C_1 + 0.447 C_2}{C_1 + 0.447 C_2} \right]$$


$$\bar{y}_r = \frac{\sigma_Y Z_C L_C^2}{3 E I_C}$$

# FNP-FSAR-3K

## V EQUILIBRIUM-POSITION CALCULATIONS

Assumptions:

- (a) Restraint goes plastic.
- (b) Restraint has no mass.



The relationships for  $y$  are given by the following three equations in which the displacement of the restraint is given by  $y - y_g$ .

The variables occurring in the equations are described in the following:

- $y$  = Maximum displacement
- $y_p$  = Yield displacement for pipe
- $y_r$  = Yield displacement for restraint
- $y_g$  = Pipe-restraint gap
- $\bar{y}_r$  = Yield distortion of restraint =  $y_r - y_g$
- $F$  = Forcing function
- $R_p$  = Pipe resistance
- $R_r$  = Restraint resistance =  $k_r \bar{y}_r = k_r y_r - k_r y_g$
- $k_p$  = Pipe stiffness,  $k_p = R_p / y_p$
- $k_r$  = Restraint stiffness,  $k_r = R_r / \bar{y}_r = R_r / (y_r - y_g)$
- $m_p$  = Mass of pipe
- $m_r$  = Mass of restraint
- $m_t = m_p + m_r$



FNP-FSAR-3K

Case (1)

$$y_r < y < y_p$$

$$y = \frac{F - k_r y_r + k_r y_g}{k_p} + \sqrt{\left[ \frac{F - k_r y_r + k_r y_g}{k_p} \right]^2 + \frac{k_r (y_r^2 - y_g^2)}{k_p} - (1 - m_p/m_t) \cdot \frac{y_g}{k_p} (2F - k_p y_g)}$$

Case (2)

$$y > y_r > y_p > y_g$$

or

$$y > y_p > y_r > y_g$$

$$y = \frac{1}{2} \frac{y_g (2F - k_p y_g) (1 - m_p/m_t) - k_p y_p^2 - k_r (y_r^2 - y_g^2)}{F - k_p y_p - k_r (y_r - y_g)}$$

Case (3)

$$y > y_r > y_g > y_p$$

$$y = \frac{1}{2} \frac{2y_g (F - k_p y_p) (1 - m_p/m_t) - (m_p/m_t) k_p y_p^2 - k_r (y_r^2 - y_g^2)}{F - k_p y_p - k_r (y_r - y_g)}$$

Assumption (b) yields:

$$m_t = m_p \quad 1 - \frac{m_p}{m_t} = 0 \quad \frac{m_p}{m_t} = 1$$

FNP-FSAR-3K

Equations (2) and (3) are identical under this condition.

$$y = \frac{F - R_r + \sqrt{(F - R_r)^2 + K_p R_r (\bar{y}_r + 2 y_g)}}{K_p} \quad y < y_p$$

$$y = \frac{1}{2} \frac{R_p y_p + R_r (\bar{y}_r + 2 y_g)}{R_p + R_r - F} \quad y > y_p$$

If  $R_p = 0$  (pipe does not act),

$$y = \frac{1}{2} \frac{R_r (\bar{y}_r + 2 y_g)}{R_r - F}$$

If  $y_g = 0$  and  $R_r = 2F$ , then

$$y = \frac{1}{2} \times \frac{2F \bar{y}_r}{2F - F} = \bar{y}_r$$

which is the well-known dynamic result for an elastic single degree of freedom system with a constant force.

## FNP-FSAR-3K

VI DUCTILITY RATIO IS DEFINED AS:


$$\mu = \frac{Y - Y_s}{Y_r}$$

Since the component members of the restraint are subjected to bending deformations, a maximum ductility of  $\mu = 26$  is used to preclude instability. A minimum ductility of  $\mu = 3$  is used to ensure a plastic impact with no rebound. A strain of 50 percent of ultimate corresponds to  $\mu = 80$ , so the actual strains are kept below this point.

VII DESIGN OF ELASTIC COMPONENTS

All bolts, welds, and supporting structures are analyzed statically and elastically. The maximum load which can be transmitted by the restraint to these items equals the resistance of the restraint. Therefore, the design load is

$$\text{Load} \equiv R_R$$



$R_R$  ① = Load Case 1, resistance for Load Case 1

$R_R$  ② = Load Case 2, resistance for Load Case 2

# FNP-FSAR-3K

## DESIGN GUIDE

### Step I

Determine pipe properties  $E$ ,  $I$ ,  $S$ ,  $F$ ,  $\sigma_Y^P$ , and  $y_g$


$E$  = modulus of elasticity

$I, S$  = pipe properties

$y_g$  = gap

$F$  = jet force

$\sigma_Y^P$  = design yield stress for pipe



### Step II


#### a) Guillotine Failure

$$K_P = \frac{6 EI}{\left[ 2 L_F^3 - 3 L_F^2 (L_F - L_P) + (L_F - L_P)^3 \right]}$$

$$y_p = \frac{\sigma_Y^P S}{L_F} \frac{1}{K_P}$$


$$R_p = K_P y_p = \frac{\sigma_Y^P S}{L_F}$$

Draw Diagram:



FNP-FSAR-3K

b) Slot Failure



$$K_P = \frac{6 EI L_T^3}{(L_T - L_F)^2 (3L_F L_T - 2L_F L_P - L_T L_P)} L_P^2$$

$$y_P = \frac{\sigma_Y^P S L_T^2}{\beta_1} \cdot \frac{1}{K_P} \quad R_P = K_P y_P = \frac{\sigma_Y^P S L_T^2}{\beta_1}$$

$$\beta_1 = (L_T - L_F) L_F^2 \quad L_F > \frac{L_T}{2} \quad \beta_1 = (L_T - L_F)^2 L_F \quad L_F < \frac{L_T}{2}$$

FNP-FSAR-3K

Step III

a. Compute  $y = \frac{2F}{K_P}$

If  $y > y_p$ , go to III b.

If  $y > y_g$ , go to IV.

If  $y < y_g$  and  $y < y_p$ , no restraint needed.

b. Compute  $y = \frac{1}{2} \frac{R_P y_p}{R_P - F}$

If  $0 < y < y_g$ , no restraint required.

Step IV Restraint Design

Choose:  $I_C, I_R, A_C$ . Find  $Z_C, Z_R$ .

$I_R, \sigma_Y^R$     Load Case 1     $C_1 = I_R L_C^3$      $C_2 = I_C L_R^3$

$$R_R = \frac{\sigma_Y Z_R}{L_R} \times \frac{C_1 + 0.2235 C_2}{0.25 C_1 + 0.0373 C_2}$$

$$\bar{y}_r = \frac{R_R}{2E} \left[ \frac{L_C}{A_C} + \frac{L_R^3}{I_R} \times \frac{0.0934 C_1 + 0.00687 C_2}{C_1 + 0.2235 C_2} \right]$$


Load Case 2

$$R_R = \frac{\sigma_Y Z_C}{L_C} \left[ \frac{2 C_1 + 0.447 C_2}{C_1 + 0.447 C_2} \right]$$

$$\bar{y}_r = \frac{\sigma_Y Z_C L_C^2}{3 E I_C}$$

FNP-FSAR-3K

Draw diagram:



If  $R_p + R_R < F$ , redesign

Step V

$$a. \quad y = \frac{F - R_R + \sqrt{(F - R_R)^2 + R_p K_p (\bar{y}_r + 2 y_g)}}{K_p}$$

If  $y < y_p$ , go to Step VI.

$$b. \quad y = \frac{\frac{1}{2} R_p y_p + R_r (\bar{y}_r + 2 y_g)}{R_p + R_R - F}$$

If  $y < y_p$ , recheck calculations.

Note: These equations are valid if  $y - y_g > \bar{y}_r$

$$\text{Step VI} \quad \mu = \frac{y - y_g}{\bar{y}_r}$$


If  $3 \leq \mu \leq 26$ , go to VII; otherwise, go to IV.

Step VII Design Bolts, Welds, etc.

For the static loading, use  $R_R$ .




FNP-FSAR-3K



FNP-FSAR-3K


FLOW CHART (CONTINUED)



# FNP-FSAR-3K

## TYPICAL DESIGN EXAMPLE

### I. 32 In. O.D. MAIN STEAM PIPE PROPERTIES



$E_P = 26,000 \text{ ksi}$	$I_P = 12,059.72 \text{ in}^4$
$F = 342 \text{ K}$	$S_P = 753.74 \text{ in}^3$
$y_g = 1 \text{ in}$	$\sigma_Y^P = 29.4 \text{ ksi}$

### II. CALCULATION OF $K_P$ , $y_p$ , AND $R_p$

$$K_P = \frac{6 E_P I_P}{\left[ 2L_F^3 - 3L_F^2 (L_F - L_P) + (L_F - L_P)^3 \right]}$$

$$= \frac{(6) (26,000 \text{ ksi}) (12,059.72 \text{ in}^4)}{\left[ 2(126'')^3 - 3(126'')^2 (64'') + (64'')^3 \right]}$$

$$= \underline{\underline{1548.8 \text{ K/in}}}$$

FNP-FSAR-3K

$$y_P = \frac{\sigma_Y^P S_P}{L_F} \cdot \frac{1}{K_P} = \frac{(29.4 \text{ ksi})(753.74 \text{ in}^3)}{(126 \text{ in})} \cdot \frac{1}{1548.8 \text{ K/in}} = \underline{0.114 \text{ in.}}$$

$$R_P = (K_P)(y_P) = (1548.8 \text{ K/in})(0.114 \text{ in})$$

$$= \underline{176.6 \text{ K}}$$

III. CHECK TO DETERMINE WHETHER A RESTRAINT IS NEEDED.

a. Compute:

$$y = \frac{2F}{K_P} = \frac{(2)(342 \text{ K})}{(1548.8 \text{ K/in})} = \underline{0.442 \text{ in.}} > y_P = 0.114 \text{ in.} - \text{Go to III.b}$$

b. Compute:

$$y = \frac{1}{2} \frac{R_P y_P}{R_P - F} = \frac{1}{2} \frac{(176.6 \text{ K})(0.114 \text{ in})}{(176.6 \text{ K} - 342 \text{ K})} = \underline{-0.061 \text{ in.}}$$

Neg. value - need restraint

IV. RESTRAINT DESIGN

Ring Size

$$I_R = 64.125 \text{ in}^4$$

$$Z_R = 41.46 \text{ in}^3$$

$$A_R = 54.00 \text{ in}^2$$

$$L_R = 18.25 \text{ in}$$

$$C_1 = I_R L_C^3 = (64.125 \text{ in}^4)(30.0 \text{ in})^3 = \underline{1,731,375 \text{ in}^7}$$

$$C_2 = I_C L_R^3 = (400.833 \text{ in}^4)(18.25 \text{ in})^3 = \underline{2,436,420 \text{ in}^7}$$

Column Size

$$I_C = 400.833 \text{ in}^4$$

$$Z_C = 130.88 \text{ in}^3$$

$$A_C = 25.00 \text{ in}^2$$

$$L_C = 30.00 \text{ in}$$

FNP-FSAR-3K

A. Load Case 1

$$R_R = \frac{\sigma_Y^R Z_R}{L_R} \times \frac{C_1 + 0.2235 C_2}{0.25 C_1 + 0.0373 C_2}$$

$$= \frac{(35.9 \text{ ksi})(41.46 \text{ in}^3)}{(18.25 \text{ in})} \times \frac{(1,731,375 \text{ in}^7) + 0.2235(2,436,420 \text{ in}^7)}{0.25(1,731,375 \text{ in}^7) + 0.0373(2,436,420 \text{ in}^7)}$$

= 354.4 K

---

$$\bar{y}_R = \frac{R_R}{2E_R} \left[ \frac{L_C}{A_C} + \frac{L_R^3}{I_R} \times \frac{0.0934 C_1 + 0.00687 C_2}{C_1 + 0.2235 C_2} \right]$$

$$= \frac{(.354.4 \text{ K})}{(2)(29,000 \text{ ksi})} \left[ \frac{30.0 \text{ in}}{25.0 \text{ in}^2} + \frac{(18.25 \text{ in})^3}{64.125 \text{ in}^4} \right]$$

$$\times \frac{0.0934(1,731,375 \text{ in}^7) + 0.00687(2,436,420 \text{ in}^7)}{(1,731,375 \text{ in}^7) + 0.2235(2,436,420 \text{ in}^7)}$$

$\bar{y}_R = 0.053 \text{ in.}$

---

B. Load Case 2

$$R_R = \frac{\sigma_Y^R Z_C}{L_C} \left[ \frac{2 C_1 + 0.447 C_2}{C_1 + 0.447 C_2} \right]$$

$$= \frac{(35.9 \text{ ksi})(130.88 \text{ in}^3)}{(30.0 \text{ in})} \left[ \frac{2(1,731,375 \text{ in}^7) + 0.447(2,436,420 \text{ in}^7)}{(1,731,375 \text{ in}^7) + 0.447(2,436,420 \text{ in}^7)} \right]$$



= 252.8 K

---

FNP-FSAR-3K

$$\bar{y}_R = \frac{\sigma_Y^R Z_C L_C^2}{3 EI_C} = \frac{(35.9 \text{ ksi})(130.88 \text{ in}^3)(30.0 \text{ in})^2}{(3)(29,000 \text{ ksi})(400.833 \text{ in}^4)} = \underline{0.1213 \text{ in.}}$$

RESISTANCE-DISPLACEMENT DIAGRAMS



V. A. CALCULATION OF  $\bar{y}$ ; LOAD CASE 1

a. Calculate:

$$y = \frac{F - R_R + \sqrt{(F - R_R)^2 + R_R(\bar{y}_R + 2 y_R)K_P}}{K_P}$$

$$y = \frac{342 \text{ K} - 354.4 \text{ K} + \sqrt{(342 \text{ K} - 354.4 \text{ K})^2 + 354.4 \text{ K}(0.053 \text{ in} + 2 \times 1.0 \text{ in}) 1548.8 \text{ K/in}}}{1548.8 \text{ K/in}}$$

$$y = 0.677 \text{ in.} > y_p = 0.114 \text{ in. N. G.}$$

b. Calculate:

$$y = \frac{1}{2} \frac{R_P y_p + R_R(\bar{y}_R + 2 y_R)}{R_P + R_R - F} = \frac{1}{2} \frac{(176.6 \text{ K})(0.114 \text{ in}) + 354.4 \text{ K}(0.053 \text{ in} + 2 \times 1.00 \text{ in})}{176.6 \text{ K} + 354.4 \text{ K} - 342 \text{ K}} = \underline{1.978 \text{ in.}}$$

FNP-FSAR-3K

V. B. CALCULATION OF y; LOAD CASE 2

a. Calculate:

$$y = \frac{F - R_R + \sqrt{(F - R_R)^2 + R_R(\bar{y}_R + 2y_R)K_P}}{K_P}$$

$$= \frac{342 \text{ K} - 252.8 \text{ K} + \sqrt{(342 \text{ K} - 252.8 \text{ K})^2 + 252.8 \text{ K}(0.1213 \text{ in} + 2 \times 1 \text{ in}) 1548.8 \text{ K/in.}}}{1548.8 \text{ K/in.}}$$

= 0.649 in. >  $y_p = 0.114 \text{ in.}$  N.G.

b. Calculate:

$$y = \frac{1}{2} \frac{R_P y_P + y_R(\bar{y}_R + 2y_R)}{R_P + R_R - F}$$

$$= \frac{1}{2} \frac{(176.6 \text{ K})(0.114 \text{ in}) + 252.8 \text{ K}(0.1213 \text{ in} + 2 \times 1 \text{ in})}{176.6 \text{ K} + 252.8 \text{ K} - 342 \text{ K}}$$

= 3.183 in

VI. CALCULATION OF  $\mu$

A. Load Case 1

$$\mu = \frac{y - y_R}{\bar{y}_R} = \frac{1.978 \text{ in} - 1.000 \text{ in}}{0.053 \text{ in}} = 18.5 < 26, \therefore \text{OK.}$$

B. Load Case 2

$$\mu = \frac{y - y_R}{\bar{y}_R} = \frac{3.183 \text{ in} - 1.000 \text{ in}}{0.1213 \text{ in}} = 18.0 < 26, \therefore \text{OK.}$$

VII. RESTRAINT RING BOLT DESIGN (VIA AISC)

A. Compute forces taken by bolts.

FNP-FSAR-3K

Case I

$$R_R = 354.4 \text{ K} \quad L_R = 18.25 \text{ in.} \quad L_C = 30.00 \text{ in.}$$




$$\beta = \frac{I_R}{I_C} = \frac{64.125 \text{ in}^4}{400.833 \text{ in}^4} = 0.1600$$

$$H = \frac{0.10245 R_R L_R^3}{\beta L_C^3 + 0.2235 L_R^3}$$

$$H = \frac{0.10245 (354.4 \text{ K}) (18.25 \text{ in})^3}{0.1600 (30.00)^3 + 0.2235 (18.25 \text{ in})^3}$$

$$= \underline{\underline{38.87 \text{ K.}}}$$

$$M_{\max} = H \times L_C = \underline{\underline{1166.1 \text{ in-K}}}$$



Case II

$$R_R = 252.8 \text{ K}$$

$$H = \frac{R_R L_C^3}{0.447 L_R^3 \alpha + 2L_C^3}, \quad \alpha = \frac{1}{\beta} \frac{I_C}{I_R} = 6.2508$$


$$= \frac{(252.8 \text{ K}) (30.00 \text{ in})^3}{0.447 (18.25 \text{ in})^3 6.2508 + 2(30.0 \text{ in})^3}$$

$$= \underline{\underline{96.14 \text{ K}}}$$

$$M_{\max} = (R_R - H) \times L_C = (252.8 \text{ K} - 96.1 \text{ K}) (30.0 \text{ in})$$

$$M_{\max} = \underline{\underline{4701.0 \text{ in-K}}}$$

$$\text{Other } M = 96.14 \text{ K} (30.0 \text{ in}) = \underline{\underline{2884.2 \text{ in-K}}}$$





FNP-FSAR-3K

B. Compute stresses in bolts.

Refer to AISC Manual Page 5-23 para. 1.6.3

Try 8 - 1-1/4 in.  $\emptyset$  bolts - A-490 material.

Load Case I  $R_R = 354.4$  K  $H = 38.87$  K

$$f_t = \frac{354.4}{8 \times 1.227} = 36.1 \text{ ksi}$$

$$f_v = \frac{38.87}{4 \times 1.227} = 7.92 \text{ ksi} < 1.33 \times 32$$

$$F_t = 1.33 (70 - 1.6 f_v) \leq 1.33 \times 54$$

$$= 1.33 (70 - 1.6 \times 7.92)$$

$$= 76.25 \text{ ksi} > 1.33 \times 54 > f_t \therefore \text{OK.}$$

Load Case II  $R_R = 252.8$  K  $H = 96.14$  K

$$f_v = \frac{(252.8 - 96.14)}{1.227 \times 4} = 31.92 \text{ ksi}$$

$$F_v = 32.00 \times 1.33 = 42.67 > f_v \therefore \text{OK}$$

Note: Allowable stresses  $F_t$  and  $F_v$  are increased by one-third because of short term nature of the design load.

FNP-FSAR-3K

**ATTACHMENT C**

**METHODS USED TO CALCULATE BLOWDOWN RATES FOR  
HIGH ENERGY FLUID LINE RUPTURES**

# FNP-FSAR-3K

## ATTACHMENT C

### METHODS USED TO CALCULATE BLOWDOWN RATES FOR HIGH-ENERGY FLUID LINE RUPTURES

#### 3K.C.1 BACKGROUND

##### 3K.C.1.1 Introduction

The following describes a method for obtaining mass flowrates which has been used for determining local pressures resulting from a steam line break outside the containment. The flowrates obtained using this procedure are defensible upper bound values for any break location outside the containment. They are intended to be used for local short term pressure calculations and do not necessarily represent limiting conditions for calculating thrust loads or impingement forces; the latter are described in attachment F. Also, in the method that follows, back flow from the intact steam lines and steam generators is included.

##### 3K.C.1.2 Basis for the Calculations

Since detailed flowrate calculations for steam line breaks outside the containment are a function of plant piping layout and break location, the effort required for transient blowdown analyses for all cases involving assessment of consequential damage resulting from the break becomes quite prohibitive. For this reason, it is desirable to obtain defensible upper bound flowrates which are independent of break location.

The limiting plant condition, in terms of both steam generator mass inventory and initial secondary system pressure, is obtained when the plant is at hot shutdown. Because of the high flowrates associated with a steamline break, frothing in the steam generator causes a rapid increase in water level, resulting in a large decrease in the quality of fluid expelled from the steam generator. Although the enthalpy of this low quality fluid is less than that of dry steam, the critical mass flowrate is much higher, resulting in a net increase in the energy release rate from the break. Current evaluations show this to be the limiting case for determining maximum pressure in vented compartments. The blowdown can be broken up into time required for both forward and back flow from a double-ended break, as discussed below.

## FNP-FSAR-3K

- A. Forward flow (steam generator side of the line sustaining the break)
1. Piping decompression - During the time required for the wave to travel to the steam generator nozzle flow restrictor and back to the break, the break flow is limited to sonic velocity of the fluid behind the decompression wave.
  2. Dry steam at flow restrictor - Following the piping decompression, the flow will be restricted to critical flow at the steam generator nozzle flow restrictor for dry steam until entrained water from the steam generator reaches the flow restrictor. This time period can be determined assuming half of the initial steam mass generator passes through the flow restrictor before significant water reaches the restrictor.
  3. Entrained water through flow restrictor - A defensible lower bound on quality of the liquid passing through the steam generator nozzle flow restrictor is obtained by assuming a homogeneous mixture of the initial steam generator inventory. The flow at this point is determined assuming critical flow at the restrictor.
- B. Reverse flow
1. Piping decompression - Since the downstream piping includes headers which may act as reservoirs during decompression, the flow is calculated assuming critical flow at the break exit for dry steam. Depending on the particular case, it may be more limiting to minimize or maximize this time period. Thus the outlined procedure gives a method for determining both cases.
  2. Entrainment through the flow restrictors - As with the forward flow case, the flow will be limited at the steam generator nozzle flow restrictors for the other steam generators (or may choke at another location with an area less than the total restrictor area), given the same assumptions regarding entrained water.

### 3K.C.1.3 Computational Method

Let A = the cross-sectional flow area of the steam pipe at the location of the break (based on the I.D. of the pipe),  
ft<sup>2</sup>

## FNP-FSAR-3K

$A_v$  = the throat area of the flow venturi,  $\text{ft}^2$ .

$P_o$  = no-load secondary system pressure, psia.


$x$  = steam quality, percent.

$h$  = enthalpy of flow, Btu/lb.

$N$  = number of loops.

# FNP-FSAR-3K

- A. Calculation of mass and energy release rates from the forward direction. In general, this is characterized as follows:



1. Calculation of  $w_{1F}$  and  $h_{1F}$

From figure 3K.C-1, get the critical mass velocity ( $\rho V$ ) in lb/s - ft<sup>2</sup> at  $P_o$ .  
Then

$$w_{1F} = (\rho V) * A_p$$

$$h_{1F} = h_g \text{ at } P_o$$

2. Calculation of  $w_{2F}$  and  $h_{2F}$

From figure 3K.C-2, get the  $\rho V$  (lb/s - ft<sup>2</sup>) at  $P_o$  and  $X = 100$  percent

Then

$$w_{2F} = (\rho V) * A_v$$

$$h_{2F} = h_{1F}$$

3. Calculation of  $w_{3F}$  and  $h_{3F}$

From figure 3K.C-2, get the  $V$  (lb/s - ft<sup>2</sup>) at  $P_o$  and  $X = 4$  percent.

## FNP-FSAR-3K

Then

$$W_{3P} = (\rho V) * A_v$$

$$h_{3P} = h_f + x h_{fg} \text{ at } P_o$$

where

$$x = 0.04.$$

#### 4. Calculation to $t_1$ and $t_2$

Let

$\ell_1$  = length of steam piping from the location of the break to the steam generator nozzle flow venturi on the same line, ft.

$$c = 1500 \text{ ft/s.}$$

$M_1$  = mass of steam in one steam generator at  $P_o$ .


Then

$$t_1 = 2 \frac{\ell_1}{c} \text{ and } t_2 = t_1 + \frac{1}{2} \frac{M}{W_{2P}}$$

FNP-FSAR-3K

B. Calculation of mass and energy release rates from the reverse direction.

In general, this flow is characterized as follows:



1. Calculation of  $W_{1B}$  and  $h_{1B}$ :

From figure 3K.C-2, get  $V$  (lb/s - ft<sup>2</sup>) at  $P_o$  and  $x = 100$  percent

Then

$$W_{1B} = (\rho V) * A_p$$

$$h_{1B} = h_x \text{ (at } P_o) = h_{1F}$$

2. Calculation of  $W_{2B}$  and  $h_{2B}$ :

From figure 3K.C-2, get  $V$  (lb/s - ft<sup>2</sup>) at  $P_o$  and  $x = 4$  percent.

Then

$$W_{2B} = (\rho V) * A * (n-1)$$

$$h_{2B} = h_{3F}$$



## FNP-FSAR-3K

### 3. Calculation of T

#### NOTE

Two methods will be outlined. The one which gives the worst results with respect to the compartment pressure analysis must be used.

#### a. Method A (Short Estimate)

Let

$\rho_s$  = density of dry steam at P, lb/ft<sup>3</sup>

$\ell_{st}$  = shortest length of piping from break to nearest flow restrictor on the unbroken line, ft

$A_p$  = defined as before

$M_s$  = defined as before

Then

$$T = \frac{\rho_s \ell_{st} A_p}{W_{IB}} + \frac{1}{2} \frac{M_s}{W_{IB}}$$

#### b. Method B (Long Estimate)

Let

$M_{s(N-1)}$  = total steam mass in steam piping of N-1 intact lines, lb

$M_{sg(N-1)}$  = total steam mass in N-1 steam generators at  $P_o$ , lb [or (N-1)\* $M_s$ ]

Then

$$T = \frac{1}{W_{IB}} [M_{s(N-1)} + M_{sg(N-1)}]$$

## FNP-FSAR-3K

### 3K.C.2 FEEDWATER LINE AND BLOWDOWN LINE BREAKS OUTSIDE CONTAINMENT

#### 3K.C.2.1 Introduction

The following outlines methods for obtaining mass and energy discharge rates following a feedwater line or a blowdown line rupture outside the containment. The outlined methods of calculating mass and energy discharge rates result in conservative upper-bound values which should be used for the calculation of short-term compartment pressures resulting from piping rupture. The discharge rates calculated by these methods should not be used for calculating long-term mass and energy releases, thrust loads, or jet impingement forces.

#### 3K.C.2.2 Basis for the Calculations

##### A. Feedwater System

Under normal operating conditions, the feedwater system will contain pressurized subcooled water. The assumption of a double-ended guillotine break under these conditions results in a decompression wave propagating through the system at sonic velocity with the pressure behind the wave corresponding to saturation pressure of the liquid. Because of the very low compressibility of subcooled water, subcooled blowdown cannot be sustained for more than a few milliseconds, and the total mass release under subcooled blowdown conditions is quite small. Following this extremely short-term initial phase, the pressure will correspond to saturation pressure of the feedwater.

Neglecting the very small amount of mass discharge under subcooled conditions, the net flowrate may be approximated using the Moody<sup>(1)</sup> results for saturated liquid assuming an  $f L/D$  of zero. Thus, the limiting conditions for a feedwater line break are obtained assuming the highest feedwater temperature to be expected under normal conditions. Additional considerations are dependent on the location of the break being addressed and are discussed below:

1. Backflow (steam generator side of break) - If the feedline check valve is between the steam generator and the break, the flow is calculated based on saturation pressure of the feedwater for the time required to empty the piping volume between the break and the check valve. If the break is between the steam generator and the check

## FNP-FSAR-3K

valve, the flowrate must be increased to that corresponding to the steam generator pressure once the perturbation has travelled to the steam generator and back to the break.

2. Forward flow - The initial break flow is estimated based on the saturation pressure of the feedwater. The capacity of the feedwater pumps should be evaluated assuming a discharge pressure corresponding to the feedwater temperature out of the high pressure heater. If this flowrate is greater than the initial break flowrate determined above, the break flowrate should be assumed to increase to the capacity of the pumps once the perturbation has travelled to the nearest pump and back to the break.

- B. Since the blowdown system piping consists of much smaller lines than the feedwater system as well as less interconnecting piping, the effects of friction losses in the piping are included in the calculation. The blowdown flowrate is calculated using the results of Moody's<sup>(2)</sup> evaluation of blowdown of a reservoir through connected piping. The steam generator pressure at no load conditions is used to determine the mass flowrate for saturated liquid.

### 3K.C.2.3 Computational Method

The zero loss maximum blowdown flowrate for saturated liquid based on the Moody<sup>(1)</sup> correlation has been fit to a simple function of pressure to obtain the following relation:

$$G = 250p^{1/2} \quad 300 < P < 1200 \text{ psia}$$

where

P = Saturation pressure of the liquid, psia

G = Mass Velocity, lbm/ft<sup>2</sup> - s

This function may be used to calculate break mass velocity for the feedline rupture, and G<sub>0</sub> for the blowdown line rupture.

Definitions:

A<sub>p<sub>fw</sub></sub> = cross-sectional area of pipe at break location, ft<sup>2</sup>.

## FNP-FSAR-3K

- $P_{sat}$  = saturation pressure corresponding to feedwater temperature at full load.  
 $P_{SG}^{NL}$  = no load secondary system pressure. (This is consistent with a plant trip from full load near the time of a feedwater line rupture.)  
 $C$  = sonic velocity of compressed water - 4500 ft/s.  
 $L_{SG}$  = length of pipe between steam generator and break, ft.  
 $L_p$  = length of pipe between nearest main feedwater pump and break, ft.  
 $W_F$  = forward flow, from break, lbm/s.  
 $W_B$  = back flow from break, lbm/s

### A. Feedwater Line Rupture

1. Backflow (steam generator side of break) - The backflow is determined as follows, depending on the assumptions regarding location of the break with respect to the feedwater line check valve.

With the break not located between the steam generator and the valve

$$W_B = A_p \times 250 (P_{sat}^{fw})^{1/2}, \quad 0 < t < 2L_{SG}/C \text{ (seconds)}$$

$$W_B = A_p \times 250 (P_{SG}^{NL})^{1/2}, \quad 2L_{SG}/C < t \text{ (seconds)}$$

The blowdown for  $t > 2L_{SG}/C$  is assumed to continue until the mass in the steam generator has been discharged.

2. Forward Flow

$$W_F = A_p \times 250 (P_{sat}^{fw})^{1/2}, \quad 0 < t < 2 L_p/C$$

$$= \max [W_p (P_{sat}^{fw}), A_p \times 250 (P_{sat}^{fw})^{1/2}],$$

$$2 L_p/c < t$$

where

$$W_p (P_{sat}^{fw}) = \text{capacity of the main feedwater pumps assuming a discharge pressure of } P_{sat}^{fw}.$$

## FNP-FSAR-3K

As indicated above, once the perturbation from the break has traveled from the break to the feedwater pump and back, the capacity of the feedwater pumps must be evaluated under these conditions to determine if this capacity exceeds the saturated liquid blowdown flowrate. The maximum value obtained using the two methods is assumed as the forward flow out of the break.

### B. Blowdown Line Rupture

Since the blowdown system consists of smaller piping with less interconnected piping which may act as reservoirs during the blowdown, the effect of line resistance may be included in the procedure.

Neglecting line resistance can lead to overpredicting the blowdown rate by a factor of 2 to 5. Allowance for resistance, however, results in a best-estimate blowdown rate with a possible uncertainty of + 40 percent. For an upper-bound prediction of the blowdown rate, the appropriate relation is therefore:

$$G_i = 1.4 \times 250 \times \sqrt{P} \times G_i/G_o = 350 \sqrt{P} G_i/G_o,$$

where  $G_i/G_o$  is a function of  $f L/D$  and is shown on figure 3K.C-3. The flowrate is determined by

$W = A_p \times 350 (P_{sg}^{NL})^{1/2}$   $0 < t < t_1$  seconds starting new loads where  $t_1$  is the time required to discharge the piping volume between the break and a steam generator and leg.

$W = A_p \times 350 (P_{sg}^{NL})^{1/2} \times (G_i/G_o)$ ,  $t_1 < t$  seconds where  $G_i/G_o$  is taken from figure 3K.C-3 as a function of piping resistance  $f L/D$ .

Figure 3K.C-3 is a condensed version of the results given in reference 2 which is applicable over the parameter range of interest. If credit is taken for a flow area in the line that is smaller than the flow area of the pipe, such as a partially closed valve, the mass velocity should be determined assuming zero resistance, i.e.:

$$W = A_v \times 350 (P_{sg}^{NL})^{1/2}$$

where  $A_v$  is the flow area of the restriction.

## FNP-FSAR-3K

Forward and reverse flow out the break should be determined separately and summed.

For both the feedwater line and the blowdown line ruptures, the energy release is determined by multiplying the mass flowrate by the enthalpy of the fluid being expelled. Note that in the case of backflow from a feedwater line rupture, with the break located between the steam generator and the check valve, the fluid enthalpy will change from that of the feedwater to the enthalpy of saturated water in the steam generator.

## FNP-FSAR-3K

### REFERENCES

1. Moody, F. J., "Maximum Flowrate of a Single Component, Two-Phase Mixture," Journal of Heat Transfer, Trans. ASME, Series C, Vol. 86, February 1965, p. 134.
2. Moody, F. J., "Maximum Two-Phase Vessel Blowdown from Pipes," Journal of Heat Transfer, August 1966, p. 285.

## FNP-FSAR-3K

### 3K.C.3 36-in. STEAM LINE BREAK

#### 3K.C.3.1 Introduction

The following outlines a method for obtaining mass flowrates which may be used for determining local pressures resulting from a 36-in. steam line break. The flowrates obtained using this procedure are defensible upper bound values. Note that they are intended to be used for local short-term compartment pressure calculations and are not applicable for calculating long-term mass and energy releases, thrust loads, or jet impingement forces. Also note that in the method that follows, flow from only one side of the break is included. The same procedure is to be used to obtain the flow from the other side.

#### 3K.C.3.2 Basis for the Calculations

Since detailed flowrate calculations for 36-in. steam line breaks are a function of plant piping layout and geometry, the effort required for transient blowdown analyses for all cases involving assessment of consequential damage resulting from the break becomes quite prohibitive. For this reason, it is desirable to obtain defensible upper bound flowrates which are as independent of piping layout as possible.

Figure 3K.C-4 shows possible steam line header configurations in junction with a 36-in. line. The dashed lines on the figure indicate the assumed break locations. If the header is assumed to rupture, the location of the rupture must be chosen to maximize the mass and energy release rates into the compartments (unless stress calculations or other considerations indicate otherwise).

The limiting plant condition in terms of both steam generator mass inventory and initial secondary system pressure are obtained when the plant is at hot shutdown. Because of the high flowrates associated with a steam line break, frothing in the steam generator causes a rapid increase in water level, resulting in a large decrease in the quality of fluid expelled from the steam generator. Although the enthalpy of this low quality fluid is less than that of dry steam, the critical mass flowrate is much higher, resulting in a net increase in the energy release rate from the break. The piping flow areas will determine however, whether or not this water entrained energy release rate is higher than that for dry steam. A method is suggested in the next section for determining a defensible time of entrainment. The flowrate from either side of the break is to be calculated using the same procedure. Hence, the method will be outlined for calculating the flow from one side of the break. The analyst, however, must calculate the rates from



## FNP-FSAR-3K

each side separately and then sum them to obtain the total. This total mass and energy release rate must be used to determine the compartment pressure.

### 3K.C.3.3 Computational Method

In general, the mass and energy release rates from one side of the break may be characterized by figures 3K.C-4, 3K.C-5, and 3K.C-6. Note that in figure 3K.C-6, the energy release rate may actually decrease at the time of entrainment ( $t_e$ ) depending on the area ratios.

Let

- $A_H$  = cross-sectional area of header piping based on the inside diameter,  $ft^2$ .
- $A_v$  = throat area of the steam line flow restrictor,  $ft^2$ .
- $P_o$  = no-load secondary system pressure, psia.
- $x$  = steam quality, percent.
- $h$  = enthalpy of fluid, Btu/lb.
- $N$  = number of flow restrictors upstream of break.
- $G$  = critical mass velocity,  $lbm/s-ft^2$ .
- $m$  = mass release rate, lb/s.
- $E$  = energy release rate, Btu/s.
- $t$  = time after rupture, s.
- $t_e$  = time of entrainment, s.
- $L$  = length of piping from break to nearest steam generator, ft.
- $c$  = velocity of sound in dry saturated steam at  $P_o$ , ft/s.
- $M_{sg}$  = mass of steam in steam generator at initiation of break, lbm.
- $( )_1$  = denotes parameter before  $t_e$
- $( )_2$  = denotes parameter after  $t_e$

## FNP-FSAR-3K

### A. Calculation of Mass Release Rate

1. For  $0 \leq t \leq t_c$

From figure 3K.C-7, get  $G$  at  $P_o$  and  $x = 100$  percent.  
Then

$$m = A_H * G$$

2. For  $t > t_c$

From figure 3K.C-7, get  $G$  at  $P_o$  and  $x = 4$  percent.  
Then

$$m_2 = A_v * N * G$$

### B. Calculation of Energy Release Rate

1. For  $0 \leq t \leq t_c$

From figure 3K.C-8, get  $h_1$  at  $P_o$  and  $x = 100$  percent.

Then

$$E_1 = m_1 * h_1$$

2. For  $t > t_c$

From figure 3K.C-8, get  $h_2$  at  $P_o$  and  $x = 4$  percent.

Then

$$E_2 = M_2 * h_2$$


### C. Calculation of Time of Entrainment

1. If  $E_2 > E_1$ , then get  $M_{sg}$  from figure 3K.C-9 for the appropriate  $P_o$  and steam generator series number. Also get  $G$  at  $P_o$  and  $X = 100$  percent from figure 3K.C-7.

Then

$$t_c = \frac{2L}{C} + 0.5 \frac{M_{sg}}{G} * A_v$$

2. If  $E_2 < E_1$ , then  $t_c = \infty$



REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CRITICAL MASS VELOCITY vs RESERVOIR PRESSURE

FIGURE 3K.C-1

Reservoir Pressure (psia)	Reservoir Quality (%)	Critical Mass Velocity (lbm/s-ft <sup>2</sup> )
1020	4	7400
1106	4	7600
1200	4	8000
1020	100	2100
1106	100	2300
1200	100	2600

\*F. J. Moody, "Maximum Flow Rate of a Single Component, Two-Phase Mixture,"  
Journal of Heat Transfer, Trans. ASME, Series C, vol. 87, February, 1965, p. 134.


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CRITICAL MASS VELOCITY vs RESERVOIR QUALITY AND  
RESERVOIR PRESSURE (VIA MOODY CORRELATION)\*

FIGURE 3K.C-2




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

REDUCTION IN MASS FLOWRATE  
DUE TO PIPING FRACTION LOSSES

FIGURE 3K.C-3




REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

UNIT 1 SIMPLIFIED SCHEMATIC OF STEAM LINE HEADER  
 AND BREAK LOCATION THREE LOOP PLANTS

FIGURE 3K.C-4




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2


MASS RELEASE RATE vs TIME

FIGURE 3K.C-5



REV 21 5/08






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CRITICAL MASS VELOCITY AS  
A FUNCTION AT PRESSURE AND QUALITY

FIGURE 3K.C-7




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

ENTHALPY OR FLUID AS A  
FUNCTION AT PRESSURE AND QUALITY

FIGURE 3K.C-8



REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

STEAM GENERATOR STEAM MASS AS  
A FUNCTION AT INITIAL PRESSURE

FIGURE 3K.C-9

FNP-FSAR-3K

**ATTACHMENT D**

**COMPARTMENT PRESSURE TEMPERATURE ANALYSIS COMPUTER PROGRAM  
DESCRIPTION**

**ATTACHMENT D**

**COMPARTMENT PRESSURE TEMPERATURE ANALYSIS COMPUTER PROGRAM  
DESCRIPTION (COPDA)**

**3K.D.1 INTRODUCTION**

This appendix describes the analytical techniques used to evaluate high-energy pipe rupture.

**3K.D.2 INITIAL COMPARTMENT CONDITIONS**

The masses of air and water as steam in the compartments are determined using the initial input conditions of temperature, pressure, relative humidity, and compartment volumes. The specific humidity of saturated air at the compartment temperature is read from a correlation table of temperature and water vapor in saturated air. The compartment specific humidity is obtained by:

$$SH = (RH) \times (SSH)$$

where:

SH = specific humidity of compartment air, lb steam/lb air

RH = relative humidity of compartment air

SSH = specific humidity of saturated air at compartment temperature, lb steam/lb air.

The vapor pressure of the water is determined by:

$$PW = \frac{(SH)(PT)}{0.623 + SH}$$

where:

PW = vapor pressure of water at compartment temperature, psia

PT = total compartment pressure, psia.

The air pressure in the compartment is determined by:

$$PA = PT - PW$$

## FNP-FSAR-3K

The mass of air in the compartment is evaluated using the perfect gas law equation:

$$MA = \frac{(144)(PA)(V)}{\left(\frac{R}{n}\right)(T)}$$

where:

- V = volume of compartment, ft<sup>3</sup>
- R = gas constant, 1545.3
- T = compartment temperature, °R
- n = molecular weight of air, 28.97 lb/lb mole
- PA = partial pressure of the air lb/in<sup>2</sup>

The mass of water in the compartment, MS, is:

$$MS = (MA)(SH)$$

The masses of air and water in the remaining compartments are determined in the same manner.

The internal energy of the air, UA(I), in each compartment is calculated using 0°F as a base:

$$UA(I) = [CV][MA(I)][TP]$$

where:

- CV = specific heat of air at constant volume, 0.171 Btu/lb-°F
- TP = compartment temperature, °F

The internal energy of the water vapor in each compartment is calculated by the equation:

$$US(I) = [MS(I)][UG]$$

where:

- UG = internal energy of the steam evaluated from the saturated steam tables at the compartment temperature.

**3K.D.3 CONSERVATION OF MASS AND ENERGY IN COMPARTMENTS**

The inventory of the total mass and energy in the compartments is maintained from the inlet and exit flows during the time increment:

$$MA(I) = MA'(I) + \sum^N |MAI| - \sum^N |MAO|$$

$$MW(I) = MW(I) + \sum^N |MWI| - \sum^N |MWO|$$

$$MS(I) = MS'(I) + \sum^N |MSI| - \sum^N |MSO|$$

$$MV(I) = MW(I) + MS(I)$$

$$MT(I) = MV(I) + MA(I)$$

$$UA(I) = UA'(I) + \sum^N |UAI| - \sum^N |UAO|$$

$$UW(I) = UW'(I) + \sum^N | (HI | MWI | ) | - \sum^N | (HO | MWO | ) |$$

$$US(I) = US'(I) + \sum^N | (HGI | MSI | ) | - \sum^N | (HGO | MSO | ) |$$

$$UV(I) = UW(I) + US(I)$$

$$UV(I) = UV(I) + UA(I)$$

where:

Primed (') values refer to end of previous time step; all other values refer to current time step.

MA(I)	=	mass of air in compartment (I), lb
MW(I)	=	mass of water in compartment (I), lb
MS(I)	=	mass of steam in compartment (I), lb
MV(I)	=	mass of water and steam in compartment (I), lb
MT(I)	=	total mass in compartment (I), lb
MAI	=	mass of air entering compartment, lb
MAO	=	mass of air leaving compartment, lb
MWI	=	mass of water entering compartment, lb
MWO	=	mass of water leaving compartment, lb

## FNP-FSAR-3K

MSI	=	mass of steam entering compartment, lb
MSO	=	mass of steam leaving compartment, lb
UAI	=	total energy of air entering compartment, Btu
UAO	=	total energy of air leaving compartment, Btu
HI	=	enthalpy of water entering compartment (I), Btu/lb
HO	=	enthalpy of water leaving compartment (I), Btu/lb
HGI	=	enthalpy of steam entering compartment (I), Btu/lb
HGO	=	enthalpy of steam leaving compartment (I), Btu/lb
UA(I)	=	energy in air in compartment (I), Btu
UW(I)	=	energy in water in compartment (I), Btu
US(I)	=	energy in steam in compartment (I), Btu
UV(I)	=	energy in two-phase mixture in compartment (I), Btu
UT(I)	=	total energy in compartment (I), Btu.

### 3K.D.4 COMPARTMENT PRESSURE CALCULATIONS

The compartment pressure is calculated using the total mass and energy in the compartment after the flow from the upstream compartments and/or the blowdown has been added to the compartment inventory of mass and energy. A convergence procedure is used to arrive at the equilibrium thermodynamics conditions in the compartment using temperature as the trial argument. The equilibrium thermodynamic state is considered determined when the trial temperature provides properties such that the ratio of the difference between the trial energy balance and the energy inventory is less than 0.001. The state properties of the steam and water mixture at the trial temperature are obtained from the saturation tables. The mass of steam is then determined by:

$$MS = \frac{(V) - (MW)_1(VL)}{VG}$$

where:

V	=	volume of compartment, ft <sup>3</sup>
VL	=	specific volume of water, ft <sup>3</sup> /lb



FNP-FSAR-3K

VG = specific volume of steam, ft<sup>3</sup>/lb

MW<sub>1</sub> = mass of water from previous iteration, lb

The mass of water (MW) is determined by:

$$MW = MV - MS$$

A trial energy balance is calculated:

$$ETRIAL = (MS)(UG) + (MW)(UL) + 0.171(MA)(TP)$$

The procedure is repeated varying the value of TP until the relation:

$$\frac{UT - ETRIAL}{UT} \leq 0.001$$

is satisfied.

If, after establishing the thermodynamic equilibrium conditions,  $MW \leq 0$ , the compartment is considered to be superheated. The equilibrium conditions are recalculated by setting the steam mass equal to the vapor mass and calculating the steam pressure at the search temperature by:

$$PS = 0.5961(MS) \frac{T}{V}$$

PS = pressure of steam, psia

T = compartment search temperature, °R

V = compartment volume, ft<sup>3</sup>

$$0.5961 = \frac{R}{\text{Mole Weight}} (144) = \frac{1545.3}{18} (144)$$

The internal energy of the steam at the pressure and temperature is obtained from the superheat tables and a trial energy balance calculated by:

$$ETRIAL = (MS)(UG) + 0.171(MA)(TP)$$

The procedure is repeated varying the value of TP until the relation:

$$\frac{UT - ETRIAL}{UT} \leq 0.001$$

is satisfied.

## FNP-FSAR-3K

where:

UL = internal energy of water at the compartment temperature, Btu/lbm

UG = internal energy of steam, Btu/lbm

The total pressure in the compartment is the sum of the steam pressure and the air pressure with the latter being calculated by:

$$PA = 0.37MA \frac{TP + 459.688}{V}$$

where:

$$0.37 = \frac{R}{\text{Mole Weight}} (144) = \frac{1545.3}{28.97} (144)$$

### 3K.D.5 FLOW CALCULATION

Two-flow equations are provided for calculating the flow between compartments. The Moody Equation is used for the analysis of reactor cavity pressures resulting from the decompression of the primary coolant system and for other compartments where the blowdown results in single component two-phase flow fairly early in the transient. A compressible fluid flow equation is used for the analysis of steam generator compartment pressures for the main steam line breaks and for other compartments where the blowdown results in two component two-phase flow for all of the transient or that portion of the transient through the maximum peak pressure.

In the application of the Moody Equation for calculating the flow from compartment 1 to component 2, the flow is assumed to be critical if the pressure in compartment 2 is less than 0.55 times the pressure in compartment 1. If the flow is critical, the throat pressure is set equal to 0.55 times compartment 1 pressure.

For subcritical flow the form of the Moody equation is:

$$G = \left[ \frac{2 \times G_c \times J(HO_1 - H_2)}{\left[ \frac{X_2 \times VG_2}{K} + (1 - X_2 \times VF_2) \right]^2 (X_2 \times K^2 + 1 - X_2)} \right]^{\frac{1}{2}}$$

1 - Corresponds to upstream compartment

2 - Corresponds to downstream compartment

## FNP-FSAR-3K

All the terms of the formula are evaluated using the following equations:

$$HO1 = \frac{HV1}{MV1}$$

$$H2 = HF2 + X2 \times HFG2$$

$$X2 = \frac{SO2 - SF2}{SG2 - SF2}$$

$$SO2 = SO1 \text{ (Since Moody's Model assumes isentropic flow)}$$

$$SO1 = SF1 + X1 \times SFG1$$

$$X1 = \frac{H01 - HF1}{HG1 - HF1}$$

$$K = \left( \frac{VG2}{VL2} \right)^{\frac{1}{3}} \times 1.224 \frac{P1 - P2}{P2}$$

where:

- HO1 = stagnation enthalpy of the fluid in compartment 1, Btu/lb
- HV1 = internal energy of the vapor in compartment 1, Btu
- MV1 = mass of vapor in compartment 1, lb
- SO1 = specific stagnation entropy of fluid in compartment 1, Btu/lb - °R
- SF1 = specific entropy of water in compartment 1, Btu/lb - °R
- SG1 = specific entropy of steam in compartment 1, Btu/lb - °R
- HF1 = specific enthalpy of water in compartment 1, Btu/lb
- HG1 = specific enthalpy of steam in compartment 1, Btu/lb
- SFG1 = specific entropy of vaporization in compartment 1, Btu/lb - °R
- P1 = total pressure in compartment 1, psia
- X1 = quality (vapor mass flow fraction) in compartment 1
- H2 = specific enthalpy of fluid in compartment 2, Btu/lb

FNP-FSAR-3K

HF2	=	specific enthalpy of water in compartment 2, Btu/lb
HFG2	=	specific enthalpy of vaporization in compartment 2, Btu/lb
SO2	=	specific stagnation entropy of compartment 2, Btu/lb - °R
SF2	=	specific entropy of water in compartment 2, Btu/lb - °R
SG2	=	specific entropy of steam in compartment 2, Btu/lb - °R
VG2	=	specific volume of steam in compartment 2, ft <sup>3</sup> /lb
VL2	=	specific volume of water in compartment 2, ft <sup>3</sup> /lb
P2	=	total pressure in compartment 2, psia
K	=	slip ratio dimensionless

The state properties for compartments 1 and 2 are obtained from the saturation tables at the pressures in the compartment.

For critical flow the form of the Moody Equation is:

$$G = \frac{[2 \times G_c \times J(H_{01} - H_T)]^{\frac{1}{2}}}{\left[ (1 - X_T \times V_{FT}^{\frac{2}{3}} + X_T \times V_{GT}^{\frac{2}{3}})^{\frac{3}{2}} \right]}$$

All the terms of the formula are evaluated using the following equations:

HO1	=	UV1/MV1
HT	=	HFT + XT × HFGT
XT	=	$\frac{SOT - SFT}{SGT - SFT}$
SOT	=	SO1 since isentropic
SO1	=	SF1 + X1 × SFG1
X1	=	$\frac{HO1 - HF1}{HG1 - HF1}$

## FNP-FSAR-3K

where:

XT	=	quality at the throat
HT	=	specific enthalpy of the fluid at the throat
HFT	=	specific enthalpy of the water at the throat
HFGT	=	specific enthalpy of the vaporization at the throat
SOT	=	specific stagnation entropy of the fluid at the throat
SGT	=	specific entropy of the steam at the throat
SFT	=	specific entropy of the water at the throat

The other variables were defined previously. The state properties for compartment 1 and the throat are obtained from the saturation tables at the respective pressures in the compartment and throat.

The throat pressure is calculated as follows:

$$P_T = P_1 \times 0.55$$

With Moody flow for both the subcritical and critical flow conditions, the calculated value of the flow is decreased to sixty percent of the flow (Moody Multiplier = 0.6).

In the application of the compressible fluid equation, if the ratio of the pressure in compartment 2 to the pressure in compartment 1 is less than RC as obtained by:

$$RC = \left[ \frac{2}{1+K} \right]^{\frac{K}{K-1}}$$

the flow is considered to be critical.

The form of the flow equation is:

$$G = \left[ G_c \times K \times P_1 \times RH_{01} \times \left[ \frac{2}{K+1} \right]^{\frac{K+1}{K-1}} \right]^{\frac{1}{2}}$$

The isentropic exponent K for the air, steam, and water mixture is calculated by:

$$K = K_{GF} \times \frac{P_{S1}}{P_1} + K_A \times \frac{P_{A1}}{P_1}$$

## FNP-FSAR-3K

where:

- KA = isentropic value of K for air (= 1.4)
- KGF = isentropic value of K for steam-water mixture
- RHO1 = specific density of the mixture in compartment 1, lb/ft<sup>3</sup>
- P1 = total pressure of compartment 1, psia
- PS1 = pressure of steam in compartment 1
- PA1 = pressure of air in compartment 1

RH01 is calculated using the equation:

$$RH01 = MT1/VOL1$$

where:

- MT1 = total mass of fluid in compartment 1, lb
- VOL1 = volume of compartment 1

If the flow is subcritical, the form of the flow equation is:

$$G = \left[ 2 \times G_c \times P1 \times RH01 \times \frac{K}{K-1} \left( R^{\frac{2}{K}} - R^{\frac{K+1}{K}} \right) \right]^{\frac{1}{2}}$$

where the terms are as previously defined and  $R = \frac{P_2}{P_1}$

The mass flow for both the compressible fluid flow equation and the Moody equation is calculated by:

$$\text{total MF} = G \times A \times C$$

$$\text{air MAF} = MF \frac{MA1}{MT1}$$

$$\text{water MWF} = MF \frac{MW1}{MT1}$$

$$\text{steam MSF} = MF \frac{MS1}{MT1}$$

## FNP-FSAR-3K

The energy transferred by the flow is:

$$\text{air } UAF = MAF \times CP \times T1$$

$$\text{water } UWF = MWF \times HL$$

$$\text{steam } USF = MSF \times HG$$

where:

$$A = \text{area of flow path, ft}^2$$

$$G = \text{mass flow, lb/ft}^2\text{-s}$$

$$C = \text{flow coefficient calculated external to code}$$

$$CP = \text{specific heat of air at constant pressure}$$

$$HL = \text{enthalpy of water at compartment temperature}$$

$$HG = \text{enthalpy of steam at compartment temperature}$$

MA1, MW1, MS1, and MT1 are the same as the one previously defined.

The flow coefficient "C" was calculated using the same method as outlined in the COPRA computer program which has been previously submitted for NRC review in NS-731-TN, "Containment Pressure Analysis," Power and Industrial Division, Bechtel Corporation, San Francisco, California, December 1968.

FNP-FSAR-3K

**ATTACHMENT E**

**CALCULATION METHODS FOR COMPARTMENT PRESSURIZATION**



### **3K.E.1 PRESSURE AND TEMPERATURE ANALYSIS**

The results presented below have been superseded with regard to the pressure and temperature transient for the main steam line break in the main steam valve room. The details and results of the new analysis are presented in appendix 3J. The discussion below is retained for completeness.

#### **3K.E.1.1 Compartment Model**

The worst break within the main steam room was determined by analysis. The main steam room is modeled as one large room. Venting to the atmosphere from the main steam room is possible through either the pipe chase or the penthouse.

The worst break within the pipe chase was determined by analysis. Venting to the atmosphere is either directly from this chase or through the main steam room.

#### **3K.E.1.2 Flow Model**

Flow coefficients for expansions and contractions were calculated by the methods outlined in reference 1. When flow was through highly restricted vents, such as through grating, a conservative flow coefficient was applied. A flow model for the main steam room is given in figure 3K.E-3. A flow model for the pipe chase is given in figures 3K.E-6 and 3K.E-6A.

#### **3K.E.1.3 Results**

A double-ended guillotine break in the 36-in. O.D. line in the main steam room results in the most severe localized pressure response. The pressure reaches a peak of 20.5 psig at 0.123 s. As the transient continues, heat absorption by the walls, which is conservatively neglected, in addition to the decrease of the blowdown, will cause the pressure and temperature to decrease. The temperature and pressure responses for a break in the main steam room are plotted in figures 3K.E-1, 3K.E-1A, 3K.E-2, and 3K.E-2A. The maximum pressure in the pipe chase is 28.8 psig. The pressure and temperature are plotted in figures 3K.E-4 and 3K.E-5.

The penthouse, which was added to provide both additional volume and venting to the atmosphere, was optimized by varying both its volume and vent area until construction and pressurization limitations were satisfied. The final design provides adequate venting so that overpressurization does not occur for any break in the main steam room.

A pressure-temperature response in the turbine-driven auxiliary feedwater pump room, resulting from the severance of a 4-in. auxiliary turbine pump steam line, is also analyzed. At the low flowrate through the 4-in. O.D. line, the valve closure time, approximately 10 seconds, is short compared to the time to reach 4-percent quality flow -- approximately 60 seconds. The pressure response curve for this room is shown in figure 3K.E-8.

## FNP-FSAR-3K

In addition to pressure and temperature response curves for the main steam system, additional curves and flow models for the following compartments containing high energy lines have been calculated using the computer model described in attachment D:

- A. Turbine-driven auxiliary feedwater pump room.
- B. CVCS letdown heat exchanger room (upper and lower levels).
- C. Piping tunnel from the letdown line penetration room, elevation 100 to the CVCS heat exchanger room.
- D. Letdown line penetration room elevation 100.
- E. Recycle holdup tank compartments (3).
- F. BTRS alternate letdown line valve compartment elevation 121.

## FNP-FSAR-3K

### REFERENCES

1. "Containment Pressure Analysis," NS-731-TN, Bechtel Corporation, Power and Industrial Division, San Francisco, California, December 1968.
2. "Subcompartment Pressure and Temperature Transient Analysis," BN-TOP-4, Rev. 1, Bechtel Power Corporation, October 1977.

FNP-FSAR-3K

**TABLE 3K.E-1**

**BLOWDOWN-AUXILIARY STEAM LINE**

<u>time</u> <u>(s)</u>	<u>m</u> <u>(lb/s)</u>	<u>h</u> <u>(Btu/lb)</u>
0.0	274.9	1191.4
0.156	274.9	1191.4
0.156	91.56	1191.4
10.0	91.56	1191.4

FNP-FSAR-3K

TABLE 3K.E-2

CVCS LETDOWN LINE RUPTURE:  
BLOWDOWN-PENETRATION ROOM (el 100 ft)

time (s)	m (lb/s)	h (Btu/lb)
0.0000	876.00	353.74
0.0201	520.89	353.69
0.0436	389.88	353.60
1.0670	389.88	353.60
1.0670	272.04	353.60
3.2581	272.04	353.60
8.2581	194.94	353.60
8.7609	194.94	353.60
8.7609	0.00	353.60
1.0E+6	0.00	353.60

FNP-FSAR-3K

TABLE 3K.E-3

UNIT 1: CVCS LETDOWN LINE RUPTURE:  
BLOWDOWN-LETDOWN HEAT EXCHANGER ROOM

<u>time</u> <u>(s)</u>	<u>m</u> <u>(lb/s)</u>	<u>h</u> <u>(Btu/lb)</u>
0.00000	632.94	353.7
0.09006	389.88	353.6
2.01000	389.88	353.6
2.01000	194.94	353.6
4.46420	194.94	353.6
9.32370	194.94	353.6
9.32370	45.93	353.6
12.3026	0.00	353.6
1.0E+06	0.00	353.6

FNP-FSAR-3K

TABLE 3K.E-4

UNIT 2: CVCS LETDOWN LINE RUPTURE:  
BLOWDOWN-LETDOWN HEAT EXCHANGER ROOM

time (s)	m (lb/s)	h (Btu/lb)
0.00000	632.94	353.7
0.09006	389.88	353.6
2.01000	389.88	353.6
2.01000	194.94	353.6
8.33410	194.94	353.6
8.33410	0.00	353.6
1.0E+06	0.00	353.6

FNP-FSAR-3K

**TABLE 3K.E-5**

**CVCS LETDOWN LINE RUPTURE:  
BLOWDOWN-SEAL WATER HEAT EXCHANGER ROOM**

<u>time</u> <u>(s)</u>	<u>m</u> <u>(lb/s)</u>	<u>h</u> <u>(Btu/lb)</u>
0.0000	876.00	353.74
0.0263	654.10	353.72
0.0637	419.60	353.64
0.0758	389.90	353.60
1.5593	389.90	353.60
1.5593	272.00	353.60
8.2279	272.00	353.60
8.2279	0.00	353.60
1.0E6	0.00	353.60



FNP-FSAR-3K

TABLE 3K.E-6

CVCS LETDOWN LINE RUPTURE:  
BLOWDOWN-PIPE TUNNEL

time (s)	m (lb/s)	h (Btu/lb)
0.0000	9.82	353.74
3.9	9.82	353.74
5.5171	4.37	353.60
445.5171	4.37	353.60
445.5171	0.00	353.60
1.00E+06	0.00	353.60

TABLE 3K.E-7

**CVCS LETDOWN LINE RUPTURE:  
PEAK TEMPERATURES AND PRESSURES**

<u>Room</u>	Temperature (°F)	Pressure (psig)
el 100-ft penetration room	171	2.7
Letdown heat exchanger room	216	2.5
Seal water heat exchanger room	219	2.6
Piping tunnel	216	2.5
el 100-ft rooms 162, 155	175	
el 100-ft rooms 160, 161, 163	142	
el 121-ft hallway areas	Bound by the BTRS line break	
el 139-ft hallway areas	Bound by the BTRS line break	
el 155-ft hallway areas	Bound by the BTRS line break	

FNP-FSAR-3K

TABLE 3K.E-8

**BTRS ALTERNATE LETDOWN LINE RUPTURE:  
BLOWDOWN-HOLDUP TANK ROOM (NO. 156)**

time (s)	m (lb/s)	h (Btu/lb)
0.0000	820.8	357.7
0.0843	472.1	357.7
0.1654	358.8	357.7
0.1654	358.8	353.6
1.5704	358.8	353.6
1.5704	265.5	353.6
6.6102	265.5	353.6
6.6102	71.0	353.6
7.30	0.0	353.6
1.0E+06	0.0	353.6

FNP-FSAR-3K

TABLE 3K.E-9

**BTRS ALTERNATE LETDOWN LINE RUPTURE:  
BLOWDOWN-HOLDUP TANK ROOM (NO. 157)**

time (s)	m (lb/s)	h (Btu/lb)
0.0000	820.8	357.7
0.0952	453.6	357.7
0.1614	358.8	357.7
0.1614	358.8	353.6
1.3773	358.8	353.6
1.3773	265.5	353.6
6.6529	265.5	353.6
6.6529	71.0	353.6
7.45	0.0	353.6
1.0E+06	0.0	353.6

**TABLE 3K.E-10**

**BTRS ALTERNATE LETDOWN LINE RUPTURE: BLOWDOWN  
UNIT 1 HEAT EXCHANGER ROOM/VALVE COMPARTMENT**

time (s)	m (lb/s)	h (Btu/lb)
0.0000	820.8	357.7
0.1079	412.6	357.7
0.1407	358.8	357.7
0.1407	358.8	353.6
0.7108	358.8	353.6
0.7108	265.5	353.6
6.8906	265.5	353.6
6.8906	71.0	353.6
17.75	71.0	353.6
22.75	71.0	353.6
1.0E+06	0.0	353.6

FNP-FSAR-3K

TABLE 3K.E-11

**BTRS ALTERNATE LETDOWN LINE RUPTURE: BLOWDOWN  
UNIT 2 HEAT EXCHANGER ROOM/VALVE COMPARTMENT**

<u>time</u> <u>(s)</u>	<u>m</u> <u>(lb/s)</u>	<u>h</u> <u>(Btu/lb)</u>
0.0000	820.8	357.7
0.1079	412.6	357.7
0.1407	358.8	357.7
0.1407	358.8	353.6
0.7108	358.8	353.6
0.7108	265.5	353.6
6.8906	265.5	353.6
6.8906	71.0	353.6
8.4	0.0	353.6
1.0E+06	0.0	353.6

**TABLE 3K.E-12**

**BTRS ALTERNATE LETDOWN LINE CRITICAL CRACK: BLOWDOWN  
UNIT 1 HEAT EXCHANGER ROOM/VALVE COMPARTMENT**


time (s)	m (lb/s)	h (Btu/lb)
0.00000	9.20	357.7
200.00	9.20	357.7
208.64	4.02	357.7
208.64	4.02	353.6
673.16	4.02	353.6
673.16	0.00	353.6
1.0E+06	0.00	353.6

TABLE 3K.E-13

**BTRS ALTERNATE LETDOWN LINE RUPTURE  
PEAK TEMPERATURES AND PRESSURES**

<u>Room</u>	<u>Temperature (°F)</u>	<u>Pressure (psig)</u>
Recycle holdup tank room (No. 156)	208	2.3
Recycle holdup tank room (No. 157)	207	2.3
Reheat heat exchanger/valve room	211	2.0
el 121-ft room 207 (hatch area)	170	
el 121-ft other hallway areas (rooms 205, 208, 209, 218, 222, and 237)	139	
el 100-ft hallway area	Bound by the CVCS line break	
el 139-ft hallway areas	123	
el 155-ft hallway areas	107	






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

DIFFERENTIAL PRESSURE ACROSS STEAM ROOM AND  
PIPE CHASE WALL

FIGURE 3K.E-1




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TEMPERATURE IN MAIN STEAM ROOM  
RESULTING FROM A DOUBLE-ENDED MAIN  
STEAM BREAK IN MAIN STEAM ROOM

FIGURE 3K.E-1A




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PRESSURE IN MAIN STEAM ROOM RESULTING FROM A  
DOUBLE-ENDED BREAK IN MAIN STEAM ROOM

FIGURE 3K.E-2




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TEMPERATURE DISTRIBUTION IN PIPE CHASE

FIGURE 3K.E-2A



**COMPARTMENT**

- 1. BREAK COMP. (Main Steam Room)
- 2. PENTHOUSE
- 3. PIPE CHASE
- 4. ATMOSPHERE


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

MAIN STEAM ROOM FLOW MODEL

FIGURE 3K.E-3




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 PIPE CHASE PRESSURE  
(COMPARTMENTS 1, 4)

FIGURE 3K.E-4




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 PIPE CHASE TEMPERATURES  
(COMPARTMENT 1)

FIGURE 3K.E-5



Compartments Location Fig. E-6A

- |                                       |   |
|---------------------------------------|---|
| 1. Break compt.                       | 6. Top of pipe chase above compt. 1           |
| 2. Mid portion of pipe chase          | 7. Top of pipe chase above compt. 4           |
| 3. Lower portion of pipe chase        | 8. Lower portion of steam room (up to e1.141) |
| 4. Adjacent to break compt.           | 9. Above compt. 8                             |
| 5. Main steam room up to hanging wall | 10. Penthouse                                 |
|                                       | 11. Atmosphere                                |

REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIPE CHASE, MAIN STEAM ROOM FLOW MODEL

FIGURE 3K.E-6






REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 PIPE CHASE, MAIN STEAM ROOM FLOW MODEL

FIGURE 3K.E-6A (SHEET 1 OF 2)



REV 21 5/08




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TURBINE-DRIVEN AUXILIARY FEEDWATER PUMP ROOM

FIGURE 3K.E-7




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

TURBINE-DRIVEN AUXILIARY FEEDWATER PUMP ROOM

FIGURE 3K.E-7A



- 1. TURBINE-DRIVEN AUX FEEDWATER PUMP ROOM
- 2. CORRIDOR
- 3. EQUIPMENT ROOM
- 4. PHOSPHATE INJECTION ROOM
- 5. PLANT HEATING ROOM
- 6. ACCESS HATCH
- 7. ROOM ATOP COMPARTMENT NO. 1

\*SEE REFERENCE 2 FOR DESCRIPTION OF ORIFICE FLOW COEFFICIENT.

A = VENT AREA (ft²)  
 C = FLOW COEFFICIENT\*  
 V = VOLUME


REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

AUXILIARY TURBINE ROOM FLOW MODEL

FIGURE 3K.E-8




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

e1 100-ft PENETRATION ROOM PRESSURES  
(LETDOWN LINE BREAK IN e1 100-ft PENETRATION ROOM)

FIGURE 3K.E-9




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

e1 100-ft PENETRATION ROOM TEMPERATURES  
(LETDOWN LINE BREAK IN e1 100-ft PENETRATION ROOM)

FIGURE 3K.E-10



REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 LETDOWN HEAT EXCHANGER ROOM PRESSURES  
(LETDOWN LINE BREAK IN  
LETDOWN HEAT EXCHANGER ROOM)

FIGURE 3K.E-11






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 LETDOWN HEAT EXCHANGER ROOM  
TEMPERATURES (LETDOWN LINE BREAK IN  
LETDOWN HEAT EXCHANGER ROOM)

FIGURE 3K.E-12




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 2 LETDOWN HEAT EXCHANGER ROOM  
PRESSURES (LETDOWN LINE BREAK IN  
LETDOWN HEAT EXCHANGER ROOM)

FIGURE 3K.E-13




REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

UNIT 2 LETDOWN HEAT EXCHANGER ROOM  
 TEMPERATURES (LETDOWN LINE BREAK IN  
 LETDOWN HEAT EXCHANGER ROOM)

FIGURE 3K.E-14




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SEAL WATER HEAT EXCHANGER ROOM PRESSURES  
(LETDOWN LINE BREAK IN SEAL WATER  
HEAT EXCHANGER ROOM)

FIGURE 3K.E-15




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

SEAL WATER HEAT EXCHANGER ROOM TEMPERATURES  
(LETDOWN LINE BREAK IN SEAL WATER  
HEAT EXCHANGER ROOM)

FIGURE 3K.E-16




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIPING TUNNEL PRESSURES (LETDOWN LINE CRITICAL  
CRACK IN PIPING TUNNEL)

FIGURE 3K.E-17




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

PIPING TUNNEL TEMPERATURES (LETDOWN LINE  
CRITICAL CRACK IN PIPING TUNNEL)

FIGURE 3K.E-18




1. LETDOWN HEAT EXCHANGER ROOM
2. SEAL WATER HEAT EXCHANGER ROOM
3. PIPING TUNNEL
4. EL. 100' CORRIDORS

A - VENT AREA (ft<sup>2</sup>)  
 C - FLOW COEFFICIENT (See Reference 2)  
 ΔP - DIFFERENTIAL PRESSURE REQUIRED TO OPEN DOOR


REV 21 5/08





1. EL. 100' PENETRATION ROOM
2. EL. 121' PENETRATION ROOM
3. EL. 139' PENETRATION ROOM

REV 21 5/08



$C_{fwd}$  - Forward Flow Coefficient (See Reference 2)  
 $C_{crvs}$  - Reverse Flow Coefficient (See Reference 2)  
 $\Delta P$  - Differential Pressure required to open door

"From"	"To"	Flow Area (ft <sup>2</sup> )	$C_{fwd}$	$C_{crvs}$	Blowout Panel ( $\Delta P$ in psi)
1	2	11.6	0.8	0.8	0.0
2	3	2.26	0.8	0.8	0.0
1	4	20.5	0.8	0.8	2.5
4	5	130.3	0.8	0.8	0.0
4	6	228.0	0.8	0.8	0.0
6	7	76.0	0.8	0.8	0.0
5	8	44.6	0.82	0.83	0.0
5	8	289.6	0.87	0.95	0.088
8	9	46.5	0.7	0.7	0.0
8	11	240.	0.8	0.8	0.0
8	16	47.2	0.83	0.83	0.0
8	16	297.0	0.95	0.87	0.088
9	10	8.63	0.8	0.8	0.0
11	12	147.3	0.8	0.8	0.0
11	13	50.38	0.8	0.8	0.0
11	14	50.38	0.8	0.8	0.0
11	15	131.75	0.8	0.8	0.0
16	17	309.6	0.88	0.87	0.0
17	18	150.7	0.85	0.8	0.0


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CVCS LETDOWN LINE RUPTURE FLOW MODEL:  
UNIT 1 - LINE BREAK IN LETDOWN HEAT EXCHANGER ROOM

FIGURE 3K.E-20 (SHEET 1 OF 2)



$C_{fwd}$  = Forward Flow Coefficient (See Reference 2)  
 $C_{rvs}$  = Reverse Flow Coefficient (See Reference 2)  
 $\Delta P$  = Differential Pressure required to open door

"From"	"To"	Flow Area (ft <sup>2</sup> )	$C_{fwd}$	$C_{rvs}$	Blowout Panel ( $\Delta P$ in psi)
1	2	11.6	0.8	0.8	0.0
2	3	2.26	0.8	0.8	0.0
5	17	6.0	0.8	0.8	0.0
1	4	20.5	0.8	0.8	2.5
4	5	130.3	0.8	0.8	0.0
4	6	228.0	0.8	0.8	0.0
6	7	76.0	0.8	0.8	0.0
12	11	46.5	0.7	0.7	0.0
13	12	240.	0.8	0.8	0.0
11	10	8.63	0.8	0.8	0.0
13	16	147.3	0.8	0.8	0.0
17	13	50.38	0.8	0.8	0.0
13	14	50.38	0.8	0.8	0.0
13	15	131.75	0.8	0.8	0.0
9	8	31.03	0.8	0.8	0.0
10	9	35.53	0.8	0.8	0.0


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CVCS LETDOWN LINE RUPTURE FLOW MODEL:  
UNIT 2 - LINE BREAK IN LETDOWN HEAT EXCHANGER ROOM

FIGURE 3K.E-20 (SHEET 2 OF 2)




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

RECYCLE HOLDUP TANK ROOM (NO. 156) PRESSURES  
(BTRS ALTERNATE LETDOWN LINE BREAK IN  
THE TANK ROOM - NO. 156)

FIGURE 3K.E-21




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

RECYCLE HOLDUP TANK ROOM (NO. 156) TEMPERATURES  
(BTRS ALTERNATE LETDOWN LINE BREAK IN  
THE TANK ROOM - NO. 156)

FIGURE 3K.E-22




REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

RECYCLE HOLDUP TANK ROOM (NO. 157) PRESSURES  
 (BTRS ALTERNATE LETDOWN LINE BREAK IN  
 THE TANK ROOM - NO. 157)

FIGURE 3K.E-23




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

RECYCLE HOLDUP TANK ROOM (NO. 157) TEMPERATURES  
(BTRS ALTERNATE LETDOWN LINE BREAK IN  
THE TANK ROOM - NO. 157)

FIGURE 3K.E-24



REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 REHEAT HEAT EXCHANGER/VALVE ROOM  
PRESSURES (BTRS ALTERNATE LETDOWN LINE BREAK IN  
THE HX/VALVE ROOM IN UNIT 1)

FIGURE 3K.E-25






REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 REHEAT HEAT EXCHANGER/VALVE ROOM  
TEMPERATURES (BTRS ALTERNATE LETDOWN  
LINE BREAK IN THE HX/VALVE ROOM IN UNIT 1)

FIGURE 3K.E-26




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 2 REHEAT HEAT EXCHANGER/VALVE ROOM  
PRESSURES (BTRS ALTERNATE LETDOWN LINE  
BREAK IN THE HX/VALVE ROOM IN UNIT 2)

FIGURE 3K.E-27




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 2 REHEAT HEAT EXCHANGER/VALVE ROOM  
TEMPERATURES (BTRS ALTERNATE LETDOWN LINE  
BREAK IN THE HX/VALVE ROOM IN UNIT 2)

FIGURE 3K.E-28




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 REHEAT HEAT EXCHANGER/VALVE ROOM  
PRESSURES (BTRS ALTERNATE LETDOWN LINE CRITICAL  
CRACK IN THE HX/VALVE ROOM)

FIGURE 3K.E-29




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 1 REHEAT HEAT EXCHANGER/VALVE ROOM  
TEMPERATURES (BTRS ALTERNATE LETDOWN LINE CRITICAL  
CRACK IN THE HX/VALVE ROOM)

FIGURE 3K.E-30



- A - Vent Area (ft<sup>2</sup>)
- C<sub>fwd</sub> - Forward Flow Coefficient (See Reference 2)
- C<sub>rvs</sub> - Reverse Flow Coefficient (See Reference 2)
- ΔP - Differential Pressure required to open door

"From"	"To"	Flow Area (ft <sup>2</sup> )	C <sub>fwd</sub>	C <sub>rvs</sub>	Blowout Panel (ΔP in psi)
1	2	31.03	0.8	0.8	0.0
1	9	14.0	0.8	0.8	3.0
2	3	35.53	0.8	0.8	0.0
3	4	8.63	0.8	0.8	0.0
4	5	46.5	0.7	0.7	0.0
5	11	240.0	0.8	0.8	0.0
10	9	131.75	0.8	0.8	0.0
11	6	147.3	0.8	0.8	0.0
11	7	50.38	0.8	0.8	0.0
11	8	50.38	0.8	0.8	0.0
11	10	131.75	0.8	0.8	0.0


REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

UNIT 2 FLOW MODEL OF eI-121 HALLWAY AREA

FIGURE 3K.E-31



REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

LINE BREAK: FLOW MODEL OF UNIT 1 HALLWAYS IN  
el 100, 121, 139, AND 155

FIGURE 3K.E-32 (SHEET 1 OF 2)

- A - Vent Area (ft<sup>2</sup>)  
 C<sub>fwd</sub> - Forward Flow Coefficient (See Reference 2)  
 C<sub>rvs</sub> - Reverse Flow Coefficient (See Reference 2)  
 ΔP - Differential Pressure required to open door or hatch

<u>"From"</u>	<u>"To"</u>	<u>Flow Area</u> (ft <sup>2</sup> )	<u>C<sub>fwd</sub></u>	<u>C<sub>rvs</sub></u>	<u>Blowout Panel</u> (ΔP in psi)
1	2	31.03	0.80	0.8	0.0
2	3	35.53	0.80	0.8	0.0
3	4	8.63	0.80	0.8	0.0
4	5	46.5	0.7	0.70	0.0
5	11	240.0	0.8	0.80	0.0
5	12	44.6	0.83	0.82	0.0
5	14	47.2	0.83	0.83	0.0
5	14	297.0	0.95	0.87	0.088
10	9	131.75	0.8	0.80	0.0
11	6	147.3	0.8	0.80	0.0
11	7	50.38	0.8	0.80	0.0
11	8	50.38	0.8	0.80	0.0
11	10	131.75	0.8	0.80	0.0
12	13	141.9	1.0	0.86	0.0
14	16	133.0	0.8	0.80	0.0
14	19	309.6	0.88	0.87	0.0
16	15	95.8	0.83	1.00	0.0
16	17	52.9	0.56	0.72	0.0
16	18	88.2	0.63	0.70	0.0
19	20	261.0	0.8	0.80	0.0
19	22	168.5	0.72	0.62	0.0
20	21	150.7	0.85	0.80	0.0

REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

LINE BREAK: FLOW MODEL OF UNIT 1 HALLWAYS IN  
el 100, 121, 139, AND 155

FIGURE 3K.E-32 (SHEET 2 OF 2)





- A - Vent Area (ft<sup>2</sup>)
- C<sub>fwd</sub> - Forward Flow Coefficient (See Reference 2)
- C<sub>rvs</sub> - Reverse Flow Coefficient (See Reference 2)
- ΔP - Differential Pressure required to open door or hatch

"From"	"To"	Flow Area (ft <sup>2</sup> )	C <sub>fwd</sub>	C <sub>rvs</sub>	Blowout Panel (ΔP in psi)
1	2	8.63	0.80	0.8	0.0
2	3	46.5	0.7	0.70	0.0
3	4	240.0	0.8	0.80	0.0
3	6	44.6	0.83	0.82	0.0
3	7	47.2	0.83	0.83	0.0
3	7	297.0	0.95	0.87	0.088
4	5	131.75	0.8	0.80	0.0
7	8	309.6	0.88	0.87	0.0

REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

CRITICAL CRACK: FLOW MODEL OF UNIT 1 HALLWAYS IN  
el 100, 121, 139, AND 155

FIGURE 3K.E-33

FNP-FSAR-3K

**ATTACHMENT F**

**METHODS USED TO CALCULATE PIPE WHIP THRUST LOADS AND  
JET IMPINGEMENT FORCES**

**ATTACHMENT F****ANALYSIS OF PIPE RUPTURE THRUST AND JET FORCES****3K.F.1 GENERAL**

Methods for calculating pipe rupture thrust and jet impingement forces are given in this attachment. Single- and two-phase blowdowns are analyzed to evaluate the nature and magnitude of these forces which result in pipe whip and impingement loads on structures and preventive barriers.

**3K.F.2 JET THRUST FORCES**

In the event of a high energy pipe break, the fluid blowdown and the propagation of pressure disturbance produce jet loads that may result in pipe whip and jet impingement forces.

Immediately after the break, while the pressure disturbance propagation is settling down and the blowdown rate is building up, the resulting jet forces are a function of time, asymptotically acquiring steady-state value provided the system stagnation pressure  $P_o$  remains constant. Methods of calculating the steady-state values of these forces are given in the following:

**3K.F.2.1 Steady-State Thrust Calculation**

The generalized steady-state thrust equation as developed by Shapiro<sup>(1)</sup> is

$$F = \frac{\dot{m}V_e}{g_c} + (P_e - P_a)A_e \quad (1)$$

where:

$\dot{m}$	=	fluid mass flowrate (lb <sub>m</sub> /s)
$V_e$	=	fluid exit velocity (ft/s)
$g_c$	=	gravitational constant (32.2 lb <sub>m</sub> ft/lb <sub>f</sub> s <sup>2</sup> )
$P_e$	=	fluid exit pressure (psf)
$P_a$	=	ambient pressure (psf)
$A_e$	=	exit area (ft <sup>2</sup> )

## FNP-FSAR-3K

A convenient nondimensional thrust can be defined by dividing through by  $P_o$  and  $A_e$  obtaining

$$\frac{F}{P_o A_e} = \frac{G V_e}{g_c P_o} + \frac{P_e - P_a}{P_o} \quad (2)$$

One-dimensional continuity,  $\dot{m} = \rho VA$  and the definition  $G = \dot{m}/A$  can be used with equation (2) to obtain the alternate expressions

$$\frac{F}{P_o A_e} = \frac{G V_e}{g_c P_o} + \frac{P_e - P_a}{P_o} \quad (3)$$

and

$$\frac{F}{P_o A_e} = \frac{G^2}{\rho_e g_c P_o} + \frac{P_e - P_a}{P_o} \quad (4)$$

where  $\rho_e$  is exit mass density ( $\text{lb}_m/\text{ft}^3$ ).

Two blowdown situations are considered for rupture of steam and water lines. They are as follows:

1. Blowdown of steam from superheated or saturated conditions.
2. Blowdown of a steam-water mixture or subcooled water.

### **3K.F.2.2 Saturated Steam**

Thrust forces associated with the blowdown of saturated steam are obtained from figure 3K.F-1 (when  $fL/D$  effects are considered) or from figure 3K.F-2 (when effects of a flow restrictor only are considered).

As can be seen from figure 3K.F-2, thrust forces associated with the critical flow of two-phase mixtures through upstream restrictions are lower than those associated with the blowdown of saturated steam through the same restriction. Therefore, the thrust forces associated with the blowdown of saturated steam were used to evaluate the effects of a main steam line rupture.

**3K.F.2.3 Saturated Steam-Water Mixture or Subcooled Water**

Although fluid escaping from a rupture in a subcooled system involves a two-phase mixture, the subcooled forces only were conservatively used for the analysis applying the following Moody equation from reference 2.

$$\frac{F_t}{A_B} = (P_m - P_\infty) + \frac{(G_m)^2 V_m}{g_c} \quad (5)$$

where

$P_m$	=	Maximum pressure at the break
$G_m$	=	Maximum flowrate at the break
$V_m$	=	Specific volume ( $V_f$ ) at $P_m$
$P_\infty$	=	Atmospheric pressure
$A_B$	=	Break Area

$G_m$  and  $P_m$  were obtained from figures 3K.F-3 and 3K.F-4, respectively, using a stagnation enthalpy ( $h_f$ ) for the system temperatures and the system source pressure  $P_o$  given in table 3K.F-1. When the corresponding data points did not fall within the envelopes in figures 3K.F-3 and 3K.F-4, a point on the saturated liquid boundary at the system pressure was used to obtain  $P_m$  and  $G_m$ .

For conservatism, no  $f\left(\frac{L}{D}\right)$  effects were considered for subcooled forces.

**3K.F.3 FLUID JET IMPINGEMENT FORCES**

In the event of a pipe break, the fluid flowing through the pipe emerges out as a jet impinging at nearby structures or equipment. Various blowdown situations considered here are described in subsection 3K.F.2. On emerging from the breakpoint, the jet undergoes free rapid expansion to the ambient pressure at relatively short distance -- a few diameters of break area. For this asymptotic distance, momentum and shear interactions with jet environment can reasonably be neglected. As such, applying forward momentum conservation, the total jet force,  $F_j$ , is constant throughout its travel, and therefore, as assumed by Moody;<sup>(2)</sup>

$$F_j = F \quad (6)$$

where  $F$  is the total thrust force defined in subsection 3K.F.2. Methods of calculating  $F$  are also given there.

## FNP-FSAR-3K

For the purpose of this attachment, it is further assumed that  $F_j$  remains constant for all distances beyond the asymptotic area. This assumption is conservative. Therefore, the jet pressure at any location along the axis of the jet is given by:

$$P_j(x) = \frac{F_j}{A_j}(x) \quad (7)$$

where

$A_j(x)$  is the expanded jet area at location  $x$  along the jet axis.  
See figure 3K.F-5 for system geometry.

Moody<sup>(2)</sup> has developed a simple analytical model for estimating the asymptotic jet area for steam, saturated water, and steam/water blowdown situations. Evaluations of LOFT<sup>(5)</sup> experimental results tend to indicate that, for subcooled water and steam blowdown situations, the jet area expands uniformly at half angle of about 15 degrees, whereas steam/water blowdown expands much more rapidly because of large-scale water flashing. Results of Moody's analytical analysis agree, at least qualitatively, with LOFT results. In addition, Moody's analytical analysis predicts results of other experiments, as discussed in reference 2.

In this attachment, an empirical approach has been adopted combining Moody's analytical model with the uniform half angle approach, as shown in figure 3K.F-5. The half angle is conservatively assumed to be  $\phi = 10$  degrees.

According to this empirical model, the distance of jet travel is divided into three regions. Region 1 extends to the asymptotic area, at which point the jet expansion area is calculated according to Moody's method; in Region 2, jet area remains constant; then in Region 3, the jet expands at half angle  $\phi = 10$  degrees.

For subcooled water blowdown, this model assumes half angle approach,  $\phi = 10$  degrees, uniformly in all the three regions, since Moody's model is not truly applicable for this case.

To follow Moody, the extent of Region 1 is taken as

$$x_1 = 5D_e \quad (8)$$

and the jet area at location  $x_1$  is given by the equation:

$$\begin{aligned} A_j(x_1) &= \pi R_{j1}^2 \\ &= (A_e G)^2 \frac{V_1}{g_c F_j} \end{aligned} \quad (9)$$

where:

$D_e$  = Equivalent diameter of pipe break area

## FNP-FSAR-3K

- $A_e$  = Pipe break area  
 $R_{j1}$  = Radius of the expanded jet at location  $x_1$ .  $R_{j1}$  is constant in region 2.  
 $F_j$  =  $F$ , thrust force (equation 6)  
 $v_1$  = Specific volume.  $v_1$  is calculated as described in reference 2

For two-phase blowdown, mass flowrate  $G$  is taken from reference 3. Region 2 extends to the location  $x_2$  given by:

$$A_j(x_1) = A_j(x), x = x_2$$

where

$A_j(x)$  is the jet area in Region 3 and is calculated by any one of the following equations. (See figure 3K.F-6 for jet geometrical configurations):

1. Guillotine break:

$$A_j(x) = A_e \left(1 + \frac{2x}{D_e} \tan \phi\right)^2$$

where  $\phi = 10$  degrees is the half angle of jet expansion

2. Longitudinal (slot) break:

$$A_j(x) = A_e \left(1 + \frac{2x}{\ell} \tan \phi\right) \left(1 + \frac{2x}{w} \tan \phi\right)$$

where  $\ell = 2D_e$  and  $w = \frac{\pi}{8} D_e$

and  $\ell$  and  $w$  are slot length and width, respectively

3. Circumferential crack:

$$A_j(x) = A_e \left(1 + \frac{2x}{w} \tan \phi\right) \left(1 + \frac{x}{\ell} (1 + 2 \tan \phi)\right)$$

where  $\ell = \frac{1}{2} D_e$  and  $w = \frac{1}{2}$  wall thickness

and  $\ell$  and  $w$  are slot length and width, respectively

## FNP-FSAR-3K

In Region 1, the additional conservative assumption is made that the jet area increases uniformly from  $A_j$  at  $x = 0$ , to  $A_j(x_1)$  at  $x = x_1$ , or

$$A_j(x) = A_e \left[ 1 + \frac{x}{x_1} \left[ \left( \frac{R_{j1}}{R_e} - 1 \right) \right] \right]^2, \text{ for } 0 \leq x \leq x_1$$

where  $R_e = \frac{D_e}{2} = \sqrt{\frac{A_e}{\pi}}$ , and  $R_{j1}$  is given by equation 9.

### 3K.F.3.1 Impingement Loads on Targets

Once the jet area  $A_j$  is calculated by the method described above, the jet pressure is readily calculated according to equation 7, i.e.,

$$P_j = \frac{F_j}{A_j}$$

and the jet impingement load on the target is given by

$$F_T = P_j A_{te}$$

where  $A_{te}$  is the effective target area. Calculation of  $A_{te}$  for various geometries is outlined below:

#### 1. Flat Surface

If the target with physical area  $A_t$  cancels all the fluid momentum in the jet, then:

$$A_{te} = A_t$$

For the case where target is oriented at angle  $\theta$  with respect to the jet axis and there is no flow reversal:

$$A_{te} = A_t \sin \theta$$

#### 2. Pipe Surface

Let

$$D_p = \text{Diameter of pipe, and}$$



### FNP-FSAR-3K

$D_j$  = Diameter of jet impinging on pipe

$$= \sqrt{\frac{4 A_j}{\pi}}$$

then, for  $D_p > D_j$

$$A_{te} = C A_j$$

where C is pipe curvature factor and  $C = \frac{2}{\pi}$

For  $D_p < D_j$

$$A_{te} = C \cdot A_t$$

where  $A_t = D_p \cdot D_j$  (conservative approximation)

**REFERENCES**



1. Shapiro, A. H., The Dynamics and Thermodynamics of Compressible Fluid Flow, Ronald Press Co., New York, 1953.
2. Moody, F. J., "Prediction of Blowdown and Jet Thrust Forces," ASME Paper 69 HT-31, August 6, 1969.
3. Moody, F. J., "Maximum Two-Phase Vessel Blowdown from Pipes," APED-4827 (65APE4), General Electric Co., April 20, 1965.
4. Moody, F. J. "Maximum Flow Rate of a Single Component, Two-Phase Mixture," APED-4378, General Electric Co., October 25, 1963.
5. Dietz, K. A., Editor, Quarterly Technical Report, Engineering and Test Branch, October 1 through December 31, 1967, Phillips Petroleum Company, IDO-17242, May 1968.
6. Moody, F. J. "Fluid Reaction and Impingement Loads," presented at the Specialty Conference, Structural Design of Nuclear Plant Facilities at Chicago, Illinois, December 17-18, 1973. (Published in Volume 1 of the conference notes.)

FNP-FSAR-3K

**TABLE 3K.F-1**

**THRUST LOADS DUE TO A FULL AREA PIPE RUPTURE**

<u>System</u>	<u>Line Size</u>	<u>Temperature (°F)</u>	<u>Pressure (P<sub>o</sub>) (psig)</u>	<u>Thrust Force (lb<sub>f</sub>)</u>
Main steam	32 in.	547	1005	285,000
	36 in.	547	1005	278,100
Main feedwater	14 in.	442	1055	122,700
Auxiliary steam	3 in.	547	1005	7,300
	4 in.	547	1005	5,400
Auxiliary feedwater	4 in.	442	1055	10,500
	8 in.	442	1055	39,400
	10 in.	442	1055	62,000
CVCS and BTRS	3 in.	380	550	6,900
Steam generator blowdown	2 in.	547	1055	4,730




REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

FRICITION EFFECT ON STEADY  
BLOWDOWN FORCE (REF. 6)

FIGURE 3K.F-1



REV 21 5/08




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

MAXIMUM STEAM WATER FLOWRATE AND LOCAL  
STAGNATION PROPERTIES (REF. 4)

FIGURE 3K.F-3




REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2


LOCAL STATIC PRESSURE AND  
STAGNATION PROPERTIES AT MAXIMUM  
STEAM/WATER FLOWRATE (REF. 4)

FIGURE 3K.F-4




REV 21 5/08






**2. SLOT - LONGITUDINAL**



**3. CIRCUMFERENTIAL CRACK**



REV 21 5/08

FNP-FSAR-3K

**ATTACHMENT G**

**MAIN STEAM ROOM AND PIPE CHASE STRUCTURAL STRESS ANALYSIS**

### **3K.G.1 INTRODUCTION**

The purpose of this attachment is to describe the analysis performed on the main steam room of the Farley Nuclear Plant, Unit 1. Since the Unit 2 main steam room is a mirror image of the Unit 1 main steam room, the results and conclusions of these analyses are applicable to both units. A computer finite element analysis was undertaken for the walls and slab of the main steam room because of the relatively complex geometry of the room, the number of possible loading cases involved, and the numerous points of application of loads. A conventional analysis was performed on the portion of the containment wall adjacent to the main steam room. These analyses are described in more detail in subsection 3K.G.2 of this attachment. Subsection 3K.G.3 contains the summary of results and conclusions.

### **3K.G.2 DESCRIPTION OF ANALYSIS**

#### **3K.G.2.1 Finite Element Model**

The structure under investigation was modeled using a finite element method. The finite element mesh is shown in figures 3K.G.2-3 and 3K.G.2-4. The model includes the north and west wall of the main steam room, the slab at elevation 127 ft 0 in., including beams and the cable chase, and two partition walls in the main steam room between the three main steam lines. A total of 758 nodal points and 693 quadrilateral and triangular elements were utilized in this model. Forty-seven beam elements were also used to represent the two beams and the cable chase. The boundary conditions which were input to the program are shown on figures 3K.G.2-3 and 3K.G.2-4. These boundary conditions include partial or complete fixity against rotation, combined with partial or complete fixity against displacement.

#### **3K.G.2.2 Containment Wall Analysis**

The method of analysis of the portion of the containment wall adjacent to the main steam room is a method described by P. P. Bijlaard in a paper titled "Stresses from Radial Loads in Cylindrical Pressure Vessels."<sup>(1)</sup> The three worst combinations of pressure loads from a postulated pipe rupture in the main steam room were applied to the containment wall. The method described in the aforementioned paper was then used to determine the maximum forces and moments. A conventional working stress design method was then used to evaluate the stresses in the containment wall and, finally, the margin of safety percentage.

#### **3K.G.2.3 Input Loads**

- A. Dead Load (D) - The concrete deadweight of 150 lb/ft<sup>3</sup> was used for the walls and slab.

FNP-FSAR-3K

B. Live Load (L) - A uniformly distributed live load of 300 lb/ft<sup>2</sup> was applied to the entire floor slab at elevation 127 ft 0 in. Of this 300 lb/ft<sup>2</sup>, 200 lb/ft<sup>2</sup> was for miscellaneous live loads and 100 lb/ft<sup>2</sup> was for piping and conduit live loads.

C. Thermal Load (T<sub>a</sub>) - Operating thermal effect was incorporated according to the following data and table.

Initial concrete temperature = 70°F  
 Main steam room operating temperature = 120°F  
 Operating temperature in other auxiliary building area = 80°F

	<u>Inside (°F)</u>	<u>Outside(°F)</u>
Wall A	120	120
Wall B	120	80
Wall C	120	120
Wall D	120	120
Slab	120	80

The resulting thermal stresses from the subsequent higher temperature in the main steam room following a pipe break were not incorporated. This is because these stresses would not occur simultaneously with those from pressure and jet-impingement forces.

D. Thermal Pipe Reaction (R<sub>a</sub>) - Forces to the structures from pipe reactions under thermal conditions generated by a postulated break were not included for the same reason as item C above. At the normal operating condition the effect was examined and found to be negligible. Hence, the load (R<sub>a</sub>) was not incorporated in the load combinations of the finite element analysis.

## FNP-FSAR-3K

- E. Pressure ( $P_a$ ) - The calculated pressure values in each main steam room compartment following a pipe break were all multiplied by a factor,  $1.4 \times 1.2 = 1.68$ , to obtain the equivalent static pressure. The value of 1.4 is a safety factor for the pressurization calculation, and the value of 1.2 accounts for the dynamic load factor. In the actual load input, these equivalent static pressures were further multiplied by 1.25 or 1.50 to comply with the load combinations.
- F. Pipe Restraint Force ( $Y_r$ ) - The structural steel pipe restraints in the main steam room are framed together so that the load taken is shared by each of the concrete separating walls. Any load which is taken by one restraint is transferred to each of the walls. It was found that because of the interaction between restraints and the stiffness of the walls, the displacement and thus the stresses in each wall are negligible. Therefore, the finite element model which analyzes the walls and slab considers the restraint point as a point of support.
- G. Jet Force ( $Y_j$ ) - The jet forces were calculated in accordance with attachment F. These forces, as in the pressure case, were multiplied by a factor,  $1.2 \times 1.2 = 1.44$ , to account for the safety and dynamic load factors, prior to being applied to the finite element analysis.
- H. Missile Impact Load ( $y_m$ ) - Pipe restraints are spaced such that no pipe missile will be generated by, or during, a postulated break. Consequently, this load was not included in the load combinations.
- I. Seismic Force ( $F_{eqo}$ ,  $F_{eqs}$ ) -
1. Vertical components of the seismic force were superimposed on the dead load as follows:  
7 percent g for OBE (1/2 SSE)  $1.25 \times 7$  percent = 8.75 percent g for 1.25 OBE, and 9 percent g for SSE.

## FNP-FSAR-3K

2. Lateral components of the seismic force were applied to the walls as uniformly distributed lateral pressures. For walls A and B (figure 3K.G.2-4) which have supports on four sides and, thus, relatively high natural frequencies, the maximum wall accelerations were taken to be the same as the maximum floor accelerations as indicated below.

$$\begin{aligned} 1.25 \quad (\text{OBE}) \quad & \text{E-W } 0.131 \text{ g} \times 1.25 = 0.164 \text{ g} \\ & \text{N-S } 0.122 \text{ g} \times 1.25 = 0.153 \text{ g} \\ (\text{SSE}) \quad & \text{E-W } 0.157 \text{ g} \\ & \text{N-S } 0.157 \text{ g} \end{aligned}$$

For cantilever walls C and D (figure 3K.G.2-4) which have relatively low natural frequencies, maximum spectral accelerations were used as indicated below.

$$\begin{aligned} 1.25 \quad (\text{OBE}) \quad & \text{N-S } 1.25 \times 1.80 \text{ g} = 2.25 \text{ g} \\ (\text{SSE}) \quad & \text{N-S } 1.10 \text{ g} \end{aligned}$$

### **3K.G.2.4      Load Combinations**

As required by "Structural Design Criteria for Evaluating the Effects of High-Energy Pipe Breaks on Category I Structures Outside the Containment"-Document (B) of the NRC, the following load combinations were examined for each postulated break:

- 1)  $U = D + L + T_a + R_a + 1.5 P_a$
- 2)  $U = D + L + T_a + R_a + 1.25 P_a + 1.0(Y_r + Y_j + Y_m) + 1.25 Feq_0$
- 3)  $U = D + L + T_a + R_a + 1.0 P_a + 1.0(Y_r + Y_j + Y_m) + 1.0 Feq_s$

The values of the input loads  $D$ ,  $L$ ,  $T_a$ ,  $R_a$ ,  $P_a$ ,  $Y_r$ ,  $Y_j$ ,  $Y_m$ ,  $Feq_0$ , and  $Feq_s$  are described in paragraph 3K.G.2.3.

### **3K.G.2.5      Description Of Program**

The program used to analyze the main steam room is a general structural analysis program originally developed by Edward L. Wilson of the University of California and subsequently improved by Bechtel. This program is called SAP (1.8).<sup>(2)</sup>

The purpose of the computer program is to perform linear, elastic analyses of three-dimensional structural systems. The structural systems to be analyzed may be composed of combinations

## FNP-FSAR-3K

of a number of structural element types. The present version contains the following element types:

- A. Boundary.
- B. Truss.
- C. Beam.
- D. Curved beam.
- E. Plane strain.
- F. Membrane (plane stress).
- G. Simple plate.
- H. Shell.
- I. Thick shell.
- J. Brick.
- K. Axisymmetric ring.

Two elements were utilized in the analysis of the main steam room. These were the shell and beam elements.

Systems composed of large numbers of joints and elements may be analyzed. There is no limitation in the program on the number of joints, number of elements, number of load cases, or equation bandwidth. In addition to being able to solve very large structural systems, the program can also analyze smaller problems with an efficiency comparable to smaller special-purpose programs. The reason for this is the fact that storage requirements of the program are adjusted dynamically during execution to conform to the actual requirements of the particular problem being considered.

The thin shell element used in this analysis is either a triangular or quadrilateral element of arbitrary geometry formed from four compatible triangles. The bending properties of this quadrilateral element are completely described in a paper titled, "A Refined Quadrilateral Element For Analysis of Plate Bending."<sup>(3)</sup>

The element employs a partially restrained linear strain triangle to represent the membrane behavior. As shown in figure 3K.G.2-1, the central node is located at the average of the coordinates of the four corner nodes. The element has 17 interior degrees of freedom which are eliminated at the element level prior to assembling; therefore, the resulting quadrilateral element has 20 degrees of freedom, 5 per node, in the local element coordinate system.

## FNP-FSAR-3K

For flat plates, the stiffness associated with the rotation normal to the shell surface is not defined; therefore, the appropriate boundary condition must be enforced.

The beam element is a straight, prismatic beam member. Any force and/or moment at either or both ends of the beam may be released if necessary. The following loads can be directly applied to the element:

- A. Inertia loads.
- B. Thermal loads due to uniform temperature difference and temperature gradient.
- C. Fixed end forces and moments.
- D. Uniformly and linearly distributed loads along the span.
- E. Concentrated forces and moments on the span.

Displacements of each node, axial forces, shear forces, and torsional and bending moments at both ends of the beam are computed.

Each joint in the system may have from 0 to 6 degrees of freedom as required. The user must ensure that the degrees of freedom specified for a given joint are compatible with the element types which are adjacent to it. Optimum solution efficiency is obtained by minimizing the number of degrees of freedom of the system.

A right-handed orthogonal coordinate system, shown in figure 3K.G.2-2, is used to describe the geometry of the structure. All joint loads and displacements are defined with reference to this system. A local coordinate system is used for each element type.

Loads may be applied by means of both point loads acting at the joints and by element loading (e.g. gravity, temperature). Each element may have an unlimited number of loads. Any number of load cases may be analyzed with each load case consisting of an unlimited combination of element loads and nodal point loads.

There is no size limitation built into the program, so the size of the problem that can be solved depends only on the machine core capacity. All storage is allocated at the time of execution and may be adjusted either upward or downward during execution. Therefore, the actual storage used will conform not only to the size of the structure, but will also conform to the specific requirements of each phase of the analysis process.

For static analysis, the program is divided into five phases. A machine-dependent overlay system is used for each phase. These five are executed in the following sequences:

- A. Data Input - Joint coordinates and loads are read or generated. As element properties are read or generated, the element stiffness matrices are formed and placed on tape.



## FNP-FSAR-3K

- B. Formation of the global stiffness matrix is accomplished by reading the element stiffness tape and forming the joint equilibrium equations in blocks.
- C. Formation of load vectors is accomplished by processing the element loads and nodal loads for each loading case.
- D. Equilibrium equations are solved for joint displacements; all load conditions are treated at the same time.
- E. From the joint displacements, element stresses are calculated for all load conditions.

The capacity of the program is controlled by the number of joints (nodal points) of the structural system. All joint data are retained in high-speed storage during the formation of the element stiffness matrices. For each joint, three coordinates and six boundary condition codes are required; therefore, the minimum required storage for a given problem is nine times the number of joints in the system.

Immediately after the joint data are supplied to the program, a relationship between each joint degree of freedom and the corresponding equation number is established. Each of the six boundary condition codes for a given joint is replaced by the equation number for that degree of freedom. Restrained boundary conditions are identified by a zero equation number. Slave degrees of freedom (for beam elements) are identified by a negative joint number of the master node.

After the coordinates of the joints are supplied and the equation numbers of the degrees of freedom established, the stiffness and stress-displacement transformation matrices are calculated for each structural element in the system. Very little additional high-speed storage is required for this phase since these matrices can be formed and placed on tape storage as the element properties are read. In addition to the element matrices, the corresponding equation numbers are written on tape.

The total stiffness matrix is formed by making a pass through the element stiffness matrices and adding in the appropriate element stiffness coefficients. To minimize the effort in searching through all the element stiffnesses, the element stiffness matrices for several blocks are transferred to another storage unit; therefore, in the formation of the next several blocks, the time required to search for the contributions to these blocks is reduced significantly.

The equilibrium equations (the global stiffness matrix and load vectors) are stored and transferred in and out of storage in large blocks. The block size is determined automatically at the time of solution, thus utilizing storage in the most efficient manner for each particular problem.

The computer program is built around two optional large-capacity linear equation solvers, USOL and SESOL. The procedure used to solve the equations is not significantly different from the method developed by Gauss in 1827. The banded characteristics of the equations are recognized.

## FNP-FSAR-3K

Operations with zero coefficients are skipped. Data are transferred in and out of high-speed storage in large blocks; therefore, a small amount of time is lost in the transfer of data. In the SESOL routine, random access files are used to reduce further the equation solution data transfer time.

After the joint displacements are calculated, a pass is made through the element stress-displacement matrix tape, and the element forces and movements are calculated and printed.

The output for the main steam room analysis includes nodal point displacements and rotations, element membrane force components, and element bending moment components.

### **3K.G.3 SUMMARY OF RESULTS AND CONCLUSIONS**

Sample deflection curves, moment diagrams, and tables of results are shown in figures 3K.G.3-1 through 3K.G.3-5 and tables 3K.G.3-1 through 3K.G.3-7.

The results of this linear, elastic finite element analysis have shown that the walls and slab in the main steam room are sufficiently strong to resist various combination loads following a postulated pipe break in the main steam room, with at least an 18-percent margin of safety over and above the margin provided by the load increases and load factors used in the analysis.

This conclusion is based on an examination of the most critical section of the walls and slab governing the entire structural strength. Structural capacity is established when this section first reaches its elastic limit. Due to the great uncertainty involved in a pipe break incident, the additional strength gained from the structure which, after reaching this elastic limit, would then undergo a nonlinear process prior to its final collapse, is not taken into consideration in this evaluation of the structural capability.



A conventional linear elastic analysis of the portion of the containment wall adjacent to the main steam room indicated that this wall is strong enough to resist the most severe combination of pressure loads resulting from a postulated pipe break in the main steam room with a 64-percent margin of safety.

**REFERENCES**

1. Bijlaard, P. P., "Stresses From Radial Loads in Cylindrical Pressure Vessels," Welding Journal Research Supplement, 1954.
2. Structural Analysis Program, Pacific International Computing Corporation.
3. "A Refined Quadrilateral Element for Analysis of Plate Bending," Proceedings, (Second) Conference on Matrix Methods in Structural Mechanics, Wright-Patterson AFB, Ohio, 1968.

**NOTES ON VALUES IN TABLES**

1. The selected points for tabulation are indicated in figures 3K.G.3-1 through 3K.G.3-5. These locations are considered the possible critical areas when subjected to various combined loads during a pipe break incident, as described previously.
2. For concrete, tensile stress was not considered.
3. Except from the operating thermal condition, the membrane stresses were found negligible. Axial compressive forces ( $P_x$  &  $P_y$ ) indicated in the tables result from pipe restraint forces in some local areas and were combined with bending moments in stress calculation.
4. The resulting operating thermal stress was found to be compressive across the entire thickness of the walls and slab. To account for the uncertainty involved in the actual temperature distribution, only maximum thermal compressive stress was added to concrete, and no reduction was made for tensile reinforcing stress.
5. The allowable stress was taken as 85 percent of the specified compressive strength for concrete and 90 percent of the yield strength for reinforcing bars.




REV 21 5/08





JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

THIN SHELL ELEMENT

FIGURE 3K.G.2-1



REV 21 5/08



**KEY PLAN**  
 1: 25  
 NOTE: FOR MAIN STEAM ROOM WALL FINITE ELEMENT MODEL SEE DWG.

- NOTES:**
- BEAM ELEMENT.
  - ALL INTERIOR NODES FIXED AGAINST IN PLANE ROTATION (Z AXIS) U.N.O.
  - JOINT FREE WITH DISPLACEMENT FIXED IN Z DIRECTION.
  - JOINT FIXED WITH DISPLACEMENT PERMITTED IN DIRECTION INDICATED.
  - JOINT FIXED WITH ROTATION PERMITTED ABOUT X AXIS COLUMN LINE 4 ONLY AND ROTATION PERMITTED ABOUT Y AXIS AT ALL OTHER INDICATED JOINTS.





REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

MAIN STEAM ROOM SLAB FINITE ELEMENT MODEL

FIGURE 3K.G.2-3



- NOTES:**
- ALL INTERIOR JOINTS FIXED AGAINST IN PLANE ROTATION EXCEPT WALL 'C'.
  - JOINT COMPLETELY FIXED
  - FIXED ROTATION PERMITTED ABOUT Z AXIS, WALL 'A' & 'B' ONLY.
  - FIXED ROTATION PERMITTED ABOUT X AXIS, WALL 'D' ONLY.
  - ROTATION FIXED ABOUT AXIS INDICATED.
  - DISPLACEMENT FIXED IN DIRECTION INDICATED.

REV 21 5/08




JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2


MAIN STEAM ROOM WALLS FINITE ELEMENT MODEL

FIGURE 3K.G.2-4








REV 21 5/08



REV 21 5/08



**MOMENT SIGN CONVENTION**  
 POSITIVE MOMENTS CAUSE  
 COMPRESSION IN FAR SIDE  
 OF THE WALL

- NOTES**
1. PLANE SHOWN IS LOOKING NORTH.
  2. DIAGRAMS SHOWN ARE FOR THIS WALL UNDER PRESSURE LOAD RESULTED FROM GUILLOTINE BREAK #6
  3. ● SUPPORT NORMAL TO THE WALL.
  4. + SELECTED LOCATIONS FOR STRESS TABULATION - TABLE G-3-3




REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

SAMPLE DEFLECTION AND MOMENT DIAGRAMS WALL C


FIGURE 3K.G.3-3





**MOMENT SIGN CONVENTION**  
 POSITIVE MOMENTS CAUSE  
 COMPRESSION IN FAR SIDE  
 OF THE WALL.

- NOTES**
1. PLANE SHOWN IS LOOKING NORTH.
  2. DIAGRAMS SHOWN ARE FOR THIS WALL UNDER PRESSURE LOAD RESULTED FROM GUILLOTINE BREAK #6
  3. ● SUPPORT NORMAL TO THE WALL.
  4. + SELECTED LOCATION FOR STRESS TABULATION-TABLE G-3-4

REV 21 5/08



PLAN



**MOMENT SIGN CONVENTION**  
 POSITIVE MOMENTS CAUSE COMPRESSION  
 ON TOP OF THE SLAB

**NOTES**

- 1 DIAGRAMS SHOWN ARE FOR THE SLAB UNDER PRESSURE LOAD RESULTED FROM GULLOTINE BREAK #10
- 2 ⊕ SUPPORT NORMAL TO THE SLAB
- 3 + SELECTED LOCATION IN SLAB FOR STRESS TABULATION - TABLE G-3-5
- 4 ⊕B2 SELECTED LOCATION IN CONCRETE BEAMS FOR STRESS TABULATION - TABLE G-3-6
- 5 ⊕C7 SELECTED LOCATION IN CABLE CHASE WALLS FOR STRESS TABULATION - TABLE G-3-7

REV 21 5/08



JOSEPH M. FARLEY  
 NUCLEAR PLANT  
 UNIT 1 AND UNIT 2

SAMPLE DEFLECTION AND MOMENT DIAGRAMS SLAB

FIGURE 3K.G.3-5

**3L ASME SECTION III NUCLEAR CLASS AUXILIARY PIPING STRUCTURE ANALYSIS**

**TABLE OF CONTENTS**

	<u>Page</u>
3L.1.0 INTRODUCTION.....	3L-1
3L.2.0 NUCLEAR CLASS 1 .....	3L-1
3L.2.1 PIPING CONSIDERED .....	3L-1
3L.2.2 METHODS OF ANALYSIS .....	3L-2
3L.2.2.1 Class 1 Lines (Including Accumulator Lines).....	3L-2
3L.2.2.2 Safety Injection Lines (Except Accumulator Lines).....	3L-2
3L.2.3 BREAK POINTS AND WHIP RESTRAINT LOCATIONS.....	3L-6
3L.2.3.1 Class 1 Lines (Including Accumulator Lines).....	3L-6
3L.2.3.2 Safety Injection Lines (Except Accumulator Lines).....	3L-6
3L.3.0 NUCLEAR CLASS 2 .....	3L-6
3L.3.1 PIPING CONSIDERED .....	3L-6
3L.3.2 METHODS OF ANALYSIS .....	3L-7
3L.3.2.1 Piping System Analysis (ME 632).....	3L-7
3L.3.2.2 Linear Elastic Analysis of Piping Systems (ME 101) .....	3L-11
3L.3.2.3 Local Stresses in Cylindrical Shells due to External Loadings (ME 210) .....	3L-12
3L.3.3 BREAK POINTS AND WHIP RESTRAINT LOCATIONS.....	3L-12

**APPENDIX 3L**

**ASME SECTION III NUCLEAR CLASS AUXILIARY PIPING STRUCTURAL ANALYSIS**

**3L.1.0      INTRODUCTION**

This appendix was prepared in response to question MEB-2.3A, transmitted by a letter from K. Kniel (NRC) to A. Barton (APC) on June 14, 1974. The appendix presents a summary of the analysis for branch lines in the containment which are ASME Section III, Nuclear Class 1 and 2.

The Design Specification for ASME Nuclear Class 1 auxiliary piping requires that a stress analysis be performed according to the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1971 Edition (including applicable addenda).

**3L.2.0      NUCLEAR CLASS 1**

This section contains the structural evaluation of ASME III Nuclear Class 1 piping connected to the reactor coolant piping and inside the containment building and all fittings connecting the above piping under postulated loading conditions. These loads result from thermal expansion, pressure, weight, earthquake, design basis accident, and plant operational thermal and pressure transients. Criteria for postulated break locations are specified in subsection 3.6.2.3.

**3L.2.1      PIPING CONSIDERED**

The Class 1 piping considered in this appendix consists of the following lines:

<u>Size (in.)</u>	<u>Line</u>
14	Pressurizer surge line
12	Residual heat removal line, loop 1
12	Residual heat removal line, loop 3
12	SIS accumulator line, loop 1
12	SIS accumulator line, loop 2
12	SIS accumulator line, loop 3
3	CVCS normal charging line
3	CVCS alternate charging line
3	CVCS normal letdown line

In addition to the lines listed above, the safety injection lines (except accumulator lines) were also considered. The stress analysis results for these lines are given in the applicable Class 1 stress reports.

### **3L.2.2 METHODS OF ANALYSIS**

#### **3L.2.2.1 Class 1 Lines (Including Accumulator Lines)**

The analytical methods used in this analysis are described in subsection 5.2.1.10. They consist of the transfer matrix method and stiffness matrix formation for the static structural analysis, the response spectrum method for seismic dynamic analysis, and a structural analysis for the effect of a reactor coolant loop pipe break. The complexity of the piping systems requires the use of a computer to obtain the displacements, forces, and stresses in the piping and support members. The computer codes used for the Class 1 piping systems are capable of performing an elastic analysis of redundant piping systems subjected to thermal, static, and dynamic loads. A detailed description, the extent of application, and the verification and qualification of the WESTDYN 7 computer code can be found in topical report WCAP-8252, Documentation of Selected Westinghouse Structural Analysis Computer Codes (April 1974).

Emergency core cooling system (ECCS) branch lines are analyzed for the effects of postulated reactor coolant pipe breaks as a faulted condition. Emergency core cooling system lines attached to both the unbroken loops and to the unbroken legs of the broken loop were considered. By comparison of the magnitude of the reactor coolant loop (RCL) and reactor pressure vessel (RPV) LOCA displacements, it was determined that the effects of a crossover leg break would be the most severe condition for the safety injection system (SIS) accumulator lines. (The RPV inlet and outlet nozzle breaks impose less severe loading conditions on the accumulator lines; therefore, the crossover leg break is presented as the limiting case.) A dynamic analysis was performed on a linear, elastic basis by applying the time-history displacement output of the RCL analysis to the ECCS lines using program FIXFM. The resultant stresses were combined with other faulted condition stresses to satisfy the ASME code equation 9 faulted stress intensity limit of  $3.0 S_m$ .

#### **3L.2.2.2 Safety Injection Lines (Except Accumulator Lines)**

The following are descriptions of the computer programs used in stress analysis of the safety injection lines (except accumulator lines). In addition to the following, ME632, described in subsection 3L.3.2.1, was also used.

##### **3L.2.2.2.1 Thermal Stress Program (ME 662)**

###### **Purpose**

To determine the temperature and stress distributions within a body as a function of time when subjected to thermal and/or mechanical loads. The program is valid for axisymmetric or plane structures.



### **Method of Analysis**

The program consists of two parts, each of which can be used separately. The first part calculates steady-state or transient temperature distributions due to temperature or heat flux inputs. The method used is the finite element technique coupled with a step-by-step time integration procedure. The program adopts a stepwise description of environmental temperatures and heat transfer coefficients if they are time dependent. Transient temperature distributions are calculated from the specified initial temperatures and the step function heat inputs.

The second part of the program is built on the displacement method of the matrix theory of structures, which calculates the displacements and stresses within the solids with orthotropic, temperature-dependent nonlinear material properties.

The user has the option of saving the results from part 1 on an external tape. After reviewing the printout, he can specify the transient states for the stress evaluations. Part 2 then picks up the necessary information from the tape and performs the calculations.

### **References**

1. Wilson, E. and Nickell, S. R. "Application of the Finite Element Method to Heat Conduction Analysis," Nuclear Engineering and Design, Vol. 4, 1966.
2. Wilson, E., "Structural Analysis of Axisymmetric Solids," AIAA Journal, Vol. 3, No. 12, December 1965.

### **Program Verification**

The program has been verified by comparing its output with the "ASME Program Verification and Qualification Problem Library," standard thermal problem. The results were acceptable.

#### **3L.2.2.2.2 LOTEMP Program (ME-913)**

##### **Purpose**

This program is used to calculate piping stresses in accordance with the simplified method of NB-3650 of the ASME Section III Code.

##### **Method of Analysis**

In order to calculate the stresses and usage factors according to the rules of NB-3650, the program requires the following input data:

- A. Moments due to thermal expansion, deadweight seismic, and seismic movement.
- B. Thermal gradient data  $\Delta t_1$ ,  $\Delta T_2$ ,  $T_a$  and  $T_b$ .

## FNP-FSAR-3L

- C. Material properties, cross-section, pressures, weld information, and component type at each data point of the pipe.
- D. Allowable stresses and number of cycles.

The stresses are calculated in accordance with equations 9 through 14 defined in Section NB-3650 of the ASME Code. The stresses and the usage factor are printed out for each data point in the analysis.

### **References**

1. ASME Sec. III Boiler and Pressure Vessel Code, 1971 Edition.
2. ASME Sample Program for Analysis of Class 1 Piping.

### **Program Verification**

LOTEMP has been verified by comparing its output with the "ASME Sample Problem," using the identical input information. The LOTEMP results were identical to the results derived in the sample program.

### **3L.2.2.2.3 Pipe Thermal Transient Program "DELTA T" (ME 912)**

#### **Purpose**

To calculate temperature gradient across the pipe wall and along the axis of the pipe, per ASME Section III code.

#### **Method of Analysis**

ME 912 is developed to calculate the reduced thermal transients along the axial direction of piping. It also calculates the thermal transient radially across the pipe wall at various locations. It allows nonuniform initial temperature distribution and time-dependent temperature inputs.

ME 912 prepares all the thermal input,  $\Delta T_1$ ,  $\Delta T_2$ ,  $(T_a - T_b)$ , etc. for program ME 913, Nuclear Class 1 piping stress analysis, per ASME Section III code.

#### **Program Verification**

The temperature gradient for various pipe sizes and for various temperatures has been calculated manually and verified with the results from ME 912. Also, the results from ME 912 have been compared with many commercially available programs. The results were very close.

#### **3L.2.2.2.4 Local Stress Analysis at Lug Supports on Piping Systems (ME 916)**

##### **Purpose**

To calculate stress intensities and fatigue analysis at the junction of the integral attachment of lugs and stanchions to the pipe, per ASME Section III, NB-3600 criteria.

##### **Method of Analysis**

In ME 916 input data needed are lug and pipe size, stress indices, material properties, loading conditions, and input loadings for pipe and lugs. For fatigue analysis, properties of cyclic loads or load pair set also are defined. The output from this program provides allowable stress equations, per MB-3600 and a cumulative usage factor.

##### **Verification**

ME 916 has been verified by a set of hand calculations of stresses as shown in NB-3600, Class I analyses. All stress and usage factors agree with hand calculations and with the results from many standard commercial programs.

#### **3L.2.2.2.5 ANSYS Program (Rev. 2)**

##### **Purpose**

This program is used to calculate stress displacement and load history as a function of time, caused by transient displacement in the reactor coolant loops during a loss-of-coolant accident and during major breaks in the loops.

##### **Method of Analysis**

A time-history displacement profile at the various nozzle connections for each of the postulated reactor coolant loop break cases was obtained from Westinghouse on computer tapes. Piping were modeled as finite element elastic stick and elastic plates. Transient displacements were applied at the nozzle connections, and reduced linear transient dynamic analysis was performed.

The results were extracted in three different steps, as follows:

- A. Displacement Pass: Displacement time-history at each node of the geometry was obtained.
- B. Stress Pass: Stresses, forces, and moments were obtained at each nodal point.
- C. Max Pass: Maximum and minimum values of displacement, stress, forces, and moments, independent of time, were obtained in this pass.

### **Verification**

The ANSYS program has been developed and verified by Swanson Analysis Systems, Inc.

### **References**

1. ANSYS Theoretical Manual
2. ANSYS User's Information Manual
3. ANSYS Verification Manual

### **3L.2.3 BREAK POINTS AND WHIP RESTRAINT LOCATIONS**

Stress analysis results utilized in the criteria for determining pipe break locations are documented in the applicable piping stress calculation for each piping system. Whip restraint locations based on postulated pipe break locations are shown on applicable civil design drawings.

#### **3L.2.3.1 Class 1 Lines (Including Accumulator Lines)**

The criteria for postulated break locations are specified in subsection 3.6.2.3. It has been determined that in all cases for these lines, the governing criterion for postulated break locations is primary and secondary stress intensity range.

#### **3L.2.3.2 Safety Injection Lines (Except Accumulator Lines)**

The criteria for postulated break locations are specified in subsection 3.6.2.3.

### **3L.3.0 NUCLEAR CLASS 2**

This section provides the information related to Class 2 piping.

#### **3L.3.1 PIPING CONSIDERED**

The Class 2 piping considered in this appendix consists of the main steam and main feedwater piping in the containment.

The stress analysis results utilized in the criteria for determining pipe break locations are documented in the applicable piping stress calculation for each piping system.

### 3L.3.2 METHODS OF ANALYSIS

The following is a description of the computer program used in stress analysis of the systems listed in 3L.2.2.2 and 3L.3.1, and also a brief description of the programs' assumptions and theory. All programs conform to the design and control measures required by Appendix B of 10 CFR Part 50.

#### 3L.3.2.1 Piping System Analysis (ME 632)

##### Purpose

The stresses and loads in piping systems due to restrained expansion, deadweight, seismic movement, and earthquake are calculated using the static analysis computer program.

##### Method of Analysis

The stiffness method of finite element analysis has been used in this program. In this method, the displacements of the joints of a given structure are considered to be the basic unknowns. The dynamic analysis of the program utilizes the general theory of response analysis by the modal synthesis methods. The modal synthesis, in principle, exploits known maximum accelerations produced in a single degree of freedom model of certain frequency. The method is described in detail in the references. The program's principal assumptions are:

- A. Linearly elastic structure.
- B. Simultaneous displacement of all supports described by a single time dependent function.
- C. Lumped mass model satisfactorily replaces the structure.
- D. Modal synthesis is applicable.
- E. Rotational inertias of the masses have negligible effect.

##### Static Analysis

For gravity, thermal, and seismic movement analyses, the static load and displacement matrices were formed in addition to the stiffness matrix of the mathematical model. These matrices included the applied joint forces and displacements, the distributed loading on the mathematical model, and the thermal forces developed in the members of the model, whichever is applicable. Once these matrices were formed, the joint displacements of the mathematical model were found by solving the following equation:

$$R - Kr = 0 \quad \text{Eq. (1)}$$

in which:

$$R = \text{Joint load matrix}$$

## FNP-FSAR-3L

$K$  = Stiffness matrix of pipe loop  
 $r$  = Joint displacement matrix

After the joint displacements were determined, the individual member forces were obtained by using the member stiffness properties, and, finally, the support reactions were calculated.

### Dynamic Analysis

The dynamic analysis of flexible piping systems is performed using the response spectrum method. A flexible piping system is idealized as a mathematical model consisting of lumped masses connected by massless elastic members. The lumped masses are carefully located so as to adequately represent the dynamic and elastic properties of the piping system. The three dimensional stiffness matrix of the mathematical model is determined by the direct stiffness method. Axial, shear, flexural and torsional deformations of each member are included. For curved members, a decreased stiffness is used in accordance with ASME Section III. The mass matrix is also calculated.

After the stiffness and the mass matrix of the mathematical model are calculated, the natural frequencies of piping system and corresponding mode shapes are determined using the following equation:

$$(\underline{K} - W_n^2 \underline{M})\underline{\phi} = \underline{0} \quad \text{Eq. (2)}$$

where:

$\underline{K}$  = stiffness matrix  
 $W_n$  = natural circular frequency for the nth mode  
 $\underline{M}$  = mass matrix  
 $\underline{\phi}_N$  = mode shape matrix for the nth mode  
 $\underline{0}$  = zero matrix

The Givens or the Jacobi method is used in the solution of the above equation. The mode shapes are normalized as follows:

$$\underline{\phi}_n^t \underline{M} \underline{\phi}_n = 1 \quad \text{Eq. (3)}$$

A generalized mass matrix is calculated, and should correspond to:

$$\underline{\phi}^t \underline{M} \underline{\phi} = I \quad \text{Eq. (4)}$$

where

## FNP-FSAR-3L

- $\phi$  = matrix of mode shapes
- $\phi^t$  = transposition of
- I = identifies matrix

If any one of the off-diagonal terms in the generation of the left-hand side of Equation (4) is greater than  $1 \times 10^{-4}$ , the problem is aborted. This occurs when poor or improper modeling of the piping system exists.

The response spectrum method is then used to find the maximum response of each mode:

$$Y_n^{(t) \max} = \frac{\phi^t \underline{M} \underline{D} S_{a_n}}{W_n^2 M_n} \quad \text{Eq. (5)}$$

where

- $S_{a_n}$  = spectral acceleration value for the nth mode
- $\underline{D}$  = earthquake vector matrix, used to introduce earthquake direction to the response analysis
- $\phi$  = transposition of the nth mode shape
- $M$  = generalized mass of the nth mode; equals one by Equation (2-2)
- $Y_n$  = generalized coordinate for the nth mode

Using the maximum generalized coordinate for each mode, the maximum displacements associated with each mode are calculated:

$$\underline{V}_n = \phi_n Y_n^{(t) \max} \quad \text{Eq. (6)}$$

Once the appropriate maximum modal displacements have been determined for each mass point, the effective inertia forces for each mode are computed:

$$\underline{Q}_n = \underline{K} \underline{V}_n \quad \text{Eq. (7)}$$

where:

- $\underline{Q}_n$  = effective inertia force matrix due to nth mode
- $\underline{V}_n$  = displacement matrix due to nth mode

The effective acceleration for each mode is calculated:

## FNP-FSAR-3L

$$\underline{a}_n = \underline{M}^{-1} \underline{Q}_n \quad \text{Eq. (8)}$$

where:

$\underline{a}$  = effective acceleration matrix due to nth mode

$\underline{M}^{-1}$  = the inverse of mass matrix

After the effective inertia forces have been determined, the internal forces and moments for each mode are also calculated:

$$\underline{S}_n = \underline{b} \underline{Q}_n \quad \text{Eq. (9)}$$

where:

$\underline{S}$  = internal force and moment matrix due to the nth mode

$\underline{b}$  = force transformation matrix

The modal stresses are then calculated from the modal internal forces and moments in accordance with ASME Section III. The analysis is made three times: once for the vertical direction and once for each of the two principal horizontal directions of the building. The method of combining the modal responses (i.e., displacements, effective inertia forces, effective accelerations, internal forces and moments, support reactions, and stresses) is the square root of the sum of the squares.

### **References**

1. Gere, J. M. and Weaver, W. Jr., Analysis of Framed Structures, D. Van Nostrand Co., Inc., 1965.
2. Weaver, W. Jr., Computer Program for Structural Analysis, D. Van Nostrand Co., Inc., 1967.
3. Roark, R. J. Formulas for Stress and Strain, McGraw-Hill, 1965.
4. Morris, D. L. "Curved Beam Stiffness Coefficients," Struct. Div. Journal, ASCE, May 1968.

### **Verification**

The program has been verified by comparing its output with the "ASME Program Verification and Qualifications Program Library," standard problems. The results were acceptable.



### **3L.3.2.2 Linear Elastic Analysis of Piping Systems (ME 101)**

#### **Purpose**

This program serves the same purpose as ME 632. In addition it forms the stress equations, as defined in ANSI B31.1 and ASME Section III, from individual loading conditions and satisfies them.

#### **Method of Analysis**

This program replaces the program ME 632 and has almost the same features. The basic method of analysis is the same as ME 632 discussed in subsection 3L.2.2.2.3.

The development of ME 101 is intended to produce a more efficient and systematic piping program. ME 101 is structured so as to allow easy incorporation of changes and any further enhancements.

ME 101 has the capability of performing stress combinations, per ASME Section III and ANSI B31.1 codes and of satisfying appropriate equations. In analysis it incorporates NRC Regulatory Guide 1.92. It prepares load summary sheets and stress summary sheets for stress reports.

#### **Verification**

The program has been verified by a series of hand calculations and by comparing the results of the program with the results from commercially available standard computer programs.

### **3L.3.2.3 Local Stresses in Cylindrical Shells due to External Loadings (ME 210)**

#### **Purpose**

To calculate local stresses caused in pipe walls due to external loading on lugs or stanchions attached integrally to the pipe.

#### **Method of Analysis**

ME 210 is based on WRC Bulletin 107 for local stresses in cylindrical shells due to external loading. In this program induced stresses in the pipe walls, due to loads applied on lugs and stanchions, are calculated and combined with stresses obtained in ME 101 analysis, to satisfy stress equations, per ASME Section III, NC and MD-3600, and ANSI B31.1.

#### **Program Verification**

The program has been verified through a set of hand calculations using procedures outlined in WRC Bulletin No. 107.

**References**

1. Forsythe, G. E. and Wasow, W. R., Finite-Difference Methods for Partial Differential Equations, John Wiley, 1960, pp 101-107, 119-125.
2. Holman, J. P., Heat Transfer, Third Edition, McGraw-Hill, 1972, Eqs. (6.1) and (6.29).
3. McNeill, D. R. and Brock, J. B., "Charts for Transient Temperatures in Pipes," in Heating/Piping/Air Conditioning, November 1971, pp 107-119.
4. Tung, T. K., "Thermal Gradients in Pipe Walls Due to Ramps in Fluid Temperature," Report BR-5853-T-012, Bechtel Power Corporation, San Francisco, 1975.
5. Tung, T. K., "Analysis on Axial Discontinuity Temperature Difference in Pipe Walls," to be reported.

**3L.3.3 BREAK POINTS AND WHIP RESTRAINT LOCATIONS**

Break points are postulated in accordance with the requirements set forth in attachment A of appendix 3K. Whip restraint locations based on postulated pipe break locations are shown on applicable civil design drawings.

**3M REACTOR PRESSURE VESSEL SUPPORT LOADS**

**TABLE OF CONTENTS**

3M.1	INTRODUCTION.....	3M-1
3M.2	INTERFACE INFORMATION.....	3M-1
3M.3	LOADING CONDITIONS.....	3M-2
3M.4	REACTOR VESSEL AND INTERNALS MODELING.....	3M-2
3M.5	ANALYTICAL METHODS .....	3M-3
3M.6	RESULTS OF THE ANALYSIS .....	3M-4

**LIST OF TABLES**

- 3M-1 Maximum Reactor Vessel Displacements at Reactor Vessel Centerline
- 3M-2 Maximum Reactor Vessel Support Loads for Postulated Pipe Rupture Conditions
- 3M-3 Maximum Reactor Vessel Support Loads for Combined Pipe Rupture Condition, Safe Shutdown Earthquake, and Deadweight

**LIST OF FIGURES**

- 3M-1 Reactor Vessel Support Shoe
- 3M-2 Reactor Vessel Support Box
- 3M-3 Mathematical Model for Horizontal Response
- 3M-4 Mathematical Model for Vertical Response

**APPENDIX 3M****REACTOR PRESSURE VESSEL SUPPORT LOADS****3M.1 INTRODUCTION**

This appendix presents the method of computing the reactor pressure vessel loss-of-coolant accident (LOCA) support loads and displacements. The structural analysis considers simultaneous application of the time history loads on the reactor vessel resulting from the reactor coolant loop vessel nozzle mechanical loads, internal hydraulic pressure transients, and reactor cavity pressurization (for postulated breaks in the reactor coolant pipe at the vessel nozzles). The vessel is restrained by reactor vessel support pads and shoes beneath each nozzle, and the reactor coolant loops with the primary supports of the steam generators and the reactor coolant pumps. The objective of this analysis is to obtain reactor vessel displacements and reactor vessel support loads.

Pipe displacement restraints installed in the primary shield wall limit the break opening area of the vessel nozzle pipe breaks to less than 100 in.<sup>2</sup> for the inlet nozzle and 30 in.<sup>2</sup> for the outlet nozzle. These areas were determined to be an upper bound by using worst case vessel and pipe relative motions based on similar plant analyses. Detailed studies have shown that pipe breaks at the hot or cold leg reactor vessel nozzles, even with a limited break area, would give the highest reactor vessel support loads and the highest vessel displacements, primarily due to the influence of reactor cavity pressurization. By considering these breaks, the most severe reactor vessel support loads are determined. For completeness, a break outside the shield wall, for which there is no cavity pressurization, is also analyzed; specifically, the pump outlet nozzle pipe break is considered. In summary, three loss of coolant accident conditions are analyzed:

- A. Reactor vessel inlet nozzle pipe break.
- B. Reactor vessel outlet nozzle pipe break.
- C. Reactor coolant pump outlet nozzle pipe break.

**3M.2 INTERFACE INFORMATION**

Bechtel Power Corporation performed the reactor containment design and analysis. Stiffness of the primary shield wall beneath the reactor vessel supports and asymmetric cavity pressurization loading was provided by Bechtel to Westinghouse. Cavity pressure loads were provided as force time histories acting on the reactor vessel.

All other input information was developed within Westinghouse. These items are reactor internals properties, loop mechanical loads and loop stiffness, internal hydraulic pressure transients, and reactor support stiffnesses. These inputs allowed formulation of the mathematical models and performance of the analyses, as will be described.

### **3M.3 LOADING CONDITIONS**

Following a postulated pipe rupture at the reactor vessel nozzle, the reactor vessel is excited by time history forces. As described, these forces are the combined effect of three phenomena: reactor coolant loop mechanical loads, reactor cavity pressurization forces, and reactor internal hydraulic forces.

The reactor coolant loop mechanical forces are derived from the elastic dynamic analyses of the loop piping for the postulated break. This analysis is described in subsection 5.2.1.10.1.1. The dynamic reactions on the nozzles of all the unbroken piping legs are applied to the vessel in the RPV blowdown analysis.

Reactor cavity pressurization forces arise for the pipe breaks at the vessel nozzles from the steam and water which is released into the reactor cavity through the annulus around the broken pipe. The reactor cavity is pressurized asymmetrically with higher pressure on the side adjacent to the break. These differences in pressure horizontally across the reactor cavity result in horizontal forces applied to the reactor vessel. Smaller vertical forces arising from pressure on the bottom of the vessel and the vessel flanges are also applied to the reactor vessel. The cavity pressure analysis is described in section 6.2.

The internals reaction forces develop from asymmetric pressure distributions inside the reactor vessel. For a vessel inlet nozzle break and pump outlet nozzle break, the depressurization wave path is through the broken loop inlet nozzle and into the region between the core barrel and reactor vessel. (See figure 3.9-1.) This region is called the downcomer annulus. The initial waves propagate up, down and around the downcomer annulus and up through the fuel. In the case of an RPV outlet nozzle break, the wave passes through the outlet nozzle and directly into the upper internals region, depressurizes the core, and enters the downcomer annulus from the bottom of the vessel. Thus, for an outlet nozzle break, the downcomer annulus is depressurized with much smaller differences in pressure horizontally across the core barrel than for the inlet break. For both the inlet and outlet nozzle breaks, the depressurization waves continue their propagation by reflection and transmission through the reactor vessel fluid but the initial depressurization wave has the greatest effect on the loads.

The reactor internals hydraulic pressure transients were calculated including the assumption that the structural motion is coupled with the pressure transients. This phenomena has been referred to as hydroelastic coupling or fluid-structure interaction. The hydraulic analysis considers the fluid structure interaction of the core barrel by accounting for the deflections of constraining boundaries which are represented by masses and springs. The dynamic response of the core barrel in its beam bending mode responding to blowdown forces compensates for internal pressure variation by increasing the volume of the more highly pressurized regions. The analytical methods used to develop the reactor internals hydraulics are described in WCAP-8708.<sup>(1)</sup>

### **3M.4 REACTOR VESSEL AND INTERNALS MODELING**

The reactor vessel and internals general assembly is shown in figure 3.9-1. The reactor vessel is restrained by two mechanisms: the three attached reactor coolant loops with the steam generator and reactor coolant pump primary supports, and six reactor vessel supports, one

## FNP-FSAR-3M

beneath each reactor vessel nozzle. The reactor vessel supports are described in subsection 5.5.14 and are shown in figures 5.5-7, 3M-1, and 3M-2. The support shoe provides restraint in the horizontal directions and for downward reactor vessel motion.

The reactor vessel model consists of two separate nonlinear elastic models connected at a common node. One model represents the dynamic vertical characteristics of the vessel and its internals, and the other model represents the translational and rotational characteristics of the structure. These two models are combined in the DARI-WOSTAS code<sup>(2)</sup> to represent motion of the reactor vessel and its internals in the plane of the vessel centerline and the broken pipe centerline.

The model for horizontal motion is shown in figure 3M-3. Each node has one translational and one rotational degree of freedom in the vertical plane containing the centerline of the nozzle attached to the broken pipe and the centerline of the vessel. A combination of beam elements and concentrated masses are used to represent the components including the vessel, core barrel, neutron panels, fuel assemblies, and upper support columns. Connections between the various components are either pin-pin rigid links, translational impact springs with damping, or rotational springs.

The model for vertical motion is shown in figure 3M-4. Each mass node has one translational degree of freedom. The structure is represented by concentrated masses, springs, dampers, gaps, and frictional elements. The model includes the core barrel, lower support columns, bottom nozzles, fuel rods, top nozzles, upper support columns, upper support structure, and reactor vessel.

The horizontal and vertical models are coupled at the elevation of the primary nozzle centerlines. Node 1 of the horizontal model is coupled with node 2 of the vertical model at the reactor vessel nozzle elevation. This coupled node has external restraints characterized by a 3 x 3 matrix which represents the reactor coolant loop stiffness characteristics, by linear horizontal springs which describe the tangential resistance of the supports, and by individual nonlinear vertical vessel support dynamic elements (spring dashpot system) which provide restraint only in the vertically downward direction. The supports as represented in the horizontal and vertical models (figures 3M-3 and 3M-4) are not indicative of the complexity of the support system used in the analysis. The individual supports are located at the actual support pad locations and accurately represent the independent nonlinear behavior of each support.

### **3M.5 ANALYTICAL METHODS**

The time-history effects of the cavity pressurization loads, internals loads and loop mechanical loads are combined and applied simultaneously to the applicable nodes of the mathematical model of the reactor vessel and internals. The analysis is performed by numerically integrating the differential equations of motion to obtain the transient response. The output of the analysis includes, among other things, the displacements of the reactor vessel and the loads in the reactor vessel supports. The loads from the postulated pipe break on the vessel supports are combined with other applicable faulted condition loads and subsequently used to calculate the stresses in the supports. Also, the reactor coolant loop is analyzed by applying the reactor vessel displacements to the reactor coolant loop model. The resulting loads and stresses in the piping, components, and supports are then combined with those from the loop dynamic



blowdown analysis, and the adequacy of the system is verified. Thus, the effect of vessel displacements upon loop response and the effect of loop blowdown upon vessel displacements are both evaluated.

### **3M.6 RESULTS OF THE ANALYSIS**

As described, the reactor vessel and internals were analyzed for three postulated break locations. Table 3M-1 summarizes the displacements and rotations of and about a point representing the intersection of the nozzle centerline of the nozzle attached to the leg in which the break was postulated to occur and the vertical centerline of the reactor vessel. Positive vertical displacement is up, and positive horizontal displacement is away from and along the centerline of the vessel nozzle in the loop in which the break was postulated to occur. These displacements were calculated using an assumed break opening area for the postulated pipe ruptures at the vessel nozzles of 144 in.<sup>2(a)</sup> and a double-ended rupture at the pump outlet nozzle. These areas are estimated prior to performing the analysis. Following the reactor coolant system structural analysis, the relative motions of the broken pipe ends are obtained from the reactor vessel and reactor coolant loop blowdown analyses. These motions resulted in an average break opening area of less than 85 in.<sup>2</sup> (100 in.<sup>2</sup>, peak) for the vessel inlet nozzle break and 15 in.<sup>2</sup> (23 in.<sup>2</sup>, peak) for the vessel outlet nozzle break. Since these areas are less than the areas used to generate the applied loads, the system structural analysis is conservative.

The maximum loads induced in the vessel supports due to the postulated pipe break are given in table 3M-2. These loads are per vessel support and are applied at the vessel nozzle pad. It is conservatively assumed that the maximum horizontal and vertical loads occur simultaneously and on the same support, even though the time-history results show that these loads do not occur simultaneously on the same support. The peak vertical load occurs for a vessel inlet nozzle break; the peak horizontal load occurs for the vessel outlet nozzle break. Note that the peak horizontal load is an extremely conservative value since the break opening area for the vessel outlet nozzle break is only 15 in.<sup>2</sup> instead of 144 in.<sup>2(a)</sup> area used to generate the applied loads. If additional analysis were performed using the lower break opening area, the load would be considerably reduced. Furthermore, the peak vertical load and peak horizontal load do not occur on the same vessel support. The largest vertical loads are produced on the supports beneath and opposite the broken nozzle. The largest horizontal loads are produced on the supports which are the most perpendicular to the broken nozzle horizontal centerline.

The LOCA loads are combined with other applicable faulted condition loads, and the total applied loads are obtained. These total loads on a per support basis are summarized in table 3M-3. This total combined load is applied to the reactor vessel supporting structure, which is analyzed into two independent components: the U-shaped vessel shoe (figure 3M-1), and the cooling box, which is the structure between the shoe and the concrete (figure 3M-2). Final analyses have been performed on the support shoe and the cooling box structure, and the results are presented in subsection 5.2.1.10.1.1(M).

---

a. The maximum break opening area of the inlet nozzle was redetermined to be 100 in.<sup>2</sup> and the maximum break area of the outlet nozzle was redetermined to be 30 in.<sup>2</sup> Only the inlet nozzle break was reanalyzed since it bounds the smaller break in the outlet nozzle.

## FNP-FSAR-3M

The reactor coolant loop piping was evaluated for the primary membrane plus bending stress intensity against the faulted- condition stress limit, equation 9 of subarticle 3650 of the ASME Section III, Nuclear Power Piping Code. The loads included in the evaluation result from the SSE inertia loading, deadweight, pressure, LOCA loop hydraulic forces, and reactor vessel motion. Individual loadings at critical stress locations were combined, and primary stress intensities were calculated for the combined load sets. The primary stress intensities at all locations were under the faulted condition stress limit. It is therefore concluded that the reactor coolant loop piping of the unbroken loop or the unbroken legs of the broken loop meets the faulted condition requirements of ASME Section III and is capable of withstanding the consequences resulting from a break at the reactor vessel inlet or outlet nozzle.

For the evaluation of the design adequacy of equipment, the maximum loads at the primary equipment nozzles resulting from the analysis of each loading condition were determined. The external loads imposed upon primary equipment by the reactor coolant loop produce stress intensities which are below the faulted condition allowable values.

The effects of the postulated breaks at the reactor vessel inlet and outlet nozzle locations on the CRDM's, reactor vessel internals, ECCS branch lines, RCS component supports, and the reactor core are presented in subsection 5.2.1.10.1.1 (N), subsection 3.9.3.8, appendix 3L, subsection 5.2.1.10.1.1(M), and subsection 4.2.1.3.2, respectively.

The results of these analyses verify that the integrity of the safeguards systems is assured during a loss of coolant accident and that the reactor can be safely shut down and maintained in a safe condition.

## FNP-FSAR-3M

### REFERENCES

1. Takeuchi, K., et al., "MULTIFLEX - A Fortran-IV Computer Program for Analyzing Thermal - Hydraulic-Structure System Dynamics," WCAP-8708, February 1976.
2. WCAP-8252, "Documentation of Selected Westinghouse Structural Analysis Computer Codes," April 1976.

FNP-FSAR-3M

**TABLE 3M-1**

**MAXIMUM REACTOR VESSEL DISPLACEMENTS AT  
REACTOR VESSEL CENTERLINE**

	Maximum Horizontal Displacement (in.)	Maximum Vertical Displacement (in.)	Maximum Rotation (radians)
144 in. <sup>2(a)</sup> RPV inlet	0.078 0.0	0.030 -0.038	0.00025 -0.0004
144 in. <sup>2(a)</sup> RPV outlet	0.086 0.0	0.016 -0.020	0.00007 -0.00026
Double-ended pump outlet	0.049 -0.028	0.004 -0.036	0.00031 -0.00029

a. Physical restraints limit the maximum circumferential break in the inlet nozzle to 100 in.<sup>2</sup> and to 30 in.<sup>2</sup> in the outlet nozzle. The maximum displacements and rotations for these breaks were verified to be less than those listed here for a 144 in.<sup>2</sup> break.

**TABLE 3M-2**

**MAXIMUM REACTOR VESSEL SUPPORT LOADS  
FOR POSTULATED PIPE RUPTURE CONDITIONS<sup>(a)</sup>**

LOCA Maximum Vertical Load Per Support Including Deadweight	LOCA Maximum Horizontal Load Per Support
2150 Kips	1050 Kips

---

a. Physical restraints limit the maximum circumferential break in the inlet nozzle to 100 in.<sup>2</sup> and to 30 in.<sup>2</sup> in the outlet nozzle. The maximum loads for these breaks were verified to be less than those listed here for a 144 in.<sup>2</sup> break.

**TABLE 3M-3**

**MAXIMUM REACTOR VESSEL SUPPORT LOADS FOR COMBINED PIPE RUPTURE CONDITION, SAFE SHUTDOWN EARTHQUAKE, AND DEADWEIGHT<sup>(a)</sup>**

Maximum Combined Vertical  
Load Per Support



2392 Kips

Maximum Combined Horizontal  
Load Per Support

1326 Kips

---


a. Physical restraints limit the maximum circumferential break in the inlet nozzle to 100 in.<sup>2</sup> and to 30 in.<sup>2</sup> in the outlet nozzle. The maximum loads for these breaks were verified to be less than those listed here for a 144 in.<sup>2</sup> break.



REV 21 5/08








REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

MATHEMATICAL MODEL FOR HORIZONTAL RESPONSE

FIGURE 3M-3



REV 21 5/08



JOSEPH M. FARLEY  
NUCLEAR PLANT  
UNIT 1 AND UNIT 2

MATHEMATICAL MODEL FOR VERTICAL RESPONSE

FIGURE 3M-4