



**Pacific Gas and
Electric Company®**

James M. Welsch
Vice President, Nuclear Generation

Diablo Canyon Power Plant
Mail Code 104/6
P. O. Box 56
Avila Beach, CA 93424

805.545.3242
Internal: 691.3242
Fax: 805.545.4884

April 27, 2017

PG&E Letter HIL-17-002

REIRS Project Manager
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10 CFR 20.2206

Docket No. 72-27, Materials License No. SNM-2514
Humboldt Bay Independent Spent Fuel Storage Installation
Annual Report of Occupational Radiation Exposure for 2016

REIRS Project Manager:

Individual monitoring at Humboldt Bay Independent Spent Fuel Storage Installation (HB ISFSI) during calendar year 2016 was not required because no work activities were conducted that required personnel entry beyond the cask vault lid. HB ISFSI environmental thermoluminescent dosimeter results were non-detectable throughout 2016 and the 2016 Quarterly Surveys of the cask area showed no discernable difference from background radiation exposure rates.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

If you have questions about the report, please contact Ms. Linda Sewell at (805) 545-4315.

Sincerely,

James M. Welsch

cc: John B. Hickman, NRC Project Manager
Kriss M. Kennedy, NRC Region IV Administrator
NRC Document Control Desk
HBPP Humboldt Distribution