




Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

Regulatory Docket File

March 10, 1975



Mr. B. J. Youngblood, Chief
 Environmental Projects Branch 3
 Division of Reactor Licensing
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Subject: Dresden Station Environmental
 Technical Specification
 NRC Dkts. 50-237 and 50-249

Dear Mr. Youngblood:


In response to your letter dated February 4,
 1975 concerning this subject, attached is the
 additional information requested in your letter.

One (1) signed original and 39 copies are
 submitted.

Very truly yours,

J. S. Abel
 Nuclear Licensing Administrator
 Boiling Water Reactors

Att.



3098

Regulatory Docket File

Control W/Ltr Dated 3-10-75

Subject: Response to NRC Requests (dated Feb. 4, 1975)
re. Dresden Environmental Technical Specifications

1. An explanation of the assumptions, theory, model and measurements involved in the derivation of the closed cycle curve in Figure 2.1.1 of the November 18, 1974 report is given in the attached Appendix. Similar arguments can be made for the open cycle curve appearing in the same figure.
2. The downstream temperature TL is measured by a Foxboro recorder on the tailwater side of the Dresden Island Lock and Dam. The location was selected by Mr. Robert R. Jaske formerly of Battelle Northwest in cooperation with the USGS in 1967. The USGS owns and maintains the recorder. Data was used by Mr. Jaske in his COLHEAT model for determining thermal load on the upper Illinois River. The temperatures are considered representative of downstream mixed conditions. When plume studies are performed in the field, the TL is determined by making an average of temperature measured horizontally and vertically across the headwater face of the dam. A study is being performed to validate the method described on page 3 with current field data.
3. Enclosed are drawings of four thermal plume measurements. Two were performed on August 10, 1974 and the remainder on October 17 and October 21, 1974. The flow of the Illinois River was determined by using gate openings at the Dresden Island Lock and Dam and a discharge rating curve. TL was determined by making an average of the headwater temperatures at the dam.

Study of August 10, 1974 (morning):

The plant load was 1246 MWe (Unit 1=75, Unit 2=650, Unit 3=500). Flow from the Unit 1 discharge canal was 378 cfs. Unit 2/3 discharge was zero. Flow in the river was about 5,450 cfs and the ambient water temperature was 28.1°C. The area contained within the excess 2.8°C isoline was 0.35 acres.

Study of August 10, 1974 (afternoon):

The plant load was 1480 MWe (Unit 1 = 128, Unit 2 = 615, Unit 3 = 737). Flow from the Unit 1 discharge canal was 378 cfs and from the Unit 2, 3 canal was 111 cfs. The river flow was about 5,450 cfs and the ambient water temperature was 28.1°C. The area contained within the excess 2.8°C contour was 0.29 acres.

Study of October 17, 1974:

The plant load was 1475 MWe (Unit 1 = 75, Unit 2 = 650, Unit 3 = 750). Flow from the Unit 1 discharge canal was 378 cfs and the ambient water temperature was 19.6°C. There was no

discernable area 2.8°C above ambient.

Study of October 21, 1974:

The plant load was 819 MWe (Unit 1=100, Unit 2=0, Unit 3=719). Flow from the Unit 1 discharge was 285 cfs and from the Unit 2,3 discharge was 117 cfs. The river flow was 2800 cfs and the ambient water temperature was 16.4°C. There was no discernable area 2.8°C above ambient.

4. Construction of the modification to the Unit 1 discharge canal outfall has been completed. The modification consisted of the removal of an existing rock jetty (see drawing no. B-27 and B-28 attached) and the installation of a slot jet outfall. The new outfall consists of two circular cells twenty feet in diameter. The cells are separated by about eight feet. This separation forms the slot which creates the high velocity discharge necessary for rapid mixing. The cells are formed of sheet metal piling, filled with rubble obtained when the jetty was removed and are capped with concrete. The cells are tied back to the shore with rock filled dikes. The Unit 2, 3 canal was not modified. The mode of operation is for Unit 2, 3 blowdown and the Unit 1 circulating water to be discharged from their respective canals.
5. The chlorine data is attached.

Dresden Station Condenser Chlorination Data

Unit 1

Date	ppm	
	Free Chlorine	Total Residual
1- 3-75	0.1	0.4
1- 8-75	0.2	0.5
	Chlorinator out of Service	
1-28-75	0.1	0.3

No Chlorination in February
to Date

Notes

1. Analysis is conducted immediately after samples are collected.
2. Method of analysis - orthotolidine
3. Collection of samples at discharge of condenser immediately after injection of chlorine.
4. Future samples will be collected at 4, 8, 12, 16 and 20 minutes after injection begins. The average of samples will be the composite of the chlorination period.

Units 2-3

No chlorine monitoring has been conducted in 1975.

Monthly monitoring was conducted during 1974. Samples were collected at the condenser discharge and in the tail water of the spill way at the discharge of the cooling lake. The samples were analyzed using the orthotolidine technique. The condenser discharge samples averaged approximately 0.3 ppm residual chlorine (free chlorine plus chloramines), and the maximum residual chlorine measured at the condenser discharge was 0.7 ppm. The lake discharge samples were all below the lower limit of residual chlorine detectability using the orthotolidine measuring technique. This lower limit is something less than 0.1 ppm residual chlorine.

Summary and Interpretation of IIHR Laboratory Data for Compliance-Test Diagrams.

The laboratory experiments on which the compliance-test diagrams are based were conducted in a thermal-hydraulic model at the Iowa Institute of Hydraulic Research with a 1:36 vertical scale and a 1:108 horizontal scale. The model includes a 2500-ft reach of the Illinois River extending from a cross section 400 ft upstream from the discharge flumes to a section 2100 ft downstream. The 3 to 1 vertical distortion was dictated by the available space for the model together with the requirement that depth of flow in the model be sufficiently large to ensure turbulent ambient river flow in the model.

Flow velocities and discharges were scaled according to the densimetric Froude similarity law according to which there is dynamic similarity between a geometrically similar model and prototype if the densimetric Froude number

$$F_D = \frac{U}{\sqrt{\frac{\Delta\rho}{\rho} g L}} \quad (A1)$$

has the same value in both model and prototype. In Eq. A1, U = a representative velocity; L = a representative length dimension; g = acceleration of gravity; $\frac{\Delta\rho}{\rho}$ = ratio of density difference between ambient and heated water to density of ambient water.

In a distorted model, L is defined as a representative vertical dimension, usually a representative depth. Due to the relaxation of the geometrical similarity requirement, dynamic similarity in the transverse direction is not preserved so that compensating adjustments are required. In the present case, the rate of transverse turbulent mixing and the outward displacement of the plume trajectory tend to be overpredicted in the model. As compensating adjustments, the bed of the model was roughened, and the slot width of the discharge structure was doubled in order to reduce the turbulent mixing and the outward displacement of the plume by reducing the initial jet velocity at the discharge structure. The factor of two was arrived at through a calibration

procedure in an earlier phase of the investigation, wherein results from an undistorted near-field model were compared with results from the distorted model for a similar though not identical outfall configuration. This has been recommended also by Neale and Hecker (2). Although increasing the slot width and reducing the initial jet velocity in the distorted model by a factor of two produced the best overall match between results in the distorted and undistorted models, differences in detail were observed. In particular there was an increased tendency for vertical density and temperature stratification to occur in the distorted model, arising from the reduction in the value of the initial jet densimetric Froude number

$$F_{DO} = \frac{U_0}{\sqrt{\frac{\Delta\rho}{\rho} g h_0}} \quad (A2)$$

by a factor of two. In Eq. A2 U_0 = initial jet velocity, and h_0 = initial jet height = 7 ft in the prototype. The slot width in the prototype is $b_0 = 7.67$ ft.

A typical set of surface isotherms of the normalized temperature rise $\Delta T/\Delta T_D$, observed in the model, is shown in Fig. A1. Values of $\Delta T_{26}/\Delta T_D$ for constructing the compliance-test diagrams were obtained from the surface isotherm data by planimetering the areas enclosed by the different isotherms and plotting the $\Delta T/\Delta T_D$ values against the enclosed areas in acres. The point at which the curve connecting the points crosses the line $A = 26$ acres defines the value of $\Delta T_{26}/\Delta T_D$.

To construct the compliance-test diagrams the resulting values of $\Delta T_{26}/\Delta T_D$ were plotted against Q_{ILL} as shown in Fig. A2 for the mixed-discharge operating mode. Two curves are shown in Fig. A2. The solid curve simulates full plant load with $\Delta T_{D1} = 19^\circ\text{F}$, $\Delta T_{D2,3} = 28^\circ\text{F}$, $\Delta T_{I1} = 0$, $T_{ILL} = 85^\circ\text{F}$ for summer, and $T_{ILL} = 55^\circ\text{F}$ for the months when the ice-melting system is in operation. For these conditions $F_{DO} \approx 5$ in the model (10 in the prototype). Any reduction in ΔT_{D1} , $\Delta T_{D2,3}$, or T_{ILL} , either individually or collectively,

would increase the value of F_{DO} , consequently reducing the tendency for vertical temperature stratification to occur, which in turn would reduce the value of $\Delta T_{26}/\Delta T_D$. This tendency is verified in the dashed curve for which F_{DO} was increased to about 10 in the model (20 in the prototype) by reducing the values of ΔT_{D1} and $\Delta T_{D2,3}$. Note that each of the curves represents both summer and winter conditions. Apparently the reductions in Q_1 and T_{ILL} for the winter conditions have mutually offsetting effects.

Due to the tendency of the distorted model to accentuate stratification effects, it is quite possible that the dashed curve simulates full load conditions in the prototype better than the solid curve. However, the conservative approach was followed in adopting the solid curve for use in the provisional compliance-test diagram in Fig. 3.

Fig. A3 shows the laboratory data used in constructing the compliance-test diagram for the unmixed-discharge operating mode. Only the summertime conditions were simulated in the laboratory. The third variable F_{DO} is in this case a hybrid initial jet densimetric Froude number wherein U_0 = initial velocity of the Unit 1 discharge through the slot, and $\Delta \rho_0$ = density difference based on the ambient temperature T_{ILL} and the temperature of the combined heated discharges T_D . Two data points are shown for which $F_{DO} = 10$. For the upper one, F_{DO} was increased by halving the slot width and doubling U_0 . For the lower one, F_{DO} was increased by reducing ΔT_D . It apparently makes little difference which way F_{DO} is increased. In comparison with Fig. A2, there seems to be relatively little sensitivity to F_{DO} in Fig. A3. This result was somewhat unexpected.

The model data used in constructing the compliance-test diagram is summarized in Table A1. Background information on discharges, temperatures and initial conditions is presented in Cols. 4-11. The parameter b'_0/b_0 in

Col. 3 is the ratio of the slot width of the discharge structure, as modified to compensate for vertical distortion effects in the model, to the unmodified slot width. The main results of the tests are listed in Cols. 12-14. The $\Delta T_{26}/\Delta T_D$ values in Col. 12 are the same as those in Figs. A2 and A3. In Col. 13, the numerator ΔT_{25} is the temperature rise of the cross-sectional isotherm enclosing the 25 percent of the cross-sectional area within which the temperature rise is highest, for the cross section identified in Col. 14. The sections listed in Col. 14 (see Fig. A1 for their locations), are the ones in which the highest ΔT_{25} values in any given run were observed. The ratio $\Delta T_{25}/\Delta T_{26}$ is thus a measure of the temperature rise at the perimeter of the mixing zone as defined by the zone-of-passage criterion, relative to the temperature rise at the perimeter of the mixing zone as defined by the 26-acre surface area criterion. So long as this ratio is less than one, the 26-acre surface area criterion controls. Thus the $\Delta T_{25}/\Delta T_{26}$ values in Col. 13 clearly indicate that the 26-acre surface area criterion is the controlling one over the range of condition tested. The $\Delta T_{25}/\Delta T_{26}$ values reach one only at $Q_{ILL} = 23,000$ cfs, when the temperature rise at the mixing zone perimeter would be about 0.8°F at most.

Table A1. Summary of Model Data for Compliance-Test Diagrams

Operating Mode	Run	b'_o/b_o	Simulated		Simulated		Simulated		Simulated		F _{DO}	$\frac{\Delta T_{26}}{\Delta T_D}$	$\frac{\Delta T_{25}}{\Delta T_{26}}$	Sect. No.
			Q_{ILL} cfs	T_{ILL} °F	Q_1 cfs	ΔT_{D1} °F	$Q_{2,3}$ cfs	$\Delta T_{D2,3}$ °F	ΔT_D °F					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	
Mixed ↓	4	2	4800	≈ 85	378	19	111	28	21.0	4.7	0.29	0.24	10W	
	5	2	4800	≈ 85	378	4.8	111	7.0	5.3	9.5	0.23	0.39	18W	
	7	2	7400	≈ 85	378	19	111	28	21.0	4.8	0.24	0.29	9W	
	7R	2	7400	≈ 85	378	19	111	28	21.0	4.9	0.24			
	7a	1	7400	≈ 85	378	19	111	28	21.0	10.0	0.18	0.20	12W	
	8	2	7400	≈ 85	378	4.8	111	7.0	5.3	9.2	0.18	0.50	14W	
	8R	2	7400	≈ 85	378	4.8	111	7.0	5.3	9.0	0.18	0.33	14W	
	9	2	7300	≈ 55	291	19	111	28	21.5	4.7	0.24	0.38	9W	
	10	2	7300	≈ 55	291	6.7	111	9.9	7.6	9.4	0.15	0.07	12W	
	10R	2	7300	≈ 55	291	6.7	111	9.9	7.6	9.0	0.15	0.27	14W	
	11	2	10,000	≈ 85	378	19	111	28	21.0	4.7	0.16	0.38	9W	
	12	2	14,500	≈ 85	378	19	111	28	21.0	5.0	0.08	0.63	16W	
	13	2	23,500	≈ 85	378	19	111	28	21.0	4.9	0.04	1.0	14W	
	14	2	23,500	≈ 85	378	4.8	111	7.0	5.3	9.0	0.04	1.0	14W	
	15	2	23,400	≈ 55	291	19	111	28	21.5	4.5	0.035	1.0	12W	
	16	2	23,400	≈ 55	291	6.7	111	9.9	7.6	8.8	0.04	0.75	14W	
Unmixed ↓	4	2	4800	≈ 85	378	19	111	28	21.0	5.0	0.33	0.16	16W	
	7	2	7400	≈ 85	378	19	111	28	21.0	5.0	0.29	0.09	10W	
	7a	1	7400	≈ 85	378	19	111	28	21.0	10.0	0.26	0.14	14W	
	8	2	7400	≈ 85	378	4.8	111	7.0	5.3	10.0	0.24	0.22	16W	
	11	2	10,000	≈ 85	378	19	111	28	21.0	5.0	0.20	0.18	14W	
	12	2	14,500	≈ 85	378	19	111	28	21.0	5.0	0.06	0.57	16W	




Fig. A1. - Surface isotherms of normalized temperature rise $\frac{\Delta T}{\Delta T_D}$ for mixed-discharge mode,
 $Q_{ILL} = 6900$ cfs.




Fig. A2. - Laboratory data for mixed-discharge mode compliance-test diagram.





Fig. A3. - Laboratory data for unmixed-discharge mode compliance-test diagram.



Avg. Temp @ 1st & 9 DAM $T_1 = 28.4^\circ\text{C}$
 Flow of Illino. River @ DAM $Q_{11} = 5450 \text{ CFS}$
 Avg. Temp @ U-1 Discharge $T_{U1} = 32.4^\circ\text{C}$
 Discharge Flow U-1 $Q_{U1} = 3780 \text{ CFS}$
 Avg. Temp @ U-2,3 Discharge $T_{U2,3} = 30.2^\circ\text{C}$
 Discharge Flow U-2,3 $Q_{U2,3} = 0 \text{ CFS}$
 Total Plant Discharge Flow $Q_D = 3780 \text{ CFS}$
 Ambient Temp. Illinois River $T_{AMB} = 28.1^\circ\text{C}$
 STATION GENERATION (MW): UNIT 1 = 125,
 UNIT 2 = 618, UNIT 3 = 500

SCALE: 1" = 200'
 ALL DEPTHS AS MARKED

DRESDEN STATION THERMAL PLUME
 DATE: 8-10-74 TIME 08:16-1005
 AREA THERMAL PLUME 0.35 SQ. MILES

31.8°C SURFACE
 31.9°C -1FT
 30.2°C -1M
 29.4°C -2M

X 28.2°C SURFACE
 28.2°C -1FT
 28.5°C -1M
 28.4°C -2M
 28.4°C -3M
 28.4°C -4M
 28.4°C -5M


X 28.5°C SURFACE
 To Bottom
 3-1M

X 28.2°C SURFACE
 28.2°C -1FT
 28.4°C -1M
 28.4°C -2M
 28.5°C -3M
 28.5°C -4M
 28.5°C -5M

X 28.1°C SURFACE
 28.1°C -1FT
 28.4°C -1M
 28.0°C -2M

X 29.2°C SURFACE
 29.4°C -1FT
 28.9°C -1M
 28.6°C -2M

X 29.2°C SURFACE
 29.2°C -1FT
 29.2°C -1M
 29.2°C -2M



AVE. TEMP. @ LOCK 1 DAM $T_L = 28.4^\circ\text{C}$
 FLOW OF ILLINOIS RIVER @ DAM $Q_{ILL} = 5450 \text{ CFS}$
 AVE. TEMP. @ U-1 DISCHARGE $T_{U1} = 31.6^\circ\text{C}$
 DISCHARGE FLOW U-1 $Q_{U1} = 37 \text{ P.C.F.S.}$
 AVE. TEMP. @ U2,3 DISCHARGE $T_{U2,3} = 28.8^\circ\text{C}$
 DISCHARGE FLOW U2,3 $Q_{U2,3} = 111 \text{ CFS}$
 TOTAL PLANT DISCHARGE FLOW $Q_D = 449 \text{ C.F.S.}$
 AMBIENT TEMP. ILLINOIS RIVER $T_{AMB} = 26.1^\circ\text{C}$
 STATION GENERATION (MWE): UNIT 1 = 128
 UNIT 2 = 615, UNIT 2737

SCALE: 1"=200'
 ALL DEPTHS AS MARKED

DRESDEN STATION THERMAL PLUME
 DATE: 8-10-74 TIME: 1315-1558
 PLUME = 0.29 ACRES

30.2°C SURFACE
 30.3°C -1FT
 29.6°C -1M
 27.5°C -2M

28.4°C SURFACE
 28.5°C -1FT
 28.4°C -1M
 28.4°C -2M
 28.5°C -4M TO BOTTOM

29.1°C SURFACE
 28.5°C -1FT
 28.4°C -1M
 28.4°C -2M
 28.4°C -3M
 28.5°C -4M TO BOTTOM

28.4°C SURFACE
 28.4°C -1FT
 28.5°C -1M TO BOTTOM

27.1°C SURFACE
 27.1°C -1FT
 27.1°C -1M
 27.0°C -2M

30.5°C SURFACE
 29.0°C SURFACE
 28.5°C -1FT
 28.5°C -1M
 28.5°C -2M
 31.7°C


8/20/75

22W 20W 18W 16W 14W 12W 10W 9W 8W 7W 6W 5W 4W 3W 2W 1W 0

Dresden Station
 Illinois River Day
 Temperature U-1
 Discharge Flow U-1
 Temperature U-2,3
 Discharge Flow U-2,3
 Full Plant Discharge Flow
 Ambient Temp. Illinois River
 at 2nd Generation (Mile): Unit 1 = 75,
 Unit 2 = 650, Unit 3 = 750

T_{amb} = 19.6°C
 Q_{U1} = 3400 cfs
 T_{U1} = 20.5°C
 Q_{U1} = 3720 cfs
 T_{U2,3} = 20.9°C
 Q_{U2,3} = 11100 cfs
 Q_D = 4720 cfs
 T_{amb} = 19.6°C

Scale: 1" = 200'
 All depths as marked




DRESDEN STATION THERMAL PLUME
 DATE: 10-17-74
 NO OBSERVED Δ 2.8°C PLUME

X 20.3°C -1FT
 X 20.5°C -1M
 X 20.7°C -2M

X 20.4°C SURFACE
 X 20.5°C -1FT
 X 19.7°C -1M
 X 18.4°C -2M

Adl 2-20-75



AVE. TEMP @ LOCK FLAM $T_L = 16.6^\circ\text{C}$
 FLOW @ ILLINOIS RIVER DAM $Q_{IL} = 2300\text{ CFS}$
 AVE. TEMP @ ILLINOIS RIVER DAM $T_{IL} = 17.5^\circ\text{C}$
 DISCHARGE FLOW #1 $Q_{F1} = 285\text{ CFS}$
 AVE. TEMP @ U.S. 2 DISCHARGE $T_{US2} = 17.8^\circ\text{C}$
 DISCHARGE FLOW U.S. 2 $Q_{US2} = 117\text{ CFS}$
 TOTAL PLANT DISCHARGE FLOW $Q_D = 4020\text{ CFS}$
 AMBIENT TEMP. ILLINOIS RIVER $T_{AMB} = 16.4^\circ\text{C}$
 STATION GENERATION (MWE): UNIT 1 = 100,
 UNIT 2 = 0, UNIT 3 = 712

SCALE: 1" = 200'
 ALL DEPTHS AS MARKED

X 16.1°C SURFACE
 16.1°C - 1FT
 16.6°C - 1/4 TO
 BOTTOM

X 16.7°C SURFACE
 TO BOTTOM

X 16.6°C - 1FT

X 17.8°C - 1FT

X 17°C SURFACE
 17°C - 1FT

X 16.8°C - 1FT

X 16.8°C - 1FT

X 17.2°C - 1FT


X 17.6°C - 1FT

X 16.2°C SURFACE
 16.2°C - 1FT
 16.1°C - 1M
 16.1°C - 2M


DRESDEN STATION THERMAL PLUME
 DATE: 10-21-74
 NO OBSERVED Δ2.8°C PLUME

18.9°C - 1FT
 18.9°C - 1M
 18.8°C - 2M
 18.7°C - 3M


84




PLAN
DISCHARGE FLUME CELLS
 TOP OF CELL 1 CHEST PIPE EL. 810'-0"
 TOP OF CELL 2 EL. 810'-0" UNLESS NOTED
 TOP OF CASTING EL. 811'-4 1/2"
 SCALE: 1/4" = 1'-0"




SECTION 5-5
 SCALE: 1/4" = 1'-0"



DETAIL 1
 SCALE: 3/4" = 1'-0"



SECTION 1 (THIS ONE 5-5-17)
 SCALE: 1/4" = 1'-0"



SECTION 6-6
 NOT TO SCALE



SECTION 7-7
 NOT TO SCALE




NOTES

1. THE STRUCTURE IS TO BE CONSTRUCTED IN ACCORDANCE WITH THE SPECIFICATIONS AND DETAILS SHOWN ON THESE DRAWINGS.
2. ALL MATERIALS TO BE USED SHALL BE OF THE BEST QUALITY AND SHALL BE APPROVED BY THE ENGINEER BEFORE USE.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES.
4. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES.
5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES.
6. THE CONTRACTOR SHALL MAINTAIN ADEQUATE DRAINAGE AND EROSION CONTROL MEASURES THROUGHOUT CONSTRUCTION.
7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION AND RESTORATION OF ALL VEGETATION AND SOILS.
8. THE CONTRACTOR SHALL MAINTAIN ADEQUATE RECORDS OF ALL CONSTRUCTION ACTIVITIES.
9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION AND RESTORATION OF ALL ADJACENT PROPERTIES.
10. THE CONTRACTOR SHALL MAINTAIN ADEQUATE RECORDS OF ALL CONSTRUCTION ACTIVITIES.

REFERENCE DRAWINGS



RICHARD'S OUTLET	
NO. 12345	
DATE: 12/31/2023	
PROJECT: DISCHARGE FLUME CELLS	
DRAWING NO. 12345	
SCALE: AS SHOWN	
BY: [Signature]	
CHECKED BY: [Signature]	
APPROVED BY: [Signature]	
DATE: 12/31/2023	



REVISIONS	
1	REVISED TO SHOW CITY & COUNTY APPROVAL
2	REVISED TO SHOW CITY & COUNTY APPROVAL
3	REVISED TO SHOW CITY & COUNTY APPROVAL

REFERENCE DRAWINGS	
NO. 1	GENERAL PLAN
NO. 2	GENERAL PLAN
NO. 3	GENERAL PLAN

PROPERTY OF THE CITY OF	
NO. 1	GENERAL PLAN
NO. 2	GENERAL PLAN
NO. 3	GENERAL PLAN
NO. 4	GENERAL PLAN
NO. 5	GENERAL PLAN
NO. 6	GENERAL PLAN
NO. 7	GENERAL PLAN
NO. 8	GENERAL PLAN
NO. 9	GENERAL PLAN
NO. 10	GENERAL PLAN
NO. 11	GENERAL PLAN
NO. 12	GENERAL PLAN
NO. 13	GENERAL PLAN
NO. 14	GENERAL PLAN
NO. 15	GENERAL PLAN
NO. 16	GENERAL PLAN
NO. 17	GENERAL PLAN
NO. 18	GENERAL PLAN
NO. 19	GENERAL PLAN
NO. 20	GENERAL PLAN
NO. 21	GENERAL PLAN
NO. 22	GENERAL PLAN
NO. 23	GENERAL PLAN
NO. 24	GENERAL PLAN
NO. 25	GENERAL PLAN
NO. 26	GENERAL PLAN
NO. 27	GENERAL PLAN
NO. 28	GENERAL PLAN
NO. 29	GENERAL PLAN
NO. 30	GENERAL PLAN
NO. 31	GENERAL PLAN
NO. 32	GENERAL PLAN
NO. 33	GENERAL PLAN
NO. 34	GENERAL PLAN
NO. 35	GENERAL PLAN
NO. 36	GENERAL PLAN
NO. 37	GENERAL PLAN
NO. 38	GENERAL PLAN
NO. 39	GENERAL PLAN
NO. 40	GENERAL PLAN
NO. 41	GENERAL PLAN
NO. 42	GENERAL PLAN
NO. 43	GENERAL PLAN
NO. 44	GENERAL PLAN
NO. 45	GENERAL PLAN
NO. 46	GENERAL PLAN
NO. 47	GENERAL PLAN
NO. 48	GENERAL PLAN
NO. 49	GENERAL PLAN
NO. 50	GENERAL PLAN

30X S.L.