



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

JUL 16 1973

Files (Docket Nos. 50-237 and 50-249)

THRU: D. L. Ziemann, Chief, ORB #2, L

D.L. Ziemann
RELIEF AND SAFETY VALVE STRESS ANALYSES - DRESDEN UNITS 2 AND 3
(COMMONWEALTH EDISON COMPANY)

By letter of June 22, 1973, Commonwealth Edison submitted an analysis of stresses on Dresden 2 and 3 relief and safety valves in response to an RO letter of April 28, 1972, and our letter of March 6, 1973. The analyses considered stresses from pressure, weight, sustained loads, and occasional loads such as earthquake and valve lift. Their analyses show the stress levels to be below acceptable stress levels.

I conclude that: (1) CE has performed the analyses and evaluations requested, (2) qualitatively the analyses appear to have been performed competently, (3) the results show that no problem exists, and (4) no further action is needed.

Richard D. Silver

Richard D. Silver
Operating Reactors Branch #2
Directorate of Licensing

cc: AEC PDR
Local PDR
DJSkovholt, L:OR
TJCarter, L:OR
DLZiemann, L:ORB #2
RDSilver, L:ORB #2
RMDiggs, L:ORB #2
JPKnight, L:MEB

2623

Reg