



**Commonwealth Edison**  
 One First National Plaza, Chicago, Illinois  
 Address Reply to: Post Office Box 767  
 Chicago, Illinois 60690

**REGULATORY DOCKET FILE COPY**

Transmittal contains  
 Attachment C

June 30, 1978

*NON-PROP PORTIONS CONTROLLED &  
 DISTRIBUTED SEPARATELY*

*Rec'd  
 7/8/78*

Mr. George E. Lear, Chief  
 Operating Reactors - Branch 3  
 Division of Operating Reactors  
 U.S. Nuclear Regulatory Commission  
 Washington, DC 20555

Subject: Dresden Station Units 2 and 3  
 Quad-Cities Station Units 1 and 2  
 Evaluation of the Consequence of a  
 Multiple Subsequent Relief Valve  
 Discharge on the Mark I Containments  
NRC Docket Nos. 50-237/249 and 50-254/265

References (a): V. Stello, Jr. letter to Commonwealth  
 Edison dated March 20, 1978

(b): R. L. Bolger letter to D. K. Davis  
 dated November 1, 1978

Dear Mr. Lear:

Enclosed is Commonwealth Edison's evaluation of the potential for and consequence of multiple subsequent relief valve discharge on the torus and torus support systems on Dresden Units 2 & 3 and Quad-Cities Units 1 & 2. This evaluation provides the assessment requested in Reference (a). As described in Attachments A and B to this letter, transient analyses results for the subject plants indicate that only the low setpoint relief valve (setpoint - 1115 psig) will undergo a subsequent actuation. The remaining four valves do not undergo a subsequent actuation after the initial cold actuation. This result was described in Reference (b), at which time the commitment was made to reduce the setpoint of the lowest setpoint valve to 1115 psig. The factors developed to establish the response of the Dresden and Quad-Cities containments to a relief valve actuation are delineated in Attachment C.

Portions of Attachment C are marked "General Electric Company Proprietary Information" because it contains Monticello ramshead test data. This Attachment contains test data from the Monticello ramshead test report (NEDC-21581-P) which was transmitted to the NRC Staff on August 23, 1977. Therefore...

*A025  
 5/60\*  
 see  
 LIST*

Mr. George E. Lear:

- 2 -

June 30, 1978


the affidavit which accompanied that transmittal is applicable to the information in Attachment C.

The results of this assessment satisfy the criteria defined in Reference (a) and indicate that the strength ratios for the torus shell and torus support system are, as required, less than 0.5. For this reason no corrective action is required.

One (1) signed original and nine (9) copies of this letter and Attachments (including Attachment C) are provided for your use. An additional fifty (50) copies of this transmittal without Attachment C are also provided. Transmittals with Attachment C are appropriately marked.

Please direct any additional questions on this subject to this office.

Very truly yours,



M. S. Turbak  
Nuclear Licensing Administrator  
Boiling Water Reactors

attachments

DOCKET NO. 50-237/249/254/265  
DATE: 9-21-78

NOTE TO NRC AND/OR LOCAL PUBLIC DOCUMENT ROOMS

The following item submitted with letter dated 6-30-78  
from Commonwealth Edison of IL. is being withheld from  
public disclosure, pending review, in accordance with Section 2.790.

PROPRIETARY INFORMATION

Applicant's Evaluation of Potential for Consequence  
of Multiple subsequent Relief Valve discharge on  
the torus and torus support systems of subject facilities

Roland Wood  
016

Regulatory File Room

GENERAL ELECTRIC COMPANY  
PROPRIETARY INFORMATION

MARK I CONTAINMENT PROGRAM  
MULTIPLE CONSECUTIVE S/RV ACTUATION EVALUATION  
TASK 7.1.3

GENERIC STRUCTURAL MULTIPLIER DEVELOPMENT PROCEDURE

GENERAL ELECTRIC COMPANY  
PROPRIETARY INFORMATION

LEGAL NOTICE

This document contains proprietary information of the General Electric Company and it is not to be reproduced or furnished to third parties nor the information contained therein utilized, in whole or in part, without the prior express written permission of the General Electric Company.

Neither the General Electric Company nor any of the contributors to this document makes any warranty or representation (express or implied) with respect to the accuracy, completeness, or usefulness of the information contained in this document or that the use of such information may not infringe privately owned rights, nor do they assume any responsibility for liability or damage of any kind which may result from the use of any of the information contained in this document.

MARK I CONTAINMENT PROGRAM  
MULTIPLE CONSECUTIVE S/RV ACTUATION EVALUATION  
TASK 7.1.3

GENERIC STRUCTURAL MULTIPLIER DEVELOPMENT PROCEDURE

The following pages document the data base and methodology used in developing the recommended generic structural values to be used by the Utility/AE's in calculating column and shell loadings which result from the multiple consecutive S/RV actuation phenomenon. The generic values described were developed following the guidelines outlined in the NRC letter to the Mark I utilities requesting that this evaluation be performed on a plant unique basis.

Throughout the discussion which follows, references will be made to the Monticello, Hatch I, and Pilgrim S/RV tests. Data from these tests was used extensively in developing the structural and attenuation curves. The reports documenting this data base are identified in the reference section.

The continuing discussion will emphasize the development of the factors and attenuation curves derived to support the Utility/AE calculations. Each section will address a single factor or attenuation curve.

A. Torus Shell Structural Response Attenuation Curve

For the purpose of the shell stress analysis, the responses from the torus shell pressure transducers in Bay D at Monticello were evaluated as a function of the distance to the centerline of the discharge ram-head. The shell pressures were chosen as the evaluation parameter as it was the only test data reflecting the membrane stress in the torus shell. All of the strain gages in Bay D were on the outside surface of the

torus shell and recorded extreme fiber stresses only. As the key Short Term Program criteria is margin on failure, i.e., bursting of the shell, the attenuation response of the membrane stress was required. As the strain gages measured both the membrane and shell bending stresses, only the pressure transducers could be relied upon to truly indicate the membrane attenuation on the shell. Pressure transducers P7, P8, P10, P14, P17 and P18 located along the bottom centerline of the torus bay were selected for the evaluation. The pressure transducers on the bottom of the torus were chosen as the maximum hydrodynamic pressures occur along the bottom of torus shell due to a ramshead S/RV discharge. Six pressure transducers were assessed to factor pressure distribution, skewness, and statistical variation into the analysis. The locations of the pressure transducers are shown in Figure 1.

The mean plus one standard deviation of the pressures was tabulated for each test and normalized with the corresponding value of Test No. 1 (Discharge in Bay D). The responses were evaluated for the following tests:

| <u>Discharge Bay</u> | <u>Test Number</u> |
|----------------------|--------------------|
| D                    | 1 (Reference Test) |
| A                    | 4, 21              |
| B                    | 20, 24             |
| C                    | 2, 13, 17          |
| E                    | 22                 |
| F                    | 6, 23, 27          |

The normalized values for each of the tests were then averaged for the cases where the nominal distance between the discharge bays and bay D, the instrumented bay, were the same, i.e., values from discharges in bays C and E were averaged as were the values from bays B and F. The data and steps performed in this calculation are shown in Table 1. The normalized average values as a function of distance from bay D were then plotted. These results are shown in Figure 2.

As a confirmation of the applicability of the torus shell attenuation curve, multiplier factors were determined from the curve and compared.




FIGURE 1) - Location of Pressure Transducers P5 through P19 in Torus Pool

GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

| DISCHARGE BAY | TEST | PRESSURES - PSID |      |      |      |      |      | $\bar{X}$ | $\sigma$ | $\bar{X} + \sigma$ |
|---------------|------|------------------|------|------|------|------|------|-----------|----------|--------------------|
|               |      | TRANSDUCERS      |      |      |      |      |      |           |          |                    |
|               |      | 7                | 8    | 10   | 14   | 17   | 18   |           |          |                    |
| A             | 4    | 1.4              | 1.2  | 2.9  | 1.5  | 1.0  | 1.5  | 1.59      | .69      | 2.28               |
|               | 21   | 1.3              | 1.8  | 3.0  | -    | 1.0  | 1.0  |           |          |                    |
|               | AVE. | 1.35             | 1.5  | 2.95 | 1.5  | 1.0  | 1.25 |           |          |                    |
| B             | 20   | 1.0              | 1.1  | 1.7  | 0.8  | 0.9  | 1.0  | 1.29      | .60      | 1.89               |
|               | 24   | -                | 1.4  | 3.2  | -    | 1.0  | 1.6  |           |          |                    |
|               | AVE. | 1.0              | 1.25 | 2.45 | 0.8  | 0.95 | 1.3  |           |          |                    |
| C             | 2    | 4.2              | 3.6  | 5.3  | 3.0  | 1.3  | 2.0  | 3.53      | 1.52     | 5.05               |
|               | 13   | 4.3              | 5.1  | 6.2  | 3.0  | 2.3  | 2.6  |           |          |                    |
|               | 17   | 5.1              | 3.8  | 5.7  | 2.0  | 2.0  | 2.0  |           |          |                    |
|               | AVE. | 4.53             | 4.17 | 5.73 | 2.67 | 1.87 | 2.2  |           |          |                    |
| D             | 1    | 19.5             | 16.2 | 22.2 | 10.8 | 9.8  | 9.8  | 14.72     | 5.38     | 20.10              |
|               | 22   | 1.0              | 1.8  | 2.5  | -    | 0.6  | -    |           |          |                    |
|               | 6    | 2.0              | 1.3  | 2.3  | 2.0  | 0.9  | 2.0  |           |          |                    |
|               | 23   | -                | 1.7  | 1.8  | 1.1  | 1.0  | 1.0  |           |          |                    |
|               | 27   | 1.5              | 1.9  | 2.1  | -    | 1.0  | 1.2  |           |          |                    |
|               | AVE. | 1.75             | 1.63 | 2.07 | 1.55 | 0.97 | 1.40 | 1.56      | .37      | 1.93               |

NORMALIZED TO TEST NO. 1 :

$A/D = 0.11$

$B/D = 0.09$

$C/D = 0.25$


$E/D = 0.12$

$F/D = 0.11$

AVERAGING EQUIDISTANT DISCHARGES :  $(C/D + E/D)_{AVE} = 0.19$

$(B/D + F/D)_{AVE} = 0.10$

TABLE 1) - SHELL ATTENUATION DATA AND CALCULATIONS



to comparative multiplier factors derived from the shell stresses recorded during multiple valve actuation tests. The data, method, and results of this comparison are shown in Figure 3. The conclusion drawn from this comparison was that there was good correlation between the multiple valve discharge strain gage data and the pressure based attenuation curve. The small differences in the results were attributed to the fact that the gages measured both the membrane and shell bending stresses.

#### B) Torus Shell Reference Stress

The clean shell reference stress was determined using strain gage 18 located midbay, 45° up from the bottom, on the outside surface of bay D at Monticello. The maximum principal, extreme fiber, stress measured on SG18 during test No. 1 was 3400 psi. In bay C at Monticello, adjacent to bay D, strain gages were located at the bottom center of the bay both on the inside and outside surface of the shell. From these gages it was possible to establish a factor relating extreme fiber stress to membrane stress. This was done by plotting the outside fiber and membrane hoop stresses as a function of time and finding the outside fiber/membrane stress ratio at several points during the event history. See Figure 4. The mean of the outside fiber/membrane stress ratios was 1.17, indicating approximately 17% of the extreme fiber stress was due to bending of the shell. The same evaluation was performed on the longitudinal stresses and resulted in an outside fiber/membrane stress ratio of 1.26. See Figure 5. From this data an extreme fiber stress to membrane stress multiplier of .84 (1/1.17) was established.

During the Pilgrim SRV test there were strain gages located on the outside surface of the torus shell, midbay 45° up from bottom, SG18, and midbay on the bottom centerline, SG17. During the test, the maximum principal stress on SG18 was 3288 psi and on SG17 it was 4893 psi. By taking the ratio between the two principal stresses, a 1.49 shell stress factor is obtained when resolving stresses from 45° to the bottom centerline midbay.

The clean shell reference stress was derived from the Monticello SG18 stress, the outside fiber/membrane stress factor, and the 45° to bottom centerline factor as follows:

$$\sigma \text{ Ref. Clean Shell} = 3400 \text{ psi} \times .84 \times 1.49 = 4360 \text{ psi}$$

The  $\sigma$  Ref is the clean shell, midbay, bottom centerline reference stress for the Monticello Torus.

# GENERAL ELECTRIC COMPANY PROPRIETARY INFORMATION

RE STRAIN GAGE TEST DATA :

| DISCHARGE BAYS | TEST | CLEAN SHELL<br>MAX. PRINCIPAL STRESS |      |      | NORMALIZED TO<br>TEST NO. 1 |      |      | CLEAN SHELL<br>AVERAGE RATIOS |
|----------------|------|--------------------------------------|------|------|-----------------------------|------|------|-------------------------------|
|                |      | SG15                                 | SG18 | SG19 | SG15                        | SG18 | SG19 |                               |
| D              | 1    | 2433                                 | 3400 | 2281 | 1.0                         | 1.0  | 1.0  |                               |
| CDE            | 11   | 3609                                 | 4252 | 3743 |                             |      |      |                               |
| CDE            | 15   | 3403                                 | 5218 | 3441 |                             |      |      |                               |
| CDE            | AVE. | 3506                                 | 4735 | 3592 | 1.44                        | 1.39 | 1.57 | 1.46                          |
| DFG            | 10   | 2519                                 | 4553 | 2480 | 1.04                        | 1.34 | 1.09 |                               |
| CD             | 9    | 2660                                 | 4105 | 1795 |                             |      |      |                               |
| CD             | 18   | 4426                                 | 4443 | 3350 |                             |      |      |                               |
| CD             | AVE. | 3543                                 | 4274 | 2573 | 1.46                        | 1.26 | 1.13 | 1.16                          |
|                |      |                                      |      |      |                             |      |      | 1.28                          |

RE ATTENUATION CURVE, FIGURE 2 :

1) BAY CDE DISCHARGE

$$\begin{aligned} \text{CONTRIBUTION FROM BAY C (2 BAYS)} &= .19 \\ \text{CONTRIBUTION FROM BAY D (0 BAYS)} &= 1.00 \\ \text{CONTRIBUTION FROM BAY E (2 BAYS)} &= .19 \end{aligned}$$

$$\underline{\text{TOTAL BAYS C, D, E}} = \underline{1.38}$$

2) BAY DFG DISCHARGE

$$\begin{aligned} \text{CONTRIBUTION FROM BAY D (0 BAYS)} &= 1.0 \\ \text{CONTRIBUTION FROM BAY F (4 BAYS)} &= 0.11 \\ \text{CONTRIBUTION FROM BAY G (6 BAYS)} &= 0.10 \end{aligned}$$

$$\underline{\text{TOTAL BAYS DFG}} = \underline{1.21}$$

3) BAY CD DISCHARGE

$$\begin{aligned} \text{CONTRIBUTION FROM BAY C (2 BAYS)} &= .19 \\ \text{CONTRIBUTION FROM BAY D (0 BAYS)} &= 1.00 \end{aligned}$$

$$\underline{\text{TOTAL BAYS CD}} = \underline{1.19}$$

FIGURE 3) STRAIN GAGE VS. PRESSURE DATA COMPARISON

$$\bar{x} = 1.168, \sigma = .099, \frac{\sigma}{\bar{x}} \times 100 = 8.47\%$$

MONTICELLO TEST NO. 1




FIGURE 4) OUTSIDE FIBER/MEMBRANE HOOP STRESS TEST 1

GENERAL ELECTRIC COMPANY  
PROPRIETARY INFORMATION

$$\bar{X} = 1.264, \sigma = .222, \frac{\sigma}{\bar{X}} \times 100 = 17.6\%$$

MONTICELLO TEST NO. 1

AXIAL STRESS - OUTSIDE FIBER

ROSETTE 51




FIGURE 5) OUTSIDE FIBER / MEMBRANE LONGITUDINAL STRESS

GENERAL ELECTRIC COMPANY  
PROPRIETARY INFORMATION

C) Torus Shell Consecutive Valve Actuation, "Hot Pop", Factor

The shell consecutive valve actuation factor, CVA, was obtained by evaluating the Monticello torus shell response for Tests No. 702, 703, and 1602. Test No. 1603 was omitted on the basis that it was not representative as a result of the earthquake tie clearance being taken up. The responses from the clean shell midspan bay D strain gages 15, 18 and 19 were used to calculate the CVA factor. The mean plus one standard deviation of the responses of each of the gages for the three tests were computed and normalized to the corresponding responses from Test No. 1. The normalized values were then averaged to obtain the CVA. See Table 2 for data and calculations. The torus shell CVA factor calculated by this method is 2.37.

D) Torus Support Column Response Attenuation Curve

The maximum downward column loads on Monticello column D4 were averaged for similar tests and then normalized to the column load from Test No. 1. The normalized values for discharges nominally equidistant from the instrumented column were then averaged as described in the previous shell stress section. Figure 6 shows the results of plotting these normalized column loads as a function of distance from column D4 to the centerline of the discharge ramshead.

Column D4 is an outside column located in bay D. During the tests, data from 3 strain gages, each separated by 90° circumferentially around the column, was recorded. In evaluating the column loads, only SG65 and SG67, located 180° apart, were used to eliminate the effect of column bending and to measure column axial load only. The data and the column attenuation load calculations are shown in Table 3.

Column load data was also available from the Hatch I S/RV test. At Hatch I, the S/RV ramsheads are located midbay and on the ring girders. Tests were run with discharges from both locations. Column load attenuation responses for both discharge locations were calculated as described above and the data points were plotted on Figure 6. Note the attenuation curve developed from Monticello data bounds the Hatch I data points and supports the use of the Monticello derived curve for analysis purposes.


The reference column load to which the column attenuation curve is to be applied for midbay discharges was obtained from Monticello column D4 during Test No. 1 and was equal to 196.7 kips compression. By comparing the column load responses from the two Hatch S/RV tests, a ring girder to midbay column load factor of .84 was determined. Applying this factor to the Monticello reference column load produced a ring girder column reference load equal to  $196.7 \times .84 = 165.3$  kips compression.

GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

- 12 -

| <u>TEST<br/>NUMBER</u>         | <u>MAX. PRINCIPAL STRESS</u>       |                                     |                                    |
|--------------------------------|------------------------------------|-------------------------------------|------------------------------------|
|                                | SG 15                              | SG 18                               | SG 19                              |
| 1                              | 2433                               | 3400                                | 2281                               |
| 702                            | 4149                               | 5957                                | 3786                               |
| 703                            | 4344                               | 6878                                | 4610                               |
| 1602                           | 5944                               | 9066                                | 4512                               |
|                                | $\bar{X} = 4812$<br>$\sigma = 984$ | $\bar{X} = 7300$<br>$\sigma = 1596$ | $\bar{X} = 4302$<br>$\sigma = 450$ |
| $\bar{X} + \sigma$<br>RATIO    | 5796<br>2.32                       | 8896<br>2.62                        | 4752<br>2.1                        |
| <u>CVA = RATIO AVE. = 2.37</u> |                                    |                                     |                                    |

TABLE 2) TORUS SHELL CVA CALCULATION



GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

| DISCHARGE<br>BAY | TEST<br>NUMBER | COLUMN STRAINS $\mu\text{IN}/\text{IN}$ |      |         | DISTANCE<br>-BAYS- |
|------------------|----------------|---|------|---------|--------------------|
|                  |                | SG65                                    | SG67 | AVERAGE |                    |
| A                | 4              | -23                                     | 3    | -10     | 5 1/2              |
|                  | 21             | -28                                     | -3   | -16     |                    |
|                  | AVE.           |   |      | -13     |                    |
| B                | 20             | -15                                     | -7   | -11     | 3 1/2              |
|                  | 24             | -25                                     | -23  | -24     |                    |
|                  | AVE.           |   |      | -17.5   |                    |
| C                | 2              | -59                                     | -52  | -56     | 1 1/2              |
|                  | 13             | -109                                    | -94  | -102    |                    |
|                  | 17             | -103                                    | -92  | -98     |                    |
|                  | AVE.           |   |      | -85.33  |                    |
| D                | 1              | -113                                    | -128 | -121    | 1/2                |
| E                | 22             | -14                                     | -23  | -19     | 2 1/2              |
| F                | 6              | -20                                     | -11  | -16     | 4 1/2              |
|                  | 23             | -12                                     | -13  | -13     |                    |
|                  | 27             | -17                                     | -13  | -15     |                    |
|                  | AVE.           |   |      | -14.67  |                    |

NORMALIZED TO TEST NO 1 (BAY D)

$$\begin{aligned}
 A/D &= -13/-121 = .11 \\
 B/D &= -17.5/-121 = .15 \\
 C/D &= -85.33/-121 = .70 \\
 E/D &= -19/-121 = .15 \\
 F/D &= -14.67/-121 = .12
 \end{aligned}$$

TABLE 3) TORUS SUPPORT COLUMN ATTENUATION CURVE DATA

GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

The analysis of the Hatch S/RV test data used in this evaluation is enclosed in Attachment A.

E) Torus Support Column Consecutive Valve Actuation Factor

A procedure similar to that described above for the torus shell was applied to the column data. The maximum column compressive loads in column D4 (strain gages 65 and 67) were calculated for Tests 702, 703, and 1602. The mean plus one standard deviation of the maximum column loads for the 3 tests was then compared to the maximum compressive column load for Test No. 1. This procedure results in an overall CVA factor of 1.96 for the columns. The data and calculations for the column CVA factor are shown in Table 4.

GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

| STRAIN GAGE | COLUMN STRAINS $\mu\text{IN}/\text{IN}$ |          |           |
|-------------|---|----------|-----------|
|             | TEST 702                                | TEST 703 | TEST 1602 |
| G5          | -199                                    | -210     | -224      |
| G7          | -193                                    | -223     | -246      |
| AVE.        | -196                                    | -216.5   | -235      |

$\bar{X} = -215.833$   
 $\sigma = 19.5$   
 $\bar{X} - 1\sigma = -235.33$

$$\text{COLUMN CVA} = \frac{-235.33}{-120.5} = 1.96$$

TABLE 4) COLUMN CONSECUTIVE VALVE ACTUATION FACTOR


GENERAL ELECTRIC COMPANY  
 PROPRIETARY INFORMATION

## References

- 1) "Final Report, In-Plant Safety/Relief Valve Discharge Load Test - Monticello Plant", General Electric Co. Report NEDC-21581-P, Class III, August 1977.
- 2) "Preliminary Data From Pilgrim Unit 1 S/RV Test", Teledyne Engineering Services Technical Report No. TR-2682, August 19, 1977.
- 3) "Measurement of Structural Response of Mark I Torus Subjected to SRV Discharge Loads", Wyle Laboratories Report No. 43797-1, December 9, 1977, Prepared for Georgia Power Company (Hatch 1)

ATTACHMENT A - ANALYSIS OF HATCH I SRV TEST DATA

HATCH I SRV TEST INSTRUMENTATION



MIDBAY RAMSNEAD DISCHARGE

TEST SG

1 1 -1753 -2172 -2017 -1651 -1365

TIME - 2205 2210 2215 2220 2225

2 -2510 -3405 -3673 -3499 -3125

AVERAGE -2131 -2788 -2845 -2575 -2245

1 3 -1711 -2110 -1972 -1604 -1249

TIME - 2205 2210 2215 2220 2225

4 -2632 -3632 -3869 -3620 -3250

AVERAGE -2172 -2871 -2921 -2610 -2250

1 7 -39 -202 -318 -323 -158

TIME - 2205 2210 2215 2220 2225

8 -77 -222 -336 -277 -94

AVERAGE -58 -212 -327 -300 -126

1 10 +114 +279 +463 +540 +466

TIME - 2205 2210 2215 2220 2225

11 -78 -216 -419 -599 -708 max.

AVERAGE +18 +32 +22 -30 -121

ATTENUATION - MIDBAY DISCHARGE

$\frac{1}{2}$  BAY  $-2883 / -2883 = 1.0$

$\frac{2}{2}$  BAY  $-327 / -2883 = 0.113$

RINGGIRDER MIDBAY DISCHARGE

TEST SG

|         |   |       |       |              |       |       |
|---------|---|-------|-------|--------------|-------|-------|
| 2       | 7 | -1093 | -1581 | -1567        | -1316 | -1042 |
| TIME    | - | 2130  | 2135  | 2140         | 2145  | 2150  |
|         | 8 | -1949 | -2975 | -3261        | -3064 | -2745 |
| AVERAGE |   | -1521 | -2278 | <u>-2414</u> | -2190 | -1894 |

|         |    |       |       |       |              |       |
|---------|----|-------|-------|-------|--------------|-------|
| 2       | 10 | -1569 | -2468 | -3009 | -3198        | -2931 |
| TIME    | -  | 2130  | 2135  | 2140  | 2145         | 2150  |
|         | 11 | -606  | -715  | -713  | -711         | -553  |
| AVERAGE |    | -1088 | -1592 | -1861 | <u>-1955</u> | -1742 |

|         |   |      |      |      |      |             |
|---------|---|------|------|------|------|-------------|
| 2       | 3 | -56  | -139 | -280 | -316 | -349        |
| TIME    | - | 2130 | 2135 | 2140 | 2145 | 2150        |
|         | 4 | -49  | -146 | -266 | -335 | -414        |
| AVERAGE |   | -53  | -143 | -273 | -326 | <u>-382</u> |

|         |   |      |      |      |      |             |
|---------|---|------|------|------|------|-------------|
| 2       | 1 | +18  | +33  | -31  | -120 | -167        |
| TIME    | - | 2130 | 2135 | 2140 | 2145 | 2150        |
|         | 2 | -24  | -41  | -86  | -123 | -116        |
| AVERAGE |   | -3   | -4   | -59  | -122 | <u>-142</u> |

ATTENUATION - RINGGIRDER DISCHARGE

0 BAYS       $-2414 / -2414 = 1.0$   
 2 BAYS       $-273 / -2414 = .113$   
 3 BAYS       $-59 / -2414 = .025$

COMPARING OUTER COLUMN AXIAL LOADS FOR MIDBAY VERSUS  
RING GIRDER RAMBHEAD DISCHARGE

MIDBAY DISCHARGE

$$F_{COL 3} = -2845 *$$

\* UNITS IN PSI STRESS

$$F_{COL 4} = -2921$$

$$\text{AVERAGE} = -2883$$

RING GIRDER DISCHARGE

$$F_{COL 6} = -2414$$

$$\frac{\text{RING GIRDER}}{\text{MIDBAY}} \text{ FACTOR} = \frac{2414}{2883} = .84 \times 100 = \underline{\underline{84\%}}$$