

**From:** [Ramsey, Kevin](#)  
**To:** [Marcano, Jonathan](#); [Smith, April](#); [Adkins, Brannen](#); [Cuadrado-Caraballo, Leira](#); [Morie, Amaryl A](#); [Brown, Nicholas W](#); [Koch, Patrick](#)  
**Cc:** [Johnson, Robert](#)  
**Subject:** Final Summary of 5/4 Call w/NFS re: GL 2015-01  
**Date:** Wednesday, May 10, 2017 8:33:00 AM

---

On May 4, 2017, the following individuals participated in a call to discuss the additional information submitted by Nuclear Fuel Services (NFS) regarding Generic Letter 2015-01:

- Kevin Ramsey, NRC
- Leira Cuadrado, NRC
- Jonathan Marcano, NRC
- April Smith, NRC
- Patrick Koch, NRC
- Amaryl Morie, NFS
- Emily Senter, NFS
- Blaine Rice, NFS
- Sam Skiles, NFS
- Bob Mauer, NFS
- Nick Brown, NFS

NRC asked about the management measures for IROFS FIRE-8 and FIRE-17. NFS confirmed that Level A management measures are applied to those IROFS's.

NRC asked if there was any piping greater than 2 inches for hazardous material. NFS said no. All piping for hazardous material is less than 2 inches.

NRC asked if the piping modifications recommended by the contractor were being implemented. NFS said all recommendations are being processed through its Corrective Action Program. They plan to implement changes during outages in July and December.

NRC asked if calculations for column supports are available at the site. NFS said yes.

NRC noted that it is performing additional calculations for the glove boxes. Another call may be scheduled if a significant difference is identified. NRC believes it has the information it needs to complete the technical evaluation report. An inspection will be scheduled for the second or third week of July.

Kevin M. Ramsey  
Senior Project Manager  
Fuel Manufacturing Branch  
U.S. NRC  
301-415-7506