

Vogle PEmails

From: Hoellman, Jordan
Sent: Friday, May 12, 2017 9:23 AM
To: Stacy, Kara M.; 'THOMPSON, RYDER CLARK'
Cc: Rivera-Varona, Aida; Welch, Christopher; Haggerty, Neil; Woods, David F.
Subject: ICN and UIN Comment Status Sheet
Attachments: 2017-05-18 UIN ICN comment status sheet.docx

Hi Kara and Ryder –

Please see the attached ICN and UIN Comment Status Sheet. As previously discussed, we will plan to discuss the Vogtle Unit 3 UIN for ITAAC Index No. 109 (Item 1) and the proposed revision to the ICN for ITAAC Index No. 514 (Item 3) at a future public meeting once we have the licensee response and draft revision, respectively (tentatively planned for May 25, 2017).

Please let me know if there is anything on this status sheet that you would like to discuss at next week's public meeting (May 18, 2017).

Thank you,
Jordan

Jordan Hoellman
Project Manager
NRO / DNRL / LB4
U.S. Nuclear Regulatory Commission
office: TWFN 6-F33
phone: (301) 415-5481
email: Jordan.Hoellman2@nrc.gov

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 106

Mail Envelope Properties (530b650c6fa9466f821d009a769f0fcd)

Subject: ICN and UIN Comment Status Sheet
Sent Date: 5/12/2017 9:22:53 AM
Received Date: 5/12/2017 9:22:54 AM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:

"Rivera-Varona, Aida" <Aida.Rivera-Varona@nrc.gov>
Tracking Status: None
"Welch, Christopher" <Christopher.Welch@nrc.gov>
Tracking Status: None
"Haggerty, Neil" <X2NHAGGE@SOUTHERNCO.COM>
Tracking Status: None
"Woods, David F." <DFWOODS@southernco.com>
Tracking Status: None
"Stacy, Kara M." <KMSTACY@southernco.com>
Tracking Status: None
"THOMPSON, RYDER CLARK" <RYDER.THOMPSON@scana.com>
Tracking Status: None

Post Office: HQPWMSMRS03.nrc.gov

Files	Size	Date & Time
MESSAGE	808	5/12/2017 9:22:54 AM
2017-05-18 UIN ICN comment status sheet.docx		26746

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

ITEM #	ICN UIN	TOPIC	ITAAC INDEX #	ISSUE	Licensee Comment
1	UIN	Containment electrical penetrations	V3 109	<p>The UIN does not adequately describe which method of protection will be utilized. The Staff's comments on this UIN were previously provided.</p> <p>ACTION: Licensee respond to staff comments.</p>	

ITEM #	ICN UIN	TOPIC	ITAAC INDEX #	ISSUE	Licensee Comment
3	ICN	CI 1E equipment qualification for SWC, EMI, RFI, ESD	S2 514 S3 514	<p>SNC has informed NRC staff of their intent to withdraw and revise ICNs for ITAAC 514. The staff would like confirmation if SCE&G plans to withdraw and revise their ICNs for ITAAC 514.</p> <p>ACTION: SCE&G confirm whether or not they intend to withdraw the ICNs for Unit 2 and 3 ITAAC 514.</p>	

ITEM #	ICN UIN	TOPIC	ITAAC INDEX #	ISSUE	Licensee Comment
4	ICN	FHS RM, FHM and Racks	V3 2	<p>This ITAAC has been submitted prematurely. The component currently do not exist in the plant. ITAAC are intended to verify the as-built facility. This ITAAC was completed based upon document reviews.</p> <p>Action: Licensee to respond to comment</p>	

ITEM #	ICN UIN	TOPIC	ITAAC INDEX #	ISSUE	Licensee Comment
5	UIN	Functional arrangement of seismic monitoring equipment	V3 575	<p data-bbox="680 191 1472 293">Similar to the other FA comments, the IDB does not tie back to the definition of FA (i.e. the components are arranged to provide the service intended).</p> <p data-bbox="680 386 1163 412">Action: Licensee to respond to comment</p>	