

Traveler	Status	Purpose	Priority
TSTF-566, "Revise Actions for Inoperable RHR-SDC Subsystems" (3Q2017)	OG review complete. Revising to address comments.	Address two URIs and delta between TS and BWR design.	M
Westinghouse Hot Channel Factor Traveler based on Topical Report WCAP-17661 (3Q2017)	Final SE received. Discuss need for traveler with NRC.	Addresses nonconservative TS.	M
Revise NUREG-1431 & NUREG-1432 Definition of Response Time Testing (3Q2017)	Scoping meeting with NRC held in January 2016.	Supports PWROG project on obsolete components	H
TSTF-564, "Safety Limit Minimum Critical Power Ratio (SL MCPR)" (3Q2017)	Presubmittal meeting held November 2016. NRC questions being addressed.	Eliminate need for cycle-specific, short-turnaround LARs.	H
NEI TR on spent fuel pool neutron adsorber and conforming changes (4Q2017)	The final SE on the NEI topical report has been received.	Provide a model program for plants revising their spent fuel pool requirements.	L
TSTF-568, "Clarify Applicability of BWR/4 TS 3.6.2.5 and TS 3.6.3.2" (4Q2017)	Preparing traveler draft for BWROG review.	NRC request to clarify the Applicability.	L
TSTF-505 Companion Traveler to Address Loss-of-Function (4Q2017)	On hold until after near-term issues resolved	NRC will not allow loss-of-function RICTs without changes.	H