

Proposed Agenda for BWROG/PWROG/Flowserve Teleconference

Introductions and Roll Call – NRR/DPR	5 minutes
Purpose and Objective of Call – NRR/DE	5 minutes
<ul style="list-style-type: none">• Provide information on recent observations related to Anchor/Darling Double Disc Gate Valves• Gain better understanding of industry actions in response to Part 21	
Review of LaSalle Event/Preliminary Observations – Region III	15 minutes
Industry Perspectives - BWROG/PWROG/Flowserve	30 minutes
<ol style="list-style-type: none">1. What guidance has been provided to group members/customers in response to the TVA and Flowserve Part 21s and are there plans to update this guidance?2. Based on your understanding of the progression of valve failure, operating experience, and available data, provide your perspectives on the following:<ol style="list-style-type: none">a. The use of stem rotation checks to demonstrate valve functionality.b. The use of motor operated valve diagnostic testing (e.g., stem strain measurement traces) to demonstrate valve functionality3. Do current methods (and supporting data) for addressing the Part 21s ensure full stem thread engagement for the valves within scope of the Part 21s.4. Are there other diagnostic tests or methods that can be used to demonstrate functionality for valves within the scope of the Part 21s?5. Is there other available operating experience associated with follow-up to the Part 21s (e.g., experience with valve inspection)	
Summary – NRR/DPR	5 minutes