

WOLF CREEK

NUCLEAR OPERATING CORPORATION

May 9, 2017

Cynthia R. Hafenstine
Manager Nuclear and Regulatory Affairs

RA 17-0063

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Docket No. 50-482: Summary of Changes to a Procedure that Implements the Wolf Creek Generating Station (WCGS) Radiological Emergency Response Plan (RERP)

To Whom It May Concern:

One procedure that implements the WCGS RERP has been revised. The revised document is identified below:

<u>Procedure</u>	<u>Effective Date</u>
AP 06-004, Rev. 5	May 2, 2017

The attached summary of the changes to the implementing procedure explains that these changes do not reduce the effectiveness of the WCGS RERP. This letter contains no commitments. If you have any questions concerning this matter, please contact me at (620) 364-4204.

Sincerely,



Cynthia R. Hafenstine

CRH/rit

Attachment

cc: K. M. Kennedy (NRC), w/a
B. K. Singal (NRC), w/a
N. H. Taylor (NRC), w/a
Senior Emergency Preparedness Inspector (NRC), w/a
Senior Resident Inspector (NRC), w/a

P.O. Box 411 / Burlington, KS 66839 / Phone: (620) 364-8831

An Equal Opportunity Employer M/F/H/VET

AX45
NRR

Summary of Changes to One Procedure that Implements the Wolf Creek Generating Station (WCGS) Radiological Emergency Response Plan (RERP)

1. Procedure AP 06-004, "Equipment Important to Emergency Response," Rev. 5

The thermocouple subcooling monitor cabinets, asset numbers RP081A and RP081B, have been added to the table of Equipment Important to Emergency Response on page 10 of 22 in Attachment C to procedure AP 06-004. Monitoring of the core exit thermocouples (CETs) has been added as an additional compensatory measure for the containment high range area radiation monitors, asset numbers GTRE0059 and GTRE0060, on pages 6 of 22 and 7 of 22 in Attachment C to procedure AP 06-004.

Additional editorial changes were made to change "HP" to "RP" throughout the procedure, correct spelling errors and restore notes to Figure 2, which were inadvertently deleted in a previous revision. The changes to procedure AP 06-004 support accurate identification and implementation of compensatory measures for equipment important to emergency response and the restoration of that equipment. Therefore, these changes do not reduce the effectiveness of the WCGS RERP.