

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 821-5151

JUN 12 1979

Mr. Boyce H. Grier
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Ave.
King of Prussia, PA 19406

Document Nos. 50-387
50-388

SUSQUEHANNA STEAM ELECTRIC STATION
IE BULLETIN NO. 79-09
ER 100450 FILE 840-4
PLA-367

Dear Mr. Grier:

In response to IE Bulletin 79-09, Pennsylvania Power and Light Company has reviewed the Susquehanna equipment and has determined that G.E. Type AK-2 breakers are utilized in safety-related 125V DC and 250V DC load centers but without the under-voltage trip device.

PP&L presently has identified a set of activities that will be incorporated into the plant preventive maintenance program. These activities will be implemented prior to fuel load.

Very truly yours,



N. W. Curtis
V.P.-Engr & Construction

SK:CAW

Copy to:
R. M. Gallo NRC

7907260192



IN THE