

APPENDIX A

NOTICE OF VIOLATION

Pennsylvania Power and Light Company

Docket No. 50-387

This refers to the inspection conducted by a representative of the Region I (Philadelphia) office at the Susquehanna Steam Electric Station, Berwick, Pennsylvania, of activities authorized by NRC License No. CPPR-101.

During this inspection conducted on June 18-29 and July 9-27, 1979, the following apparent item of noncompliance was identified.

10 CFR 50, Appendix B, Criterion V, states, in part: "Activities affecting quality...shall be accomplished in accordance with these instructions, procedures or drawings...."

The Susquehanna PSAR Section D.2.5 states, in part: "Activities affecting quality will be prescribed by documented instructions, procedures or drawings appropriate to the circumstances."

Bechtel Field Procedure FP-G-4, Revision 11 Section 3.3.3 states, in part, "Individuals requiring additional drawings/documents for construction or inspection may be issued prints identified as "Production Prints" in approximately half-inch high letters."

Contrary to the above, as of July 12, 1979, vendor drawings used for construction of the Refueling Platform were not identified as "Production Prints".

This item is an Infraction.



2