

CENTRAL FILES

PP&L

8005050361

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 821-5151

A012

March 31, 1980

Mr. Boyce H. Grier
Director, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


SUSQUEHANNA STEAM ELECTRIC STATION
IE BULLETIN 79-28
ER 100450 FILE 840-4
PLA-465

DOCKET NOS. 50-387
50-388

Dear Mr. Grier:

Please refer to Pennsylvania Power & Light Company letter No. PLA-449 dated February 11, 1980 concerning IE Bulletin 79-28. We have determined that the subject NAMCO Model EA180 Limit Switches with date codes between 02-79 and 08-79 are utilized in safety-related applications at Susquehanna SES. The top gasket of these switches will be replaced in accordance with the bulletin's required corrective action prior to fuel load.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction

SK:AAW
SK#149

Copy to:
R.M.Gallo-NRC Susq. SES

