

ATTACHED IS A PART 21 REPORT FROM IE MAIL UNIT - ROOM 359E/W

50-381

PART 21 IDENTIFICATION NO. 80-195-006 COMPANY NAME American Warming
DATE OF LETTER 5/14/80 DOCKET NO. Susquehanna J Ventilating
DATE DISTRIBUTED 5/20/80 ORIGINAL REPORT SUPPLEMENTARY
Doc.

DISTRIBUTION:

REACTOR(R)

FUEL CYCLE &

SAFEGUARDS(S)

MATERIALS(M)

NRR/DOR, DIRECTOR (2)

AD/FFMSI

AD/SG-IE

NRR/DPM DIRECTOR (2)

NMSS/FCMS

AD/ROI

AD/ROI (2)

REGIONS

REGIONS

AD/RCI

IE FILES

NRR/DOR, DIRECTOR

REGIONS

PDR

NMSS/SG SS-881

IE FILES

LPDR

PDR

CENTRAL FILES

CENTRAL FILES-SS-396

LPDR

~~CENTRAL FILES (CHRON)~~

CENTRAL FILES(CHRON)
(016)

TERA

PDR

TERA

IE FILES (2)

LPDR

CENTRAL FILES 016

TERA

LOEB/MPA MNB 5715

CENTRAL FILES (CHRON)

LOEB/MPA MNB 5715

AEOD - MNB-7602

CENTRAL FILES - SS-396

AEOD MNB-7602

LOEB/MPA MNB 5715

AEOD MNB-7602

ACTION:

PRELIMINARY EVALUATION OF THE ATTACHED REPORT INDICATES LEAD RESPONSIBILITY FOR FOLLOW-UP AS SHOWN BELOW:

IE

NRR

NMSS

OTHER

RCI
ROI
SG
FFMSI

REV.



SECRET

american warming
and ventilating inc

MA/4

May 14, 1980

80-195-006

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

✓ 50-387
50-388

Attn: Director, Office of Inspection
and Enforcement

From: American Warming & Ventilating, Inc.
1310 Indian Wood Circle
Maumee, Ohio 43537

Subject: 10 CFR 21 Notification Dated February 6, 1980

Reference: Bechtel Corp. (San Francisco)
Susquehanna Steam Elec. Sta. Units 1 & 2
AWV Job No. 90125

Gentlemen:

AWV has determined that the ITT General Controls NH90 Series Actuator supplied on AWV dampers, to the Susquehanna jobsite, all meet the damper required thrust and corresponding specified safety factor. This determination is based on review of the one hundred percent testing, at 1.5 times both flow and pressure, performed by AWV on this equipment.

Due to this fact the Susquehanna Project is hereby cleared of the Subject 10 CFR 21 by AWV.

Very truly yours,

Donald E. Sloan
Donald E. Sloan
Quality Assurance Manager

cc: W.B.B., R.L.B., R.L.A., J.M.T.,
R.J.M., D.S.L., S.F.G., D.W.L.

P. O. BOX 279
1310 INDIAN WOOD CIRCLE
MAUMEE, OHIO 43537
(419) 893-5011

AMCA MEMBER



