

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 821-5151

A012

NORMAN W. CURTIS
Vice President-Engineering & Construction
821-5381

AUG 15 1980

Mr. Boyce H. Grier
Director, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406


Docket Nos. 50-387
50-388

SUSQUEHANNA STEAM ELECTRIC STATION
IE BULLETIN NO. 79-03A
ER 100450 FILE 840-4
PLA-528

Dear Mr. Grier:

In response to the revised action required by IE Bulletin No. 79-03A, Pennsylvania Power & Light Company has determined that there is no ASME SA-312 or A-312, Type 300 Series fusion welded pipe planned for use in safety-related systems which will be subjected to design stresses greater than 85 percent of the Code allowable stresses.

Very truly yours,



N. W. Curtis
Vice President-Engineering and Construction

cc: Office of Inspection and Enforcement
Division of Reactor Construction Inspection
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. R. M. Gallo
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, Pennsylvania 18655

8009090036

Q

R