

CENTRAL FILES



TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

JAN 14 1981

Mr. Boyce H. Grier, Director
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406



SUSQUEHANNA STEAM ELECTRIC STATION
IE BULLETIN 80-21
ER 100450 FILE 841-4
PLA-612

Docket Nos. 50-387
And 50-388

Dear Mr. Grier:

The following information is provided in response to IE Bulletin 80-21,
"Valve Yokes Supplied by Malcolm Foundry Company, Inc."

IE Bulletin actions to be taken (CP):

1. Malcolm Foundry Company, Inc. supplied 154 yokes to Anchor Darling Valves for use at Susquehanna SES. Identification of other uses of valve parts cast by Malcolm Foundry Company, Inc. has not been completed.
2. Not applicable to SSES.
3. Testing of sample valve yokes indicates that none of these have mechanical properties in accordance with the ASTM material specification. All 154 valve yokes will be replaced prior to fuel load.

A complete response including estimates of manpower expended will be provided by February 16, 1981.

Very truly yours,
NW Curtis

N. W. Curtis

RMH:jmr

8102180895

Q

Kor



JAN 14 1981

cc: Director
Division of Reactor Construction Inspection
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. R. M. Gallo
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Mr. Lou Narrow
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

