


PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 821-5151

NORMAN W. CURTIS
 Vice President-Engineering & Construction
 821-5381

MAY 12 1981



Mr. Boyce H. Grier, Director
 Region I
 U.S. Nuclear Regulatory Commission
 631 Park Avenue
 King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
 IE BULLETIN 81-01 REVISION 1
 ER 100450 FILE 842-3
 PLA-767

DOCKET NOS. 50-387
 AND 50-388

The following information is provided in response to IE Bulletin 81-01, Revision 1, "Surveillance of Mechanical Snubbers."


IE Bulletin actions to be taken (CP):

1. Following individual final piping walkdown inspections and prior to initial criticality, the safety-related snubbers that require surveillance testing in accordance with Technical Specifications Section 4.7 will be examined and tested as follows:
 - a) Visual inspections for damage; manual tests to verify function of movement over the range of stroke in both compression and tension.
 - b) INC snubbers are not used at Susquehanna SES.
 - c) Corrective actions will be completed prior to initial criticality.
2. Inspections and tests will follow the individual final piping system inspection when the completeness and correctness of each snubber on the system is verified. All inspections and tests will be completed prior to initial criticality. A report will be submitted to NRC within 30 days after completion of all inspections and tests.

Handwritten initials: H62

81060.40485

Handwritten letter: Q



Mr. Boyce H. Grier

Page 2

MAY 12 1981

This time frame is different from that proposed in the bulletin, but it meets the intent of the bulletin and best reflects the phases of testing conducted at Susquehanna SES. Demonstration of snubber operability can only be conducted after verification of snubber installation, which occurs during the final piping system inspection. This inspection normally occurs after system preoperational testing is completed. Until initial criticality, no heat source is available and no significant thermal expansion occurs. Since there is no fission product inventory, a snubber failure prior to initial criticality would have no safety implications. Therefore, completion of inspections and tests prior to fuel load is not necessary; completion prior to initial criticality is adequate.

Required affidavits and estimates of manpower expended will be provided with the final report.

Very truly yours,



N. W. Curtis

Vice President-Engineering & Construction-Nuclear

RMH/mks

cc: Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. G. Rhoads
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Mr. L. D. Narrow
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

