

JUN 29 1981

DISTRIBUTION


Docket Nos. 50-387  
and 50-388

Docket  
NRC PDR  
Local PDR  
TERA  
NSIC  
LB#2 Reading  
ASchwencer  
RStark  
MService  
OELD  
OI&E(3)  
ACRS(16)

Mr. Norman W. Curtis  
Vice President - Engineering & Construction  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

Subject: Request for Additional Information



As a result of our status review of your Susquehanna Steam Electric Station Units 1 and 2 FSAR, we have determined that there are a number of review matters still outstanding which require additional information in order for us to complete our evaluation. A list of the review areas for which this information is required is provided in the Enclosure. The specific information required has been discussed with your representatives.

To maintain our licensing review schedule for the Susquehanna Steam Electric Station, Units 1 and 2, it is requested that you inform us within ten (10) days after receipt of this letter of your schedule of when you plan to submit your responses to our request for additional information. We urge your prompt consideration of this matter since it directly affects the licensing actions for your plant.

Should you have any questions on these matters, contact the licensing project manager.

Sincerely,

Original signed by  
Robert L. Tedesco

Robert L. Tedesco, Assistant Director  
for Licensing  
Division of Licensing

Enclosure:  
Request for Additional  
Information

cc w/encl:  
See next page

APP 3

OFFICE	DL:LB#2	DL:LB#	DL:				
SURNAME	RStark:lb	ASchwencer	RL Tedesco				
	6/25/81						

B107170262 B10629  
PDR ADDCK 05000387  
A PDR

OFFICIAL RECORD COPY

USGPO: 1981-335-960

17.

12 26

1931 12 26

1931 12 26

Mr. Norman W. Curtis  
Vice President - Engineering  
and Construction  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

cc: Mr. Earle M. Mead  
Project Engineering Manager  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Jay Silberg, Esq.  
Shaw, Pittman, Potts &  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. William E. Barberich,  
Nuclear Licensing Group Supervisor  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Edward M. Nagel, Esquire  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Bryan Snapp, Esq.  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Robert M. Gallo  
Resident Inspector  
P. O. Box 52  
Shickshinny, Pennsylvania 18655

John L. Anderson  
Oak Ridge National Laboratory  
Union Carbide Corporation  
Bldg. 3500, P. O. Box X  
Oak Ridge, Tennessee 37830

Gerald R. Schultz, Esq.  
Susquehanna Environmental Advocates  
P. O. Box 1560  
Wikes-Barre, Pennsylvania 18703

Mr. E.B. Poser  
Project Engineer  
Bechtel Power Corporation  
P. O. Box 3965  
San Francisco, California 94119

Matias F. Travieso-Diaz, Esq.  
Shaw, Pittman, Potts &  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Dr. Judith H. Johnsrud  
Co-Director  
Environmental Coalition on  
Nuclear Power  
433 Orlando Avenue  
State College, Pa 16801

Mr. Thomas M. Gerušky, Director  
Bureau of Radiation Protection  
Department of Environmental  
Resources  
Commonwealth of Pennsylvania  
P. O. Box 2063  
Harrisburg, Pa 17120

Ms. Colleen Marsh  
Box 538A, RD#4  
Mountain Top, PA 18707

Mr. Thomas J. Halligan  
Correspondent  
The Citizens Against Nuclear  
Danagers  
P. O. Box 5  
Scranton, Pennsylvania 18501

Mr. J.W. Millard,  
Project Manager  
Mail Code 394  
General Electric Company  
175 Curtner Avenue  
San Jose, California 95125

Robert W. Adler  
Dept. of Environmental Resources  
505 Executive House  
P. O. Box 2357  
Harrisburg, Pennsylvania 15120

SUSQUEHANNA OL APPLICATION  
AREAS WITH IDENTIFIED ITEMS REQUIRING ADDITIONAL  
INFORMATION FROM APPLICANT FOR STAFF TO COMPLETE ITS REVIEW

(Does not include items of a confirmatory nature or areas where the staff review of available information is not complete).

AREA

- . Make environmental qualification records on electrical equipment available for NRC audit.
- . Submit additional information on emergency plans.
- . Submit additional information on emergency facilities.
- . Participate in an emergency plan drill so that it can be evaluated by FEMA
- . Provide response to concerns of IE Bulletin 79-27 on Loss of Power to I&C systems
- . Commit to and modify the plant to provide emergency power to the pump seals (II.K.3.25)
- . Demonstrate steam bypass capability of the suppression pool
- . Provision for a common reference level for level instrumentation (II.K.3.27)
- . Submit additional information on operator requalification
- . Clarify alternate shutdown capability (alternate shutdown panel).