

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8203010089 DOC. DATE: 82/02/23 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 CURTIS, N.W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Advises of slight increase in peak drywell pressure during DBA due to capping of five vacuum breaker downcomers & revised load line limit analysis. Type A, B & C leak rate tests will be effected.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: I&E: 3 copies FSAR & all amends. LPDR: 2 cys 05000387  
 I&E: 3 copies FSAR & all amends. LPDR: 2 cys 05000388

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME	LTTR
	A/D LICENSNG		1	0	LIC BR #2 BC	1	0
	LIC BR #2 LA		1	0	PERCH, R. 01	1	1
INTERNAL:	ELD		1	0	IE 06	3	3
	IE/DEP/EPDB 35		1	1	IE/DEP/EPLB 36	3	3
	MPA		1	0	NRR/DE/CEB 11	1	1
	NRR/DE/EQB 13		3	1	NRR/DE/GB 28	2	2
	NRR/DE/HGEB 30		2	2	NRR/DE/MEB 18	1	1
	NRR/DE/MTEB 17		1	1	NRR/DE/QAB 21	1	1
	NRR/DE/SAB 24		1	1	NRR/DE/SEB 25	1	1
	NRR/DHFS/HFEB 40		1	1	NRR/DHFS/LQB 32	1	1
	NRR/DHFS/OLB 34		1	1	NRR/DHFS/PTRB20	1	1
	NRR/DSI/AEB 26		1	1	NRR/DSI/ASB 27	1	1
	NRR/DSI/CPB 10		1	1	NRR/DSI/CSB 09	1	1
	NRR/DSI/ETSB 12		1	1	NRR/DSI/ICSB 16	1	1
	NRR/DSI/PSB 19		1	1	NRR/DSI/RAB 22	1	1
	NRR/DSI/RSB 23		1	1	NRR/DST/LGB 33	1	1
	<del>REG FILE</del> 04		1	1			
EXTERNAL:	ACRS 41		16	10	BNL (AMDTS ONLY)	1	1
	FEMA-REP DIV 39		1	1	LPDR 03	2	2
	NRC PDR .02		1	1	NSIC 05	1	1
	NTIS		1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR

64  
63 ENCL 56

JW

Faint, illegible text at the top of the page, possibly a header or title area.

Section 1

Main body of faint, illegible text, appearing to be a list or series of entries.




**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215 / 770-5381

FEB 23 1982



Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
TYPE A, B AND C INTEGRATED AND LOCAL  
LEAK RATE TESTING  
ER 100450 FILE 172-M-149  
PLA-1016

DOCKET NOS. 50-387  
50-388

Dear Mr. Schwencer:


Recently, we completed the capping of the five (5) vacuum breaker downcomers. As a result, there are now 82 downcomers instead of 87 downcomers available for steam flow into the suppression pool. This change, coupled with a revised Load Line Limit Analysis results in a slight increase in the peak drywell pressure during a DBA. Our preliminary estimates indicate an increase of approximately 3 psig. This would increase the present peak drywell pressure of Pa = 43.8 psig to approximately 47.0 psig. This compares with a containment design pressure of 53 psig. Those are preliminary conservative estimates which will be confirmed in the near future. We plan to revise the FSAR and DAR to reflect these revised transient curves when the analysis is finalized.

Although this increase in pressure does not compromise the containment design, it will effect the Type A, B and C leak rate tests, since these test procedures were prepared assuming Pa = 43.8 psig. Per our discussions with the NRC staff, the effects on these tests will be accounted for as follows:

- The Type B and C penetrations which have already been leak tested based on Pa = 43.8 psig will not be retested for the higher peak containment pressure. For these penetrations, the measured leak rate based on the lower value of 43.8 psig will be increased to reflect the higher peak containment pressure. The measured leak rate will be multiplied by the square root of the ratio of the revised peak pressure to the original peak pressure.

*3001  
S/10*

8203010087 820223  
PDR ADOCK 05000387  
A PDR



Mr. A. Schwencer  
PLA-1016

Page 2  
FEB 23 1982

The revised peak pressure to be used for this increase will be 43.8 psig (original peak pressure) + 3 psig (expected increase) + 1 psig (conservatism) which is approximately equal to 48 psig. Thus the multiplier becomes  $\sqrt[3]{48/43.8} = 1.047$ . The revised peak containment pressure of 48 psig will be verified as conservative when the revised transient curves are available.

- The Type A Integrated Leak Rate Test will be performed at a revised pressure of 48. psig.

If you have any questions, please contact us.

Very truly yours,



N. W. Curtis  
Vice President-Engineering and Construction-Nuclear

CTC/mjm

cc: R. Perch      NRC



THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

PHYSICS 309

1

2

3