

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8206040355 DOC. DATE: 82/06/01 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Responds to NRC 820330, re: natural gas pipeline in vicinity of facility. Location acceptable assuming flow restrictive device is used in gas line.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR ENCL SIZE: 9
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	A/D LICENSG	LTR	ENCL		ID CODE/NAME	LTR	ENCL	
	LIC BR #2 LA		1	0	LIC BR #2 BC		1	0	
			1	0	PERCH, R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEP EPDS 35		1	1	IE/DEP/EPLB 36		3	3	
	MPA		1	0	NRR/DE/CEB 11		1	1	
	NRR/DE/EQB 13		3	3	NRR/DE/GB 28		2	2	
	NRR/DE/HGEB 30		2	2	NRR/DE/MEB 18		1	1	
	NRR/DE/MTEB 17		1	1	NRR/DE/QAB 21		1	1	
	NRR/DE/SAB 24		1	1	NRR/DE/SEB 25		1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB 32		1	1	
	NRR/DHFS/OLB 34		1	1	NRR/DHFS/PTRB20		1	1	
	NRR/DSI/AEB 26		1	1	NRR/DSI/ASB 27		1	1	
	NRR/DSI/CPB 10		1	1	NRR/DSI/CSB 09		1	1	
	NRR/DSI/ETSB 12		1	1	NRR/DSI/ICSB 16		1	1	
	NRR/DSI/PSB 19		1	1	NRR/DSI/RAB 22		1	1	
	NRR/DSI/RSB 23		1	1	NRR/DST/LGB 33		1	1	
	<u>REG FILE</u> 04		1	1	RGN1		2	2	
EXTERNAL:	ACRS 41		10	10	BNL (AMDTS ONLY)		1	1	
	FEMA-REP DIV 39		1	1	LPDR 03		2	2	
	NRC PDR 02		1	1	NSIC 05		1	1	
	NTIS		1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 58 ENCL 53

CONFIDENTIAL
This document contains information that is classified as CONFIDENTIAL. It is intended for the use of authorized personnel only. It is not to be distributed, disseminated, or otherwise made available to the public or other personnel who do not have a valid "need to know" without the express written approval of the appropriate authority.

CONFIDENTIAL
This document contains information that is classified as CONFIDENTIAL. It is intended for the use of authorized personnel only. It is not to be distributed, disseminated, or otherwise made available to the public or other personnel who do not have a valid "need to know" without the express written approval of the appropriate authority.

CONFIDENTIAL
This document contains information that is classified as CONFIDENTIAL. It is intended for the use of authorized personnel only. It is not to be distributed, disseminated, or otherwise made available to the public or other personnel who do not have a valid "need to know" without the express written approval of the appropriate authority.

CONFIDENTIAL

CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL
1	CONFIDENTIAL	2	CONFIDENTIAL
2	CONFIDENTIAL	3	CONFIDENTIAL
3	CONFIDENTIAL	4	CONFIDENTIAL
4	CONFIDENTIAL	5	CONFIDENTIAL
5	CONFIDENTIAL	6	CONFIDENTIAL
6	CONFIDENTIAL	7	CONFIDENTIAL
7	CONFIDENTIAL	8	CONFIDENTIAL
8	CONFIDENTIAL	9	CONFIDENTIAL
9	CONFIDENTIAL	10	CONFIDENTIAL
10	CONFIDENTIAL	11	CONFIDENTIAL
11	CONFIDENTIAL	12	CONFIDENTIAL
12	CONFIDENTIAL	13	CONFIDENTIAL
13	CONFIDENTIAL	14	CONFIDENTIAL
14	CONFIDENTIAL	15	CONFIDENTIAL
15	CONFIDENTIAL	16	CONFIDENTIAL
16	CONFIDENTIAL	17	CONFIDENTIAL
17	CONFIDENTIAL	18	CONFIDENTIAL
18	CONFIDENTIAL	19	CONFIDENTIAL
19	CONFIDENTIAL	20	CONFIDENTIAL
20	CONFIDENTIAL	21	CONFIDENTIAL
21	CONFIDENTIAL	22	CONFIDENTIAL
22	CONFIDENTIAL	23	CONFIDENTIAL
23	CONFIDENTIAL	24	CONFIDENTIAL
24	CONFIDENTIAL	25	CONFIDENTIAL
25	CONFIDENTIAL	26	CONFIDENTIAL
26	CONFIDENTIAL	27	CONFIDENTIAL
27	CONFIDENTIAL	28	CONFIDENTIAL
28	CONFIDENTIAL	29	CONFIDENTIAL
29	CONFIDENTIAL	30	CONFIDENTIAL
30	CONFIDENTIAL	31	CONFIDENTIAL
31	CONFIDENTIAL	32	CONFIDENTIAL
32	CONFIDENTIAL	33	CONFIDENTIAL
33	CONFIDENTIAL	34	CONFIDENTIAL
34	CONFIDENTIAL	35	CONFIDENTIAL
35	CONFIDENTIAL	36	CONFIDENTIAL
36	CONFIDENTIAL	37	CONFIDENTIAL
37	CONFIDENTIAL	38	CONFIDENTIAL
38	CONFIDENTIAL	39	CONFIDENTIAL
39	CONFIDENTIAL	40	CONFIDENTIAL
40	CONFIDENTIAL	41	CONFIDENTIAL
41	CONFIDENTIAL	42	CONFIDENTIAL
42	CONFIDENTIAL	43	CONFIDENTIAL
43	CONFIDENTIAL	44	CONFIDENTIAL
44	CONFIDENTIAL	45	CONFIDENTIAL
45	CONFIDENTIAL	46	CONFIDENTIAL
46	CONFIDENTIAL	47	CONFIDENTIAL
47	CONFIDENTIAL	48	CONFIDENTIAL
48	CONFIDENTIAL	49	CONFIDENTIAL
49	CONFIDENTIAL	50	CONFIDENTIAL
50	CONFIDENTIAL	51	CONFIDENTIAL
51	CONFIDENTIAL	52	CONFIDENTIAL
52	CONFIDENTIAL	53	CONFIDENTIAL
53	CONFIDENTIAL	54	CONFIDENTIAL
54	CONFIDENTIAL	55	CONFIDENTIAL
55	CONFIDENTIAL	56	CONFIDENTIAL
56	CONFIDENTIAL	57	CONFIDENTIAL
57	CONFIDENTIAL	58	CONFIDENTIAL
58	CONFIDENTIAL	59	CONFIDENTIAL
59	CONFIDENTIAL	60	CONFIDENTIAL
60	CONFIDENTIAL	61	CONFIDENTIAL
61	CONFIDENTIAL	62	CONFIDENTIAL
62	CONFIDENTIAL	63	CONFIDENTIAL
63	CONFIDENTIAL	64	CONFIDENTIAL
64	CONFIDENTIAL	65	CONFIDENTIAL
65	CONFIDENTIAL	66	CONFIDENTIAL
66	CONFIDENTIAL	67	CONFIDENTIAL
67	CONFIDENTIAL	68	CONFIDENTIAL
68	CONFIDENTIAL	69	CONFIDENTIAL
69	CONFIDENTIAL	70	CONFIDENTIAL
70	CONFIDENTIAL	71	CONFIDENTIAL
71	CONFIDENTIAL	72	CONFIDENTIAL
72	CONFIDENTIAL	73	CONFIDENTIAL
73	CONFIDENTIAL	74	CONFIDENTIAL
74	CONFIDENTIAL	75	CONFIDENTIAL
75	CONFIDENTIAL	76	CONFIDENTIAL
76	CONFIDENTIAL	77	CONFIDENTIAL
77	CONFIDENTIAL	78	CONFIDENTIAL
78	CONFIDENTIAL	79	CONFIDENTIAL
79	CONFIDENTIAL	80	CONFIDENTIAL
80	CONFIDENTIAL	81	CONFIDENTIAL
81	CONFIDENTIAL	82	CONFIDENTIAL
82	CONFIDENTIAL	83	CONFIDENTIAL
83	CONFIDENTIAL	84	CONFIDENTIAL
84	CONFIDENTIAL	85	CONFIDENTIAL
85	CONFIDENTIAL	86	CONFIDENTIAL
86	CONFIDENTIAL	87	CONFIDENTIAL
87	CONFIDENTIAL	88	CONFIDENTIAL
88	CONFIDENTIAL	89	CONFIDENTIAL
89	CONFIDENTIAL	90	CONFIDENTIAL
90	CONFIDENTIAL	91	CONFIDENTIAL
91	CONFIDENTIAL	92	CONFIDENTIAL
92	CONFIDENTIAL	93	CONFIDENTIAL
93	CONFIDENTIAL	94	CONFIDENTIAL
94	CONFIDENTIAL	95	CONFIDENTIAL
95	CONFIDENTIAL	96	CONFIDENTIAL
96	CONFIDENTIAL	97	CONFIDENTIAL
97	CONFIDENTIAL	98	CONFIDENTIAL
98	CONFIDENTIAL	99	CONFIDENTIAL
99	CONFIDENTIAL	100	CONFIDENTIAL



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

JUN 01 1982

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
NATURAL GAS PIPELINE ANALYSIS
ER 100450 FILE 841-2
PLA-1104

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

This letter is in response to the NRC letter of March 30, 1982, regarding a natural gas pipeline in the vicinity of Susquehanna Steam Electric Station. The following conservative analysis shows that the location of the gas line is acceptable assuming a passive flow restriction device in the gas line. The restriction would limit the break flow to a value that would not pose a hazard to the Susquehanna plant.

Calculations were performed to determine the maximum distance to the lower flammability limit (LFL) versus steady state break flow. Since natural gas is significantly lighter than air, the calculations were based on dispersion of an elevated plume for which ground reflection does not occur. This results in the following equation for determining the plume centerline concentration:

where

$$X = \frac{Q}{2\pi \sigma_y \sigma_z U}$$

X = concentration at a distance x
downwind from the break location

Q = steady state break flow,

σ_y, σ_z = horizontal and vertical dispersion
coefficients at the distance x, and

Boo/s
//



JUN 01 1982

Page 2

SSES PLA-1104
ER 100450 File 841-2
Mr. A. Schwencer

U = wind speed.

The above equation was used with the following data to calculate the curve shown on Figure 1:

χ = 0.048 volume fraction (LFL
of natural gas in air - Ref. 1),

σ_y, σ_z = values from F stability curve on
Figure 4-1 of Ref. 2, and

U = 1 m/sec.

In order to determine a limiting flow at which a postulated double ended gas line break would pose no hazard to the Susquehanna plant, it is necessary to consider the distances between the gas line and plant structures critical to safe shutdown. The structures considered are the reactor buildings, the control complex, the diesel generator building, and the ESSW pumphouse. These relationships are shown on Figure 2, which indicates that the air intakes for the reactor building and control complex are over 1500 feet from the nearest approach to the gas line.

Using the 1500 foot value as a limit, a steady state break flow of 39 m³/sec results (Figure 1). If the break flow was limited to this value, the maximum range of a flammable gas mixture resulting from a double ended break of the gas line at any location would not reach either the reactor buildings or the control complex.

The other two critical structures, the ESSW pumphouse and the diesel generator building, are less than 1500 feet from the gas line, but the air intakes on these structures are lower than the pipeline elevation at its nearest approach to these structures. Analysis of break locations at different elevations along the gas line shows that even under an assumption of a two-thirds reduction in buoyancy, the centerline of a plume from a gas line break would clear the pumphouse and the diesel generator building by a substantial margin. The results of this analysis for a steady state break flow of 39 m³/sec are shown in Figures 3 and 4. The solid plume centerlines are based on Briggs' methodology (refs. 3-5). The dashed plume centerlines are based on the assumed two-thirds reduction in buoyancy.

Based on the above analysis and discussion, a flow restriction sized to limit the steady state break flow to 39 m³/sec would eliminate the pipeline as a potential threat to the safe operation of the Susquehanna plant. The attached letter from the Pennsylvania Gas and Water Company (PG&W) indicates that a 2" restriction already exists in their system which limits the flow from



[The text in this section is extremely faint and illegible. It appears to be a list or a series of entries, possibly names or dates, but the characters are too small and light to transcribe accurately.]

JUN 01 1982

Page 3

SSES PLA-1104
ER 100450 File 841-2
Mr. A. Schwencer

one side of the break to 30 m³/sec. Based on subsequent discussions with PG&W, we believe this calculation to be extremely conservative, and the actual flow would be about 25 m³/sec. PG&W expects the existing flow restriction to remain unchanged for the next two years.

We have conservatively calculated a maximum backflow from the other direction of 9 m³/sec based on information supplied by PG&W. We believe this flow is actually substantially lower. Based on these calculations, the maximum flow from a double ended break in the natural gas line would be 39 m³/sec which is acceptable, as shown above.

PG&W has agreed to perform a detailed study to show the precise flow limitations of their existing system as well as the size of restriction that would be needed in the future as their system develops. This analysis will confirm that the flow from a double ended break would be limited such that the gas plume in the vicinity of the affected air intake structures would be below the lower flammability limit.

At the April 12, 1982 meeting in Bethesda, the NRC Staff indicated concern with respect to the effects of low natural gas concentrations on control room habitability, due to its classification as an asphyxiant. With the flow restriction device, the concentration of natural gas at the control room air intakes will be substantially below the LFL (4.8%). However, to assess the effects on control room operators, it is conservatively assumed that they could breathe a mixture of 4.8% natural gas and 95.2% air. The resulting oxygen content in such a mixture is 19.94%. This value is larger than the minimum 19.5% oxygen concentration specified in OSHA's 29 CFR Chapter XVII Part 1910 for assuring worker safety.

The PG&W pipeline was installed to the Federal safety standards for gas pipelines relating to transportation of natural gas as given in 49 CFR Part 192. The line, although used for distribution, was designed to the more elaborate requirements of a transmission pipeline. The design conservatively assumed Class 4 conditions (i.e., in a city with 4 story buildings). All welds were X-rayed during installation. Prior to being put into service the line was hydrostatically tested to 1130 psi, which is more than three times its maximum operating pressure. The line has cathodic protection to prevent corrosion during operation.

Based on the above information, we believe that operation of the PG&W pipeline will pose no undue risk to the Susquehanna plant.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction-Nuclear

WEB/mks

cc: R. Perch
G. Rhoads



JUN 01 1982

Page 4

SSES PLA-1104
ER 100450 File 841-2
Mr. A. Schwencer

REFERENCES

1. Theodore Baumeister et al eds, Marks Standard Handbook for Mechanical Engineers, Eighth Edition, McGraw Hill Book Company, New York, 1978.
2. D. Bruce Turner, Workbook of Atmospheric Dispersion Estimates, Environmental Protection Agency, Publication No. AP-26, July, 1971.
3. G. A. Briggs, Plume Rise, TIC-25075, November, 1969.
4. G. A. Briggs, Plume Rise Predictions, ATDL Contribution File No. 75/15.
5. G. A. Briggs, Plume Rise and Buoyancy Effects, ATDL Contribution File No. 79/6.



1

W. E. Barberich



PG&W PENNSYLVANIA GAS AND WATER COMPANY

WILKES-BARRE CENTER
39 PUBLIC SQUARE, WILKES-BARRE, PENNSYLVANIA 18711

RECEIVED
MAY 26 1982
NUCLEAR DEPT.

GERALD B. TAYLOR
Vice-President, Operations and Engineering

May 25, 1982

5/26/82

Mr. R. J. Shovlin,
Asst. Project Director
Pennsylvania Power & Light Co.
Two North Ninth Street
Allentown, PA 18101

Dear Mr. Shovlin:

I am writing to confirm our recent discussions regarding our company's position concerning the restriction of gas flows from the Salem Township City Gate Station through the 12" gas main near the Susquehanna Steam Electric Station. This is a result of the N.R.C. request for flow restriction.

Based on load projections for the upcoming two-year period, the Pennsylvania Gas and Water Company feels it will be able to provide system demands through an existing 2" orifice run in the station. This orifice will limit maximum gas flows which will occur in the event of a line rupture to less than 3800 MCF/hr. or 30 cu. meters/second.

Since this is only a short term solution to flow restriction, it will be necessary to conduct further studies to determine the means to provide for flow restriction in event of a rupture of the pipeline while providing alternate supply required to maintain service to customers. With the builtin flow restriction, it will be possible to conduct these studies and complete the analyses while your plant is operating.

The fact is, these points must be studied to quantify each parameter. Once the parameters have been quantified, we must develop alternate plans to minimize to an acceptable level, the overall system effect of the restriction device.

We understand that P. P. & L. is prepared to provide the funds which will be expended on these analyses. Mr. James Palumbo will contact you shortly with schedules and cost estimates.

Very truly yours,

GBT:P
CC: J. Palumbo



STEADY STATE BREAK FLOW (m^3/sec)




FIGURE 1



14

The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and is not readable.

BREAK AT ELEVATION 700

(NEAREST PUMPHOUSE)

STEADY STATE BREAK FLOW




FIGURE 3



4

BREAK AT ELEVATION 600'
STEADY STATE BREAK FLOW





FIGURE 4



7

CONRAIL

PM
520



LEGEND

- PG&W GAS LINE
- REACTOR BUILDING
- AIR INTAKE
- GAS LINE OUTSIDE APPLIED TO REACTOR BUILDING VENTS

FIGURE 2

