

REGULATORY INFORMATION DISTRIBUTION STATEMENTS (GRIDS)

ACCESSION NBR: 8208030455 DOC. DATE: 82/07/29 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Responds to request for results of reassessment of seismic & dynamic qualification of individual NSSS equipment per SER item 3.1.0.3. Results of each assessment method on equipment items listed.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	A/D LICENSNG		1	0	LIC BR #2 BC		1	0	
	LIC BR #2 LA		1	0	PERCH, R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3	
	NRR/DE/CEB	11	1	1	NRR/DE/EQB	13	3	3	
	NRR/DE/GB	28	2	2	NRR/DE/HGEB	30	2	2	
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1	
	NRR/DE/QAB	21	1	1	NRR/DE/SAB	24	1	1	
	NRR/DE/SEB	25	1	1	NRR/DHFS/HFEB40		1	1	
	NRR/DHFS/LQB	32	1	1	NRR/DHFS/OLB	34	1	1	
	NRR/DHFS/PTRB20		1	1	NRR/DSI/AEB	26	1	1	
	NRR/DSI/ASB	27	1	1	NRR/DSI/CPB	10	1	1	
	NRR/DSI/CSB	09	1	1	NRR/DSI/ETSB	12	1	1	
	NRR/DSI/ICSB	16	1	1	NRR/DSI/PSB	19	1	1	
	NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1	
	NRR/DST/LGB	33	1	1	<u>REG FILE</u>	04	1	1	
	RGN1		2	2	RM/DDAMI/MIB		1	0	
EXTERNAL:	ACRS	41	10	10	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	2	2	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	

TOTAL NUMBER OF COPIES REQUIRED: LTTR 59 ENCL 54



Faint, illegible text at the top of the page.

Faint, illegible text in the upper middle section.

Main body of faint, illegible text, appearing as scattered characters and light lines.



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

JUL 29 1982

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
NEW LOAD ADEQUACY EVALUATION REVISED
BUILDING SPECTRA ASSESSMENT
SER ITEM 3.10.3
ER 100450 FILE 841-2
PLA-1221

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

This letter is provided in response to your request for the results of the reassessment of the seismic and dynamic qualification of each individual NSSS equipment. Below find a tabulation listing each individual equipment item, the assessment methodology utilized, and results. Based upon the revised response spectra assessment, the existing basemat spectra was bounded and, therefore, no equipment on the basemat was evaluated.

<u>Equipment</u>	<u>Assessment Method</u>	<u>Results</u>
1) Local Panels (MPL-H23)	Enveloped and combined the revised building response spectra and performed a comparison with Test Response Spectra (TRS) and high-frequency cutoff curve. Also showed ZPA x transmissibility less than tested capability.	Acceptable
2) Refueling Platform New Fuel Storage Racks* Fuel Prep Machine*	Combined the revised building response spectra and performed a comparison against the original design basis spectra.	Acceptable
3) RHR Heat Exchanger	Performed a load comparison with the design basis loads at the RHR Heat Exchanger natural frequencies.	Acceptable
4) Hydraulic Control Unit (HCU)	Combined the revised building response spectra and performed a	Acceptable

13001

8208030455 820729
PDR ADOCK 05000387
E PDR



The page contains extremely faint and illegible text, likely due to low contrast or scanning quality. The text is scattered across the page and does not form any recognizable words or sentences.

JUL 29 1982

Page 2

SSES PLA-1221
ER 100450 File 841-2
Mr. A. Schwencer

<u>Equipment</u>	<u>Assessment Method</u>	<u>Results</u>
	comparison with Test Response Spectra (TRS).	
5) MSIV Leakage Control Blower	The blower's first natural frequency falls within the revised buildings response spectra ZPA. A revised building response ZPA was compared against the design basis loads.	Acceptable
6) Control Room Panels (H12)	Showed TRS high frequency cutoff curve envelopes revised building response spectra and ZPA x transmissibility less than tested capability.	Acceptable

*New Fuel Storage Racks and Fuel Prep Machine were only impacted by the vertical spectra.

This letter completes our response to this item. Should you have any questions, contact Mr. G. Wetzel at 770-6534 or Mr. W. Williams at 770-4274.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction-Nuclear

WWW/mks

cc: R. Perch - NRC
A. Lee - NRC

