

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8208040142 DOC. DATE: 82/07/28 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

see R15

SUBJECT: Forwards qualification repts for MSIV actuators & MSIV leakage control heater sys.

DISTRIBUTION CODE: A048S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 11+282
 TITLE: Equipment Qualification (OR & PRE-OL)

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
	LIC BR #2 BC 12		1	0	PERCH, R.	01	1	1
INTERNAL:	ELD/HDS4	12	1	1	GC	13	1	1
	IE FILE	09	1	1	NRR CALVO, J		1	1
	NRR/DE/EQB	07	2	2	NRR/DL DIR	14	1	1
	NRR/DL/QRAB	06	1	1	NRR/DSI/AEB		1	1
	<u>REG FILE</u>	04	1	1	RGN1		1	1
EXTERNAL:	ACRS	15	10	10	LPDR	03	2	2
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS	31	1	1				



THE UNITED STATES OF AMERICA
 DEPARTMENT OF THE INTERIOR
 BUREAU OF LAND MANAGEMENT
 WASHINGTON, D. C. 20250

NATIONAL SYSTEM OF PUBLIC LANDS
 LAND ACQUISITION
 REPORT OF PROGRESS
 LAND ACQUISITION
 REPORT OF PROGRESS
 LAND ACQUISITION

THE UNITED STATES OF AMERICA
 DEPARTMENT OF THE INTERIOR
 BUREAU OF LAND MANAGEMENT
 WASHINGTON, D. C. 20250

NATIONAL SYSTEM OF PUBLIC LANDS
 LAND ACQUISITION
 REPORT OF PROGRESS
 LAND ACQUISITION
 REPORT OF PROGRESS
 LAND ACQUISITION



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

JUL 28 1982

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
SEISMIC QUALIFICATION OF MSIV ACTUATOR AND
LEAKAGE CONTROL HEATER SYSTEM
ER 100450 FILE 841-2
PLA-1220

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

Enclosed are four-page SQRT Forms and qualification reports for the Main Steam Isolation Valve Actuators (HV-1F022 A through D, HV-1F028A through D) and the Main Steam Isolation Valve - Leakage Control System Heater (1E-203 A through D).

This letter and the enclosed material are provided to satisfy the requirements of Section 3.10.2.1 (3) and (4) of Supplement No. 3 to NUREG 0776 and completes our response to these requirements.

Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

A048

Enclosure

cc: R. Perch - NRC w/o
A. Lee - NRC w/a

8208040142 820728
PDR ADOCK 05000387
P PDR



Qualification Summary of Equipment


I. Plant Name: Susquehanna Type:
1. Utility: Penn. Power & Light PWR
2. NSSS: GE 3. A/E: Rechtel BWR/4-Mark II Containment

II. Component Name Main Steam Isolation Valve & Actuator

1. Scope: NSSS BOP
2. Model Number: 21283-H Quantity: 8
3. Vendor: Atwood & Morrill Company
4. If the component is a cabinet or panel, name and model No. of the devices included: Not Applicable
5. Physical Description
 - a. Appearance Air-operated Y-pattern globe valve
 - b. Dimensions 45" wide, 63" long, 114" high
 - c. Weight 12,300 lb. dry, 13,400 lb wet; Note 1
6. Location: Building: Drywell and steam tunnel
Elevation: 745'
7. Field Mounting Conditions Bolt (No. 20, Size 2")
 Held (Length)
 Butt-welded to 26" main steam piping
at the valve inlet and discharge
8. a. System in which located: Main Steam
b. Functional Description: Isolate main steam lines and provide signal on stem position
c. Is the equipment required for Hot Standby Cold Shutdown
 Both Neither
9. Pertinent Reference Design Specifications: GE specification 21A9257, Rev.3

Note 1: Weight of the actuator assembly alone is 2,780 lb.

12/80



III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method:

Test Analysis Combination of Test and Analysis
VPF 3180-12-3 (Note 2)

Qualification Report*: ATR For Susquehanna 1 & 2, 26" MSIV Valve Actuator
Dynamic Qualification Test
(No., Title and Date) ATR-DDO-8204

Company that Prepared Report: GE

Company that Reviewed Report: GE

V. Vibration Input:

- 1. Loads considered: a. Seismic only
- b. Hydrodynamic only
- c. Combination of (a) and (b)

2. Method of Combining RRS: Absolute Sum SRSS (other, specify)

3. Required Response Spectra (attach the graphs): Yes

4. Damping Corresponding to RRS: OBE 4% SSE 4%

5. Required Acceleration in Each Direction: ZPA Other RRS (attached) (specify)

OBE	S/S =	<u>N/A</u>	F/B =	<u>N/A</u>	V =	<u>N/A</u>
SSE	S/S =	<u>N/A</u>	F/B =	<u>N/A</u>	V =	<u>N/A</u>

6. Were fatigue effects or other vibration loads considered?
 Yes No

If yes, describe loads considered and how they were treated in overall qualification program: Thermal fatigue effect was evaluated per the applicable ASME Boiler & Pressure Vessel Code and documented in the Design Report (VPF 3180-12-3)

*NOTE: If more than one report complete items IV thru VII for each report.

Note 2: This is the valve design report. It is referenced here only for the thermal fatigue analysis.

12/80



VI. If Qualification by Test, then Complete*: Actuator only

1. Single Frequency Multi-Frequency: random
 sine beat
 Independent
2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE 10 SSE 2 Other _____
(specify)

4. Frequency Range: 1-100 Hz

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
 S/S = Open & closed 10.2 Hz F/B = Open - 11.4 Hz V = Open - 90 Hz
Closed-11.7 Hz Closed - 10 Hz

6. Method of Determining Natural Frequencies
 Lab Test In-Situ Test Analysis

7. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

8. Input g-level Test: OBE S/S = N/A F/B = N/A V = N/A
 SSE S/S = N/A F/B = N/A V = N/A

9. Laboratory Mounting:
 1. Bolt (No. 20 , Size 2") Weld (Length _____) _____

10. Functional operability verified: Yes No Not Applicable

11. Test Results including modifications made: Demonstrated that the valve actuator assembly performed all tested functions throughout the test sequence.

12. Other test performed (such as aging or fragility test, including results):
NONE

*Note: If qualification by a combination of test and analysis also complete Item VII.



VII. If Qualification by Analysis, then complete:

1. Method of Analysis:

- Static Analysis Equivalent Static Analysis
 Dynamic Analysis: Time-History Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____ PISYS _____ _____

Frequency Range and No. of modes considered: Seismic: 1-33 Hz
 Hydrodynamic: 1-60 Hz

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____ (specify)

6. Damping: OBE .5% N/A SSE 1% Seismic Basis for the damping used: 385H777
2% Hydrodynamic

7. Support Considerations in the model: Rigid supports, snubbers, hangers,
struts and weld ends


8. Critical Structural Elements:

A. Identification	Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
Inboard MSIV Outlet at Line A	Main Steam A line	SSE & Hydro.	SSE	8226	17,700 psi

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Opera- bility
See Test		



RUN 25 TPP524.8926 OBE 90X XA-YC DATE 6/15/82 16:18: 8 CHANNEL 4 TAB VT1
 DECIMATION RATIO 2 7412 POINTS ANALYZED DELTA T .004 1/6 OCTAVE 100.00 HZ LP FILTER 6 POLES
 4.00 X DAMPING START TIME 0.000 SEC END TIME 29.648 SEC 8 RECORDS SKIPPED 218 RECORDS ANALYZED
 100.0 X AND 0.0 X RRS PLOTTED



ATR-DDO-8204
 Figure 10A

Sh 84
 of 108

SEMI-CLOSED METHOD APPROXIMATION : 7-22-80 REVISION



RUN 10.25 TPP524.0926 OBE 90X XA-YC

DATE 6/15/82

16:10:0

CHANNEL 3

TAB HZ1

DECIMATION RATIO 2 7412 POINTS ANALYZED

DELTA T .004

1/6 OCTAVE 100.00 HZ LP FILTER

6 POLES


4.00 % DAMPING START TIME 0.000 SEC

END TIME 29.648 SEC

0 RECORDS SKIPPED

218 RECORDS ANALYZED

100.0 % AND 0.0 % RRS PLOTTED




SEMI-CLOSED METHOD APPROXIMATION : 7-22-80 REVISION

ATR-DDO-8204
Figure 10B

Sh 85
of 108



RUN 45 TPP524.0926 MSIV OBEZ 95X ZB-YC DATE 6/19/82 12:50:0 CHANNEL 3 TAB HZ1
 DECIMATION RATIO 2 7344 POINTS ANALYZED DELTA T .004 1/6 OCTAVE 100.00 HZ LP FILTER 6 POLES
 4.00 % DAMPING START TIME 0.000 SEC END TIME 29.376 SEC 0 RECORDS SKIPPED 216 RECORDS ANALYZED
 100.0 % AND 0.0 % RRS PLOTTED



Up set Load Side To Side


SEMI-CLOSED METHOD APPROXIMATION : 7-22-82 REVISION

ATR-DDO-8204
 Figure 10L

Sh 95
 of 108



RUN 53 TPP524.8926 MSIV SSEZ 100% ZC-YD DATE 6/21/82 15:38: 8 CHANNEL 4 TAB VT1
 DECIMATION RATIO .2 7514 POINTS ANALYZED DELTA T .004 1/ 6 OCTAVE 100.00 HZ LP FILTER 6 POLES
 .4.00 % DAMPING . START TIME 0.000 SEC END TIME 30.056 SEC 0 RECORDS SKIPPED 221 RECORDS ANALYZED
 . 100.6 % AND . 8.8 % RRS PLOTTED




SCALE-CURVE METHOD APPROXIMATION : 7-22-80 REVISION

Faulted Load - Vertical
 AFR-DDO-8204
 Figure 10U



RUN 54 TPP524.0926 MSIV SSEX 0%XA-100XY DATE 6/22/82 9:50:0 CHANNEL 3 TAB HZ1
 DECIMATION RATIO 2 7514 POINTS ANALYZED DELTA T .004 1/6 OCTAVE 100.00 HZ LP FILTER 6 POLES
 4.00% DAMPING START TIME 0.000 SEC END TIME 30.056 SEC 0 RECORDS SKIPPED 221 RECORDS ANALYZED
 100.0% AND 0.0% RRS PLOTTED

MULTIPLY SCALE BY 10**1




Faulted Load - End to End

ATR-DDO-8204
Figure 10X

SEMI-CLOSED METHOD APPROXIMATION : 7-22-80 REVISION



RUN 53 TPP524.0926 MSIV SSEZ 100% ZC-YD DATE 6/21/82 15:30:0 CHANNEL 3 TAB HZ1
 DECIMATION RATIO 2 7514 POINTS ANALYZED DELTA T .004 1/6 OCTAVE 100.00 HZ LP FILTER 6 POLES
 4.00 X DAMPING START TIME 0.000 SEC END TIME 30.056 SEC 0 RECORDS SKIPPED 221 RECORDS ANALYZED
 100.0 X AND 0.0 X RRS PLOTTED



SEMI-CLOSED METHOD APPROXIMATION : 7-22-80 REVISION

ATR-DDO-8204
 Figure 10V

Sh 105
 of 108

Faulted load - Side to side



Handwritten marks and scribbles in the top right corner.

Handwritten marks and scribbles in the bottom right area.