

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

AEA  
SZ  
DOCKET #  
05000387

ACCESSION NBR: 8210250256 DOC. DATE: 82/10/19 NOTARIZED: NO  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv  
 AUTH. NAME AUTHOR AFFILIATION  
 CURTIS, N.W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards Amend 11 to License NPF-14 & proposed Tech Spec changes. Amend deletes Fire Zone 1-6A in access area from Tech Specs.

DISTRIBUTION CODE: B002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2  
 TITLE: Licensing Submittal; Fire Protection

NOTES: w/check \$4,000

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR LB2 BC	1 1	PERCH, R.	01 1 1
INTERNAL:	ELD/HDS4	1 0	IE FILE	07 1 1
	NRR/DE/ADMGE	1 0	NRR/DE/CEB	06 4 4
	NRR/DSI/ASB	1 1	REG FILE	04 1 1
	RGN1	1 1		
EXTERNAL:	ACRS 10	6 6	LPDR 03	2 2
	NRC PDR 02	1 1	NSIC 05	1 1
	NTIS	1 1		





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215 / 770-5381

OCT 19 1982

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
PROPOSED AMENDMENT 11 TO LICENSE NO. NPF-14  
ER 100450 FILE 841-8  
PLA-1351

Docket No. 50-387

Dear Mr. Schwencer:

The purpose of this letter is to propose a change to Appendix A to License No. NPF-14, the Susquehanna SES Unit One Technical Specifications. The proposed change is provided as Attachment A to this letter.

Specification 3.7.6.2 lists sprinkler systems required to be operable; the proposed change deletes Fire Zone 1-6A (item 1) from this listing. Fire Zone 1-6A is an access area which contains no equipment essential for the safe shutdown of Unit One.

Fire Zone 1-2B does contain essential equipment and should be added in place of Zone 1-6A.

This change has been determined to be Class III in nature and the appropriate fee is enclosed.

Very truly yours,

N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

RRS/mks

Attachment

cc: R. L. Perch - USNRC

Book  
w/ check  
\$ 4,000

8210250256 821019  
PDR ADDCK 05000387  
P PDR

