

PLANT SYSTEMS

SPRAY AND SPRINKLER SYSTEMS

LIMITING CONDITION FOR OPERATION

---

3.7.6.2 The following spray and sprinkler systems shall be OPERABLE:

- a. RCIC Pump Room, Unit 1
- b. HPCI Pump Room, Unit 1
- c. Upper Cable Spreading Room, Unit 1
- d. Lower Cable Spreading Room, Unit 1
- e. Diesel Generator A Room
- f. Diesel Generator B Room
- g. Diesel Generator C Room
- h. Diesel Generator D Room
- i. Fire Zones 1-3A and 1-3B
- j. Fire Zone 1-4A
- k. Fire Zone 1-5A
- l. Fire Zone ~~1-6A~~ 1-2B

APPLICABILITY: Whenever equipment protected by the spray and/or sprinkler systems is required to be OPERABLE.

ACTION:

- a. With one or more of the above required spray and/or sprinkler systems inoperable, within one hour establish a continuous fire watch with backup fire suppression equipment for those areas in which redundant systems or components could be damaged; for other areas, establish an hourly fire watch patrol. Restore the system to OPERABLE status within 14 days or, in lieu of any other report required by Specification 6.9.1, prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 30 days outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- b. The provisions of Specification 3.0.3 and 3.0.4 are not applicable.

821025 0276

SECRET

851058