

REGULATORY INFORMATION DISTRIBUTION SYSTEM (IDS)

ACCESSION NBR: 8211020443 DOC. DATE: 82/10/29 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 AUTH. NAME AUTHOR AFFILIATION
 KENYON, B.D. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards Revision 1 to 820717 application for Amend 4 to License NPF-14 re qualification of purge valves.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR/DL/ADL	1 0	NRR LB2 BC	1 0
	NRR LB2 LA	1 0	PERCH,R, 01	1 1
INTERNAL:	ELD/HDS4	1 0	IE FILE	1 1
	IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
	NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
	NRR/DE/EQB 13	3 3	NRR/DE/GB 28	2 2
	NRR/DE/HGEB 30	2 2	NRR/DE/MEB 18	1 1
	NRR/DE/MTEB 17	1 1	NRR/DE/GAB 21	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/OLB 34	1 1	NRR/DHFS/PTRB20	1 1
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB 27	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ETSB 12	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	NRR/DST/LGB 33	1 1
	<u>REG FILE</u> 04	1 1	RGN1	2 2
	RM/DDAMI/MIB	1 0		
EXTERNAL:	ACRS 41	6 6	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	2 2	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 56 ENCL 50

ALLEGEDLY...
RECEIVED...
DATE: ...

of ... and ...

1952

DATE	DESCRIPTION	AMOUNT	TOTAL
1
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Bruce D. Kenyon
Vice President-Nuclear Operations
215 / 770-4378

OCT 29 1982

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
REVISION TO PROPOSED AMENDMENT 4 TO
LICENSE NPF-14
ER 100450 FILE 841-2
PLA-1372

Docket No. 50-387

Dear Mr. Schwencer:

On September 14, 1982, PP&L submitted PLA-1291 which requested a change to license condition #5. We wish to revise the proposed change as follows:

Qualification of Purge Valves (Section 6.2:4, SS&R #11)

- a) The licensee shall provide justification for operation which demonstrates the operability of the purge supply & exhaust isolation valves to close against peak LOCA pressure when blocked to 50 degrees. Until such time that this information is approved, operation of these valves shall comply with the following configuration.
 - 1) Close and electrically prohibit from opening valves HV-15704, HV-15714, HV-15721, HV-15722, HV-15723, HV-15724, and HV-15725.
 - 2) Block to a maximum opening of no greater than 50 degrees valves HV-15703 and HV-15713.
- b) Once the justification in part a has been approved by NRC, the licensee may operate the plant with all purge supply and exhaust isolation valves blocked to a maximum opening of no greater than 50 degrees.
- c) Parts a and b apply only to operating modes 1, 2, and 3. No blocking or maintaining valves closed is required in modes 4 and 5.
- d) Prior to the startup following the first refueling outage, the licensee must submit for NRC review and approval information which demonstrates the purge supply and exhaust isolation valves are qualified to close against peak LOCA pressure from the full open position.

8211020443 821029
PDR ADOCK 05000387
P PDR



13001



6-2
2
2

[The main body of the page contains extremely faint and illegible text, likely bleed-through from the reverse side of the paper. The text is scattered across the page and cannot be transcribed accurately.]

OCT 29 1982

Page 2

SSES PLA-1372
ER 100450 File 841-2
Mr. A. Schwencer

This change is justified because the paths that will be used to maintain containment atmosphere control are limited by flow through lines no greater than two inches in diameter until NRC approves blocking all valves to 50 degrees. Thereafter the plant configuration will be such that flow is through valves qualified to close against peak LOCA pressure.

Very truly yours,



B. D. Kenyon
Vice President-Nuclear Operations

DPM/mks

cc: R. L. Perch - NRC



Handwritten marks and symbols in the top right corner, including a wavy line and several small dots.

Faint handwritten text or symbols in the upper right quadrant.

Faint handwritten text or symbols in the middle right area.

Faint handwritten marks or symbols at the bottom right of the page.