

CONTROLLED

TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-1988  
Temporary Change Page 1 of 1

A: Procedure No. EP-IP-001, Rev. 0  
Title EMERGENCY CLASSIFICATION

B. Requested Change  
Change the time limit in I.A.2 from 10 minutes to 15 minutes on page 25 of the procedure. Thus, a fire emergency must exceed 15 minutes before it is classified as an unusual event, unless safety related equipment is involved.

C. Reason For Change  
To agree with E-Plan and EP-IP-041, Fire Emerg.

Does this change alter the intent of the procedure? Yes  No   
Does this change identify an unreviewed safety question? Yes  No   
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes  No

E. Expiration Date N/A [ "N/A" for permanent status.  
45-60 days for temporary status ]

F. Initiator J. Baileys Title Fire Protection Engineer Date 10/5/82

G. Temporary Change Authorization  
W.F. Shum / 110-7-82 / [Signature] / 110/7/82  
Shift Supervision Date Management Member Date

H. Temporary Change Approval  
Approved as written for permanent status Yes  No

\_\_\_\_\_/\_\_\_\_\_  
PORC Chairman/Section Head Date  
(As Applicable) PORC Review (If Applicable) Mtg. No. / Date

\_\_\_\_\_/\_\_\_\_\_  
Superintendent of Plant Date

8211110038 BV2102  
PDR ADOCK 05000387  
PDR

11-12-68

1  
11-12-68

CONTROLLED

TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-1989  
Temporary Change Page 1 of 1

A. Procedure No. EP-IP-QA-1, Rev. 0  
Title FIRE EMERGENCIES

B. Requested Change:  
Add step E.3. to attachment E  
E.3 As soon as practical, notify the site Fire Protection Engineer.

C. Reason For Change  
AD-QA-110 and the NDI require notification of the fire protection engineer of all fires at the site.

Does this change alter the intent of the procedure?      Yes       No   
Does this change identify an unreviewed safety question?      Yes       No   
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status    Yes     No

E. Expiration Date N/A      ["N/A" for permanent status.  
45-60 days for temporary status]

F. Initiator J. Bails      Title Fire Protection Engineer      Date 10/5/82

G. Temporary Change Authorization  
W. Shum      /      10-7-82      [Signature]      /      10/7/82  
Shift Supervision      Date      Management Member      Date

H. Temporary Change Approval  
Approved as written for permanent status      Yes       No

\_\_\_\_\_/\_\_\_\_\_  
PORC Chairman/Section Head      Date      PORC Review      /  
(As Applicable)      (If Applicable) Mtg. No.      Date

\_\_\_\_\_/\_\_\_\_\_  
Superintendent of Plant      Date