

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8301040249 DOC. DATE: 82/12/29 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Informs that review of as-built reconciliation complete.
 Rework performed where necessary on all Phase III anchors in
 accordance w/commitments in 821027 ltr. Teledyne will review
 results per SER Suppl 4.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	PERCH,R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3	
	NRR/DE/AEAB		1	0	NRR/DE/CEB	11	1	1	
	NRR/DE/EQB	13	2	2	NRR/DE/GB	28	2	2	
	NRR/DE/HGEB	30	1	1	NRR/DE/MEB	18	1	1	
	NRR/DE/MTEB	17	1	1	NRR/DE/QAB	21	1	1	
	NRR/DE/SAB	24	1	1	NRR/DE/SEB	25	1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1	
	NRR/DHFS/OLB	34	1	1	NRR/DL/SSPB		1	0	
	NRR/DSI/AEB	26	1	1	NRR/DSI/CPB	10	1	1	
	NRR/DSI/CSB	09	1	1	NRR/DSI/ICSB	16	1	1	
	NRR/DSI/METB	12	1	1	NRR/DSI/PSB	19	1	1	
	NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1	
	<u>REG FILE</u>	04	1	1	RGN1		3	3	
	RMZ/DAMI/MIB		1	0					
EXTERNAL:	ACRS	41	6	6	BNL (AMDTs ONLY)		1	1	
	DMB/DSS (AMDTs)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	2	2	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 46



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

DEC 29 1982

Mr. A. Schwencer
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
HANGER RECONCILIATION
LICENSE CONDITION 2.C.(19)
ER 100450 FILE 841-2
PLA-1458

Docket No. 50-387

Dear Mr. Schwencer:

This letter supplements PP&L letters PLA-1346 (dated October 4, 1982), PLA-1369 (dated October 27, 1982) and PLA-1383 (dated November 4, 1982). PP&L has completed its review of the as-built reconciliation and has performed rework where necessary on all phase III (large pipe) anchors in accordance with the commitments described in PLA-1369. Category III differences which were determined to reduce the conservatism of the original design margin were reworked. This included three anchors inside containment and eight anchors outside containment. PP&L has also completed an as-built review of all rework and has determined the rework to be acceptable.

This completes our actions in response to License Conditions 2.C.(19)(a) and (b). In accordance with SER Supplement 4, Section 17.6, Teledyne will evaluate the results of this anchor program and report its findings to NRC.

Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

cc: R. L. Perch - NRC
D. F. Landers - TES

8301040249 821229
PDR ADOCK 05000387
P PDR

13001

