

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8303070080 DOC. DATE: 83/02/28 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Forwards updated "Susquehanna Steam Electric Station Units 1 & 2 Dynamic Qualification," for recirculation discharge gate valve assemblies HV-1F031 A & B, including Limitorque actuator installation.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+24
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: 1cy NMSS/FCAF/PM. 05000387
 1cy NMSS/FCAF/PM. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	PERCH, R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3	
	NRR/DE/AEAB		1	0	NRR/DE/CEB	11	1	1	
	NRR/DE/EQB	13	2	2	NRR/DE/GB	28	2	2	
	NRR/DE/HGEB	30	1	1	NRR/DE/MEB	18	1	1	
	NRR/DE/MTEB	17	1	1	NRR/DE/QAB	21	1	1	
	NRR/DE/SAB	24	1	1	NRR/DE/SEB	25	1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1	
	NRR/DL/SSPB		1	0	NRR/DSI/AEB	26	1	1	
	NRR/DSI/ASB		1	1	NRR/DSI/CPB	10	1	1	
	NRR/DSI/CSB	09	1	1	NRR/DSI/ICSB	16	1	1	
	NRR/DSI/METB	12	1	1	NRR/DSI/PSB	19	1	1	
	NRR/DSI/SAB	22	1	1	NRR/DSI/RSB	23	1	1	
	REG FILE	04	1	1	RGN1		3	3	
	RM/DDAMI/MIB		1	0					
EXTERNAL:	ACRS	41	6	6	BNL (AMDTs ONLY)		1	1	
	DMB/DSS (AMDTs)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	2	2	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 54 ENCL 47



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

FEB 28 1983

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
QUALIFICATION OF THE REACTOR RECIRCULATION
DISCHARGE VALVE ASSEMBLIES (HV-1F031A & B)
LICENSE CONDITION 2.C(23)(e)
ER 100450 FILE 843-05
PLA-1546

Docket No. 50-387

Dear Mr. Schwencer:

License Condition 2.C.(23)(e) requires qualification of the recirculation discharge valve assemblies (HV-1F031 A & B) including installation of new Limitorque actuators wired for torque seating type operation.

Enclosed are updated SQRT forms for the recirculation discharge valves. The new Limitorque actuators have been installed and wired for torque seating type operation.

This letter with the attached SQRT forms completes our response to License Condition 2.C.(23)(e).

Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

Enclosure

13001

8303070080 830228
PDR ADOCK 05000387
P PDR

