

TABLE 3.3.7.9-1 (Continued)  
FIRE DETECTION INSTRUMENTATION

<u>FIRE ZONE</u>	<u>ROOM OR AREA</u>	<u>ROOM NO.</u>	<u>ELEV.</u>	<u>HEAT</u>		<u>IONIZATION</u>		<u>PHOTO-ELECTRIC</u>					
				<u>TOTAL MIN.</u>	<u>TOTAL MIN.</u>	<u>TOTAL MIN.</u>	<u>TOTAL MIN.</u>	<u>TOTAL MIN.</u>	<u>TOTAL MIN.</u>				
<u>Reactor Building (Continued)</u>													
1-6D	H&V Equipment Room	<del>I-612</del>	779'-1"	NA	NA	12	20	8	6	NA	NA		
1-6E	Recirculation Fans Area	<del>I-615</del>	779'-1"	NA	NA	2	1			NA	NA		
0-6G	Surge Tank Vault	<del>I-601</del>	779'-4"	NA	NA	2	1			NA	NA		
1-7A	H&V Fan and Filter Rooms	I-703	799'-1"	NA	NA	8	15	8	7	2	NA	2	NA
<del>1-7B</del>	<del>Recirculation Fan Room</del>	<del>I-701</del>	<del>799'-1"</del>	<del>NA</del>	<del>NA</del>	<del>2</del>	<del>1</del>			<del>NA</del>	<del>NA</del>		
0-8A	Refueling Floor	-	818'-1"	NA	NA	NA	NA	30	15				
c. <u>ESSW Pumphouse</u>													
0-51	Pump Room	E-1	685'-6"	NA	NA	6	3	NA	NA				
0-52	Pump Room	E-2	685'-6"	NA	NA	6	3	NA	NA				
						<u>INFRA-RED (FLAME)</u>							
						<u>TOTAL MIN.</u>							
d. <u>Diesel Generator Building</u>													
0-41A	Diesel Generator Rooms and	DG-1 DG-18	660'-0" 677'-0"	22	11	2	1	15	7				
0-41C	Diesel Generator Rooms and	DG-2 DG-17	660'-0" 677'-0"	22	11	2	1	15	7				
0-41B	Diesel Generator Rooms and	DG-3 DG-18	660'-0" 677'-0"	22	11	2	1	15	7				
0-41D	Diesel Generator Rooms and	DG-4 DG-19	660'-0" 677'-0"	22	11	2	1	15	7				

\*Not accessible.



Handwritten marks and scribbles in the top right corner.

Handwritten text in a rounded rectangular box at the bottom right, possibly containing a date or reference number.