



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

50-387
50-388

IE HQ FILE COPY

April 6, 1983

Commonwealth of Pennsylvania
Department of Environmental Resources
Bureau of Water Quality Management
Wilkes-Barre Regional Office
90 East Union Street, 2nd Floor
Wilkes-Barre, PA 18702

SUSQUEHANNA STEAM ELECTRIC STATION
DISCHARGE MONITORING REPORT (DMR) NPDES
NPDES PERMIT NO. PA0047325 AND
NPDES PERMIT NO. PA0027448
FILE 01-061.09

Gentlemen:

Attached are the completed copies of the NPDES Monitoring Report for the month of February, 1983 for all the waste discharges at the subject location. The forms are being submitted in accordance with the requirements of our NPDES Permit.

There was one noncompliance reported on Outfall 041 (Cooling Tower Blow-down) during the month. On February 6, a total iron concentration of 8.0 mg/l was recorded; the cause is unknown.

If you have any questions about this material, please contact Mr. Jerry Fields at 215/770-5842.

Very truly yours,

Chas. F. Fretz
Coordinator - Government Relations

CFF:ecb

Attachment

Copy to:
EPA, Region III

Chief, US NRC, Washington, DC ✓

Handwritten initials
~~FILED~~
IF25

8304150222 830406
PDR ADDCK 05000387
PDR

SECRET

SECRET

SECRET

SECRET