

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of :
PENNSYLVANIA POWER & : Docket No. 50-387
LIGHT COMPANY :

PROPOSED AMENDMENT NO. 23
FACILITY OPERATING LICENSE NO. NPF-14
SUSQUEHANNA STEAM ELECTRIC STATION
UNIT NO. 1

Licensee, Pennsylvania Power & Light Company, hereby files a correction to Amendment No. 23 to its Facility Operating License No. NPF-14 dated July 17, 1982.

This amendment contains a revision to License Condition 2.C.28(g)(1).

PENNSYLVANIA POWER & LIGHT COMPANY
BY:

N. W. Curtis

N. W. Curtis
Vice President - Engineering and
Construction - Nuclear

Sworn to and subscribed before me
this *29th* of *April*, 1983.

Martha C. Barto
Notary Public

MARTHA C. BARTO, Notary Public
Allentown, Lehigh County, Pa.
My Commission Expires Jan. 13, 1986

8305030153 830429
PDR ADCK 05000387
PDR



the completion of the staff's review of this report.

(ii) By October 31, 1982, PP&L shall submit its proposal for conforming with item II.F.2 of NUREG-0737 in view of the BWR Owners Group report.

(e) Modification of Automatic Depressurization System Logic (II.K.3.18, SER, SSER#1, SSER#2, SSER#3)

(a) By October 1, 1982, PP&L shall evaluate the alternative design modifications of the BWR Owners Group relative to the logic for the automatic depressurization system, submit such evaluation, and propose modifications to the NRC for review and approval.

(b) Prior to startup following the first refueling outage, PP&L shall implement the approved alternative logic modification of the automatic depressurization system.

(f) Effect of Loss of Power on Alternating Current Pump Seals (II.K.3.25, SER, SSER#1)

Prior to startup after the first refueling, PP&L shall provide an emergency power supply to the cooling system for the recirculation pump seals.

(g) Upgrade Emergency Support Facilities (III.A.1.2, SER, SSER #1, SSER #2)

PP&L shall complete its Emergency Response Facilities as follows:

- | | |
|-------------------------------------|---|
| (1) Safety Parameter Display System | - September ^{December} 30, 1983 |
| (2) Emergency Operations Facility | - October 1, 1982 |
| (3) Technical Support Center | - October 1, 1982 |

(29) SRV Inplant Test (Section 6.2.1.8, SER; 6.2.1.5, SSER#1)

Within 90 days following the staff receipt of the report providing the results of the inplant SRV test at the LaSalle, Unit 1 facility, PP&L shall furnish the results of its evaluation and application of the LaSalle data to assure that for Susquehanna Unit 1, the delta T between bulk and local pool temperatures will not exceed 10°F.