

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8306300092 DOC. DATE: 83/06/27 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Informs of emergency power supply addition to recirculation pump seals cooling sys. Action on License Condition 2.C.28(f) closed.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: 1cy NMSS/FCAF/PM.

05000387

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR/DL/ADL	1 0	NRR LB2 BC	1 0
	NRR LB2 LA	1 0	PERCH, R. 01	1 0
INTERNAL:	ELD/HDS4	1 0	IE FILE	1 0
	IE/DEPER/EPB 36	3 3	IE/DEPER/IRB 35	1 0
	IE/DEQA/QAB 21	1 1	NRR/DE/AEAB	1 0
	NRR/DE/CEB 11	1 1	NRR/DE/EHEB	1 0
	NRR/DE/EQB 13	2 2	NRR/DE/GB 28	2 2
	NRR/DE/MEB 18	1 1	NRR/DE/MTEB 17	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SGEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/PSRB	1 1	NRR/DL/SSPB	1 0
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ICSB 16	1 1	NRR/DSI/METB 12	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	<u>REG FILE</u> 04	1 1
	RG1	3 3	RM/DDAMI/MIB	1 0
EXTERNAL:	ACRS 41	6 6	BNL (AMDTs ONLY)	1 1
	DMB/DSS (AMDTs)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	2 2	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTR 55 ENCL 48



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

JUN 27 1983

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSE CONDITION 2.C.28(f)
ER 100450 FILE 841
PLA-1718

Docket No. 50-387

Dear Mr. Schwencer:

In response to License Condition 2.C.28(f) of License No. NPF-14, Pennsylvania Power & Light Company has provided an emergency power supply to the cooling system for the recirculation pump seals.

This completes our action on this license condition.

Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

cc: R. L. Perch - NRC

13001
1/0

8306300092 830627
PDR ADOCK 05000387
F PDR