

GENERAL ELECTRIC

APPLICABLE TO:
PUBLICATION NO. NEDO-22128
T. I. E. NO. 82NED051
TITLE GE BWR Extended Load Line
Limit Analysis for Susquehanna
Steam Electric Station Unit 1
ISSUE DATE May 1982

ERRATA And ADDENDA SHEET

NO. 2
DATE June 1983
NOTE: Correct all copies of the applicable publication as specified below.

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
1.	Pages 3-2 and 3-3	Replace with revised pages 3-2 and 3-3.

8308220282 830815
PDR ADOCK 05000387
PDR



11

11

1. For those transients and accidents that are sensitive to variations in power and flow, the 105% power/100% flow (licensing basis) point must be shown to be a more limiting condition than any condition within the expanded operating region (i.e., the shaded region of Figure 2-1).
2. In no instance shall the ratio of power to flow intentionally exceed the ratio defined by the APRM rod block line.
3. The slope of the APRM rod block line must be such that flow increases are capable of compensating for xenon buildup while increasing reactor power.
4. The consequences of all accidents and transients analyzed in the FSAR and subsequent amendments and the license submittals must remain within the limits normally specified for such events.
5. Reactor power ascension from minimum recirculation pump speed to full power shall be directly attainable through combined control rod movement and recirculation flow increase without violation of either the power/flow line or PCIOMRs.

To meet these objectives, analyses were performed for typical BWRs and conclusions were drawn concerning the safety consequences of operation in the extended operating region (shaded area of Figure 1-1). It was shown by specific analyses for the SSES-1 equilibrium cycle of the current GE fuel type that these conclusions were applicable to SSES-1, Cycle 1.

3.3 ANALYSIS AND RESULTS

3.3.1 Stability

3.3.1.1 Channel Hydrodynamic Conformance to the Ultimate Performance Criterion

The channel performance calculation for SSES-1, Cycle 1, was performed for the most limiting load line limit case at the point of intersection of the extrapolated rod block line and natural circulation power. The results are given below.

Channel Hydrodynamic PerformanceExtrapolated Rod Block Line* -
Natural Circulation PowerChannel TypeDecay Ratio

P8x8R Channel

0.81

At this most responsive condition, the most responsive channels are clearly within the bounds of the ultimate performance criteria of ≤ 1.0 decay ratio at all attainable operating conditions.

3.3.1.2 Reactor Conformance to Ultimate Performance Criterion

The limiting reactor core stability condition for this analysis is the extrapolated rod block line* - natural circulation condition. The results of the calculation are shown below.

Reactor Core StabilityExtrapolated Rod Block Line* -
Natural Circulation PowerDecay Ratio, X_2/X_0

0.96

These calculations show the reactor to be in compliance with the ultimate performance criteria, including the most responsive condition.

3.3.2 Loss-of-Coolant Accident

A discussion of low-flow effects on LOCA analyses for all operating plants (Reference 2) has been presented to and was approved by the NRC (Reference 3). The LOCA analysis for SSES-1 (contained in Reference 1) is applicable in the power flow domain discussed in this report.

3.3.3 Pressurization Transients

As shown in Reference 1, the most limiting transient for SSES-1 equilibrium cycle is the Load Rejection without bypass. The results of numerous transient

*RB $\leq 0.58 W + 50\%$, where W is recirculation flow in % of rated.



1941
1942
1943
1944
1945
1946
1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025

1941

1942

1943

1944 1945 1946 1947 1948 1949 1950 1951 1952 1953 1954 1955 1956 1957 1958 1959 1960 1961 1962 1963 1964 1965 1966 1967 1968 1969 1970 1971 1972 1973 1974 1975 1976 1977 1978 1979 1980 1981 1982 1983 1984 1985 1986 1987 1988 1989 1990 1991 1992 1993 1994 1995 1996 1997 1998 1999 2000 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025